

**Comhairle
Chondae
Chill Dara**
Naomh Mhuire
An Nás



**Kildare
County
Council**
St. Mary's
Naas

E-mail: secretar@kildarecoco.ie


Main Switch

Phone: (045) 873800

Fax: (045) 876875

This matter is being dealt with by:

Date: 27/10/2005 Your Ref:



Environment
Section


Ms. Liz Leacy,
Licensing Unit,
Office of Licensing & Guidance,
EPA,
P.O. Box 3000,
Johnstown Castle Estate,
Co. Wexford.

Re: **Revision of IPC Licence (Reg. No. 756) – AHP Manufacturing B.V., T/a
Wyeth Medica Ireland.**

Dear Ms. Leacy,

I refer to your letter of the 30th August 2005 in the above and enclose herewith sanitary authority response.

Yours sincerely,


A. GREENE,
Acting Senior Executive Officer.

EPA

MAIN FILE ☒
PUBLIC FILE ☒
EVALUATION FILE KOB
DATE 2/11/05 go

SANITARY AUTHORITY RESPONSE
re: SECTION 52 OF THE WASTE MANAGEMENT ACTS, 1996 to 2003

Name & Address of Sanitary Authority: Kildare County Council, St. Mary's, Naas,
County Kildare. **FAO:** Mr. Joseph Boland,
**Director of Services, Transportation &
Environment.**

Waste Reg. No. 756

Waste Facility: Buckley's Cross Roads, Old Connell,
Newbridge
Co. Kildare.

Waste Licence Applicant: AHP Manufacturing B.V. Trading as
Wyeth Medica Ireland

Consent: Indicate Yes to one of the following statements:


Consent granted subject to the consent conditions outlined below	YES
Consent granted without conditions	
Consent refused ^{Note 1}	

Note 1 Where it is proposed to refuse permission the reasons for the refusal should be clearly outlined in the response.

GENERAL CONSENT CONDITIONS	Condition to be included (Yes/No)
1. No specified emission from the installation shall exceed the emission limit value set out in <i>Schedule B: Emissions Limits to Sewer</i> . There shall be no other emission to sewer of environmental significance.	YES
2. The licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as out in <i>Schedule C</i> .	YES
3. Monitoring and analytical equipment shall be operated and maintained as necessary so that monitoring accurately reflects the discharge or emission.	YES
4. The licensee shall permit authorised persons of the Agency and the Sanitary Authority to inspect, examine and test, at all reasonable times, any works and apparatus installed, in connection with the process effluent, and to take samples of the process effluent.	YES
5. All automatic monitors and samplers shall be functioning at all times (except during maintenance and calibration) when the	YES

activity is being carried on unless alternative sampling or monitoring has been agreed in writing by the Agency for a limited period. In the event of the malfunction of any continuous monitor, the licensee shall contact the Agency as soon as practicable, and alternative sampling and monitoring facilities shall be put in place. Prior written agreement for the use of alternative equipment, other than in emergency situations, shall be obtained from the Agency.	
6. The licensee shall record all sampling, analyses, measurements, examinations, calibrations and maintenance carried out in accordance with the requirements of this licence.	YES
7. The licensee shall provide safe and permanent access to all on-site sampling and monitoring points and to off-site points as required by the Agency.	YES
8. The licensee shall at no time discharge or permit to be discharged into the sewer any liquid matter or thing which is or may be liable to set or congeal at average sewer temperature or is capable of giving off any inflammable or explosive gas or any acid, alkali or other substance in sufficient concentration to cause corrosion to sewer pipes, penstock and sewer fittings or the general integrity of the sewer.	YES
9. In the event of any incident which relates to discharges to sewer, having taken place, the licensee shall notify the Agency, Local Authority and Sanitary Authority as soon as practicable after the incident.	YES

ADDITIONAL GENERAL CONSENT CONDITIONS in respect of discharges or emissions to sewers, in accordance with Section 52 of the Waste Management Acts, 1996 to 2003 <i>(specify, if required)</i>
The E.P.A. should also include the other conditions listed under Condition 6 "Emissions to Sewer", in the existing I.P.C. Licence (Reg No. 673), but modified as required.



For inspection purposes only.
Consent of copyright owner required for any other use.

Limit Values for Process Effluent to Sewer

Schedule B: Emission Limits

Waste licence application Register No. 756

Emission Point Reference No: SE - 1 (WP1)

Emission to (sewer description): Local Authority Foul Sewer

Volume to be emitted: Maximum in any one day: 777 m³

Maximum rate per hour: 60 m³

Parameter <i>(delete parameters which are not applicable)</i>	Emission Limit Value	
	Daily Mean Concentration (mg/l)	Daily Mean Loading (kg/day)
BOD	800	180
COD	2000	450
Suspended Solids	500	150
pH	6.0 – 9.0	
Temperature	35 ^o C	
ADDITIONAL PARAMETERS <i>(if required)</i>		
Total Phosphorus (as P)	20	6
Total Nitrogen	70	21
Ammonia (as N)	30	9
Chloride	500	350
Sodium	800	550
Sulphate	100	30
Oils, Fats, Greases	50	15

Additional parameters including solvents of active substances as required by E.P.A.		
*See Appendix 1		

For inspection purposes only.
Consent of copyright owner required for any other use.

Frequency of Monitoring Process Effluent to Sewer

Schedule C

Waste Licence application Register No. 756

Emission Point Reference No: SE – 1 (WP1)

Parameter <i>(delete parameters which are not applicable)</i>	Monitoring Frequency (e.g. monthly, quarterly, annually)	Sampling Type <i>(grab, composite)</i>
Flow to sewer		
Temperature		
PH		
BOD	As per Schedule 2(iii) of existing I.P.C. Licence	
COD		
Suspended Solids		
ADDITIONAL PARAMETERS <i>(if required)</i>		
Ammonical Nitrogen	Monthly	Composite
Total Organic Carbon	“	“
Chloride	“	“
NH4 – N	“	“
Orthophosphate (asP)	“	“
Nitrate	“	“

*See Appendix 1

SANITARY AUTHORITY CHARGES	
Charge per cubic meter of process effluent (per s52 of the Waste Management Acts, 1996 to 2003)	* €0.48/M ³
Payment Frequency	Once per year
Annual Monitoring Costs	€434/year

* Charges may vary annually.

Signed on behalf of Kildare County Council

Algreene

Date 27th October 2005

For inspection purposes only.
Consent of copyright owner required for any other use.