



Reg: 774. P0443-02

COMHAIRLE BUIRGE CHLUAIN MEALA
CLONMEL BOROUGH COUNCIL

Ms Dorota Richards,
Office of Licensing and Guidance,
Environmental Protection Agency,
Johnstown Castle,
Wexford.

31st May 2006.

Our Ref: 34/1/07.

**RE: Clarification Sought by EPA re: Bulmers IPPC License Application
(Consent Conditions).**

Dear Ms Richards,

Please find clarifications the Agency requested on consent conditions for Bulmer's IPPC Revised Licence Application. The consent parameters related only to the year 2006 and did not take account (Form did not provide for) of increases in reserve capacity allocated to Bulmer's for years 2007, 2008 and 2009.

Table 1 contains the additional information requested by the Agency and should clarify the issue for the years 2007, 2008 and 2009.

Table 1 – Limit values for discharge to Eastern Sewer Clonmel

Year	2006	2007	2008	2009
Total BOD kg/d	1616	1708	1800	1891
Total BOD kg/hr	110	116	122	129
Max Daily Volume Cu. M/d	1770	1870	1970	2070
Max Vol Cu.M/Hr	120	127	134	140
Suspended Solids kg per Day	1000	1000	1000	1000
Suspended Solids kg/hr	50	50	50	50

Other conditions and Emission Limit Value will remain unchanged over the period of the license from that stipulated in the consent form for 2006. (BOD:COD loading Ratio will remain unchanged from 2006)

Hopefully this clarifies the situation sufficiently but if you request further information please contact me.

Yours faithfully,


Michael Hayes,
Borough Engineer.



Comhairle Buirge Chluain Meala,
Áras an Bhaile,
Cluain Meala,
Contae Thiobraid Árann.
Telefón 052-83800
Facs 052-83805
E-mail: tclerk@clonmelbc.ie

Clonmel Borough Council,
Town Hall,
Clonmel,
County Tipperary.
Telephone 052-83800
Fax 052-83805
E-mail: tclerk@clonmelbc.ie