

Comhairle Chontae Uíbh Fhailí

Tel: 057 9346800 • Fax: 057 9346868

Website: www.offaly.ie

email: secretar@offalycoco.ie

Offaly County Council

Áras an Chontae,
Charleville Road,
Tullamore,
Co. Offaly.



EPA

Environmental Protection Agency
Headquarters, PO Box 3000,
Johnstown Castle Estate
Co. Wexford.

MAIN FILE ☒PUBLIC FILE ☒26th June 2006EVALUATION FILE alDATE 30/6/06 go

Attention: Ms Dorota Richards

Re: Review of IPC Licence Reg. No.180, Glanbia Fresh Pork, Carrick Road, Edenderry.

I refer to your correspondence of 10th May in relation to the above (Reg. No. 761).

Offaly County Council note Glanbia's Objection No.3, Schedule B.3 Emissions to Sewer.

Offaly County Council has no objection to Glanbia's revised proposal to maintain a Total Nitrogen Limit of 55mg/l, with Kjeldhal Nitrogen set at 35mg/l and Nitrate set at 20mg/l, instead of previously sought limits of 50 mg/l Kjeldhal Nitrogen and 30 mg/l Nitrate.


Therefore with reference to Schedule B.3 Emissions to the Sewer, the following limits should apply with respect to Nitrate and Kjeldahl Nitrogen.

| Parameter | Emission Limit Value |
|--------------------------|----------------------|
| Nitrate (mg/l) | 20 |
| Kjeldahl Nitrogen (mg/l) | 35 |


All other Emission Limit Values and comments as per our letter dated 27th March 2006 still apply. Emission Limit Values are with reference to the existing municipal treatment plant in Edenderry as it is. The proposed upgrade referred to in E G Pettit's correspondence is not expected to be complete until circa mid 2007.

Yours faithfully,

Michael Roche
Director of Services,
Roads and Infrastructure Section.



offaly.ie - your community online

| | | |
|---|---|----------------------|
|  | Offaly County Council | EPA |
| | Comhairle Chontae Uíbh Fhailí | |
| | FAX COVER PAGE | |
| | ROADS & WATER SERVICES Bóithre & Seirbhísí Uisce | |
| | MAIN FILE _____ | ✓ Hand Copy Rec 29/6 |
| | PUBLIC FILE _____ | |
| | EVALUATION FILE _____ | |
| | DATE _____ | |

Áras an Chontae
Charleville Road
Tullamore
Co Offaly

offaly.ie - our community online
[http:// www.offaly.ie/yourcouncil.html](http://www.offaly.ie/yourcouncil.html)

Teileafón/ Phone: 0506 46800
Roads & Water Department: 0506 46890

Chuig/ To:

Facs/ Fax: 0506 29231

Ms. Dorota Richards,
Environmental Protection Agency
Johnstown Castle,
Wexford

Ó/ From:

Michael Roche
Director of Services
Roads and Water Services,
Offaly County Council

Uimhir Facs/ Fax number:

053 916 0699

Ext.:

Email:

Uimhir Leathanach (ceann seo sam airiamh)
Number of pages (inc. cover page)

2

Dáta/ Date:

29th June 2006


TEACHTAIREACHT/ MESSAGE:

F.A.O. DOROTA RICHARDS

Please find attached correspondence re: IPC Licence reg. 180. Original forwarded by post.

Regards,

Michael Roche
Director of Services
Roads and Water Services

| | |
|---|---|
| RECEIVED | |
| Time | 1000 |
| 29 JUN 2006 | |
| Signature |  |
| Environmental Protection Agency, HQ. P.O. Box 3000, Johnstown Castle Estate, Co. Wexford. | |

Comhairle Chontae Uíbh Fhailí

Tel: 057 9346800 • Fax: 057 9346868

Website: www.offaly.ie

email: secretar@offalycoco.ie

Offaly County Council

Áras an Chontae,
Charleville Road,
Tullamore,
Co. Offaly.



Environmental Protection Agency
Headquarters, PO Box 3000,
Johnstown Castle Estate
Co. Wexford.

26th June 2006

Attention: Ms Dorota Richards

Re: Review of IPC Licence Reg. No.180, Glanbia Fresh Pork, Carrick Road, Edenderry.

I refer to your correspondence of 10th May in relation to the above (Reg. No. 761).

Offaly County Council note Glanbia's Objection No.3, Schedule B.3 Emissions to Sewer.

Offaly County Council has no objection to Glanbia's revised proposal to maintain a Total Nitrogen Limit of 55mg/l, with Kjeldhal Nitrogen set at 35mg/l and Nitrate set at 20mg/l, instead of previously sought limits of 50 mg/l Kjeldhal Nitrogen and 30 mg/l Nitrate.

Therefore with reference to Schedule B.3 Emissions to the Sewer, the following limits should apply with respect to Nitrate and Kjeldahl Nitrogen.

| Parameter | Emission Limit Value |
|--------------------------|----------------------|
| Nitrate (mg/l) | 20 |
| Kjeldahl Nitrogen (mg/l) | 35 |

All other Emission Limit Values and comments as per our letter dated 27th March 2006 still apply. Emission Limit Values are with reference to the existing municipal treatment plant in Edenderry as it is. The proposed upgrade referred to in E G Pettits correspondence is not expected to be complete until circa mid 2007.

Yours faithfully,

Michael Roche
Director of Services,
Roads and Infrastructure Section.