



Fingal County Council Comhairle Contae Fhine Gall

Mr Stuart Huskisson
Office of Licensing & Guidance,
Environmental Protection Agency,
McCumiskey House,
Richview,
Clonskeagh,
Dublin 14.

ENVIRONMENTAL PROTECTION AGENCY

29 MAR 2007

OFFICE OF LICENSING & GUIDANCE

27th March 2007

Water Services Department
Postal Address
P.O. Box 174,
County Hall,
Swords,
Fingal,
Co. Dublin

An Roinn Seirbhíse Uisce
Bosca 174,
Áras an Chontae,
Sord,
Fine Gall,
Contae Átha Cliath

Office Address
Grove Road,
Blanchardstown,
Fingal,
Dublin 15

Telephone
01 890 5970
Facsimile
01 890 5919
Email
waterservices@fingalcoco.ie
www.fingalcoco.ie

Amendments to consent to discharge –
Swords Laboratories, t/a Bristol Myers Squibb Cruiserath.


Dear Sir,

Please find enclosed an amendment to Schedule C of the consent to discharge form submitted to the EPA on 2nd March 2007, for Swords Laboratories, t/a Bristol Myers Squibb Cruiserath, Mulhuddart, Dublin 15.

The amendment concerns the metal monitoring frequency and Organic Compounds monitoring frequency which should both be changed to quarterly monitoring. Apologies for these errors.

If you have any queries regarding this matter do not hesitate to contact David Devine on 8906776 or by email at: david.devine@fingalcoco.ie.

Yours Faithfully,



David Devine
A/Senior Executive Engineer
Water Pollution Control

Water is precious. Let's conserve it.
Tá uisce luachmhar. Caomhnaímís é.



Frequency of Monitoring Trade Effluent to Sewer

Schedule C - Monitoring of Emissions to Sewer

Emission point reference no: **E30794, N24135**

Parameter	Monitoring Frequency	Sampling Method/Type (grab, continuous)
Flow to sewer	Continuous	Continuous
BOD	Fortnightly	24-hr composite sample
COD	Fortnightly	24-hr composite sample
Suspended Solids	Fortnightly	24-hr composite sample
Sulphates (as SO ₄)	Fortnightly	24-hr composite sample
pH	Continuous	Continuous
Temperature	Continuous	Continuous

ADDITIONAL PARAMETERS

(if required)

Phosphates (as PO ₄ -P)	Fortnightly	24-hr composite sample
Chlorides	Fortnightly	24-hr composite sample
Zinc	Quarterly	24-hr composite sample
Chromium	Quarterly	24-hr composite sample
Copper	Quarterly	24-hr composite sample
Lead	Quarterly	24-hr composite sample
Nickel	Quarterly	24-hr composite sample
Arsenic	Quarterly	24-hr composite sample
Fluoride (as F-)	Fortnightly	24-hr composite sample
Organic Compounds*	Quarterly	24-hr composite sample
Toxicity (ISO 8196)	Quarterly	Grab Sample
Activated Sludge		

* Screening for Priority Pollutant List Substances. This analysis shall include those organic solvents in use in the processes, which are likely through normal process operations, to be discharged to the wastewater stream being discharged to sewer, and particularly including the Dangerous Substances- Toluene, Dichloromethane and Xylenes.