



Rialtas Áitiúil
Local Government

Environmental
Protection Agency

22 MAY 2007

Comhairle Chontae
Loch Garman

Wexford County Council
County Hall
Wexford

Tel 053 9176500
Fax 053 9143406
email postmaster@wexfordcoco.ie

E.P.A.
Office of Licensing and Guidance
P.O Box 3000
Johnstown Castle Estate.
Wexford

21 May 2007

**Re: Application for review of a Waste Licence from South East Recycling
Co. Ltd, Wexford (Reg No W0111-03)**

Attention : Ms Suzanne Wylde

Dear Ms Wylde,

I wish to advise you that Wexford County Council hereby give consent to the discharge to the public sewer from South East Recycling at Pembrokestown Wexford of process effluent in accordance with the parametric values stated on the EPA Waste Application form (enclosed).

Yours sincerely,

D.Cullinan
Senior Engineer
Water Services (Operations)

100 Years of Community Service
Céad bliain ag tabhairt seirbhíse don phobal

SANITARY AUTHORITY RESPONSE

Name of Sanitary Authority: *Wexford County Council*

Address: *County Hall,
Spawell Road,
Wexford*

FAO: *Mr Niall McGuigan,
Director of Services, Water, Environment & Emergency Services*

Name of Facility: *South East Recycling Company Ltd*

Waste Reg. No: *W0111-03*

Address: *Pembrokestown,
Carrighawn,
Wexford*

Consent: Indicate Yes to one of the following statements:

Consent granted subject to the consent conditions outlined below.	<i>Yes.</i>
Consent granted without conditions.	
Consent refused ^{Note 1} .	

Note 1 Where it is proposed to refuse permission the reasons for the refusal should be clearly outlined in the response.

GENERAL CONSENT CONDITIONS	Condition to be Included (Yes/No)
1. The licensee shall permit authorised persons, of the Agency and Sanitary Authority, to inspect, examine and test, at all reasonable times, any works and apparatus installed in connection with the process effluent and to take samples of the process effluent	<i>Yes.</i>
2. The licensee shall at no time discharge or permit to be discharged into the sewer any liquid matter or thing that is or may be liable to set or congeal at average sewer temperature or is capable of giving off any inflammable or explosive gas or any acid, alkali or other substance in sufficient concentration to cause corrosion to sewer pipes, perstock and sewer fittings or the general integrity of the sewer.	<i>Yes.</i>

ADDITIONAL GENERAL CONSENT CONDITIONS
In respect of discharges or emissions to sewers, in accordance with Section 99E of
the Environmental Protection Agency Acts 1992 and 2003
(Specify, if required)

*For inspection purposes only.
Consent of copyright owner required for any other use.*

Section 99E of the Environmental Protection Agency Acts 1992 and 2003

99E - (1) Where the Agency proposes to grant a licence (including a revised licence) which involves a discharge of any trade effluent or other matter (other than domestic sewage or storm water) to a sewer, it shall obtain the consent of the sanitary authority in which the sewer is vested, or by which the sewer is controlled, to such a discharge being made.

(2) Where consent is sought in accordance with subsection (1), the Agency may specify a period (which period shall not in any case be less than 4 weeks from the date on which the consent is sought) within which the consent may be granted subject to, or without, conditions or refused; any consent purporting to be granted (whether subject to or without conditions) after the expiry of that period, or any decision given purporting to refuse consent after that expiry, shall be invalid and in those circumstances the Agency may proceed to grant the licence concerned as if the requirements of subsection (1) had been satisfied.

(3) Subject to subsection (4), a consent under subsection (1) may be granted subject to or without conditions and if it is granted subject to conditions the Agency shall include in the licence or revised licence concerned conditions corresponding to them or, as the Agency may think appropriate, conditions more strict than them.

(4) The conditions that may be attached to a consent by a sanitary authority under this section are the following and no other conditions, namely conditions-

(a) relating to-

(i) the nature, composition, temperature, volume, level, rate, and location of the discharge concerned and the period during which the discharge may, or may not, be made,

(ii) the provision, operation, maintenance and supervision of meters, gauges, manholes, inspection chambers and other apparatus and other means for monitoring the nature, extent and effect of emissions,

(iii) the taking and analysis of samples, the keeping of records and furnishing of information to the sanitary authority,

(b) specifying a date not later than which any conditions attached under this section shall be complied with,

(c) relating to, providing for or specifying such other matter as may be prescribed.

(5) A sanitary authority may request the Agency to review a licence or revised licence to which this section relates-

(a) at intervals of not less than 3 years from the date on which the licence or the revised licence is granted, or

(b) at any time with the consent, or on the application, of the person making, causing or permitting the discharge, or

(c) at any time if-

(i) the sanitary authority has reasonable grounds for believing that the discharge authorised by the licence or revised licence is, or is likely to be, injurious to public health or is likely to render the waters to which the sewer concerned discharges unfit for use for domestic, commercial, industrial, fishery (including fish-farming), agricultural or recreational uses or is, or is likely to be otherwise, a serious risk to the quality of the waters,

(ii) there has been a material change in the nature or volume of the discharge,

(iii) there has been a material change in relation to the waters to which the sewer concerned discharges, or

(iv) further information has become available since the date on which the licence or revised licence was granted relating to polluting matter present in the discharge concerned or relating to the effects of such matter,

and the Agency shall consider and may comply with such request and shall have regard to any submission on the matter received from the sanitary authority.

For inspection purposes only.
Consent of copyright owner required for any other use.



WASTE Application Form

TABLE 1.3(i): EMISSIONS TO SEWER (One page for each emission)
Please refer to attachment 18.4 (Sewer Discharge Licence) in attached Report.
Emission Point:

Emission Point Ref. No.:	FW1
Location of connection to sewer:	Discharge to public sewer at Pembrokestown
Grid Ref. (10 digit, SE, SN):	303871; 119583
Name of sewage undertaker:	Water Services Department, Wexford County Council

Emission Details:

(i) Volume to be emitted			
Normal/day	m ³	Maximum/day	40m ³
Maximum rate/hour	m ³		

(ii) Period or periods during which emissions are made, or are to be made, including daily or seasonal variations (start-up / shutdown to be included):

Periods of Emission (avg)	min/hr	hr/day	day/yr
---------------------------	--------	--------	--------

For inspection purposes only.
Consent of copyright owner required for any other use.

200

WASTE Application Form

TABLE E.3(ii) EMISSIONS TO SEWER - Characteristics of the emission (1 table per emission point)

Emission point reference number: FW1

Parameter	Prior to treatment			As discharged			% Efficiency	
	Max hourly average (mg/l)	Max. daily average (mg/l)	kg/day	kg/year	Max. hourly average (mg/l)	Max. daily average (mg/l)		kg/day
BOD		400						
COD		1500						
Suspended solids		500						
Temperature		10°C						
pH		6-9 pH units						
Chloride		350						
Sulphate		250						
Oil, Fat and grease		40						
Arsenic		0.075						
Chromium		0.005						
Copper		0.005						
Lead		0.005						
Zinc		0.1						
Nickel		0.002						
Cyanide		0.010						
Fluoride		0.5						

For inspection purposes only. Consent of copyright owner required for any other use.

0041901 Application Form.doc

ANNEX - Standard Form