


# Comhairle Contae Chorcaí Cork County Council

Noeleen Roche, Recd 21/6/07  
Licencing Unit  
Office of Licencing and Guidance  
Environmental Protection Agency  
Johnstown Castle Estate  
County Wexford  
Ireland

Environmental Department,  
Inniscarra, Co. Cork.  
Tel: (021) 4532700 • Fax (021) 4532727  
Web: [www.corkcoco.ie](http://www.corkcoco.ie)  
An Rannóg Comhshaoil,  
Inis Cara, Co. Chorcaí.  
Fón: (021) 4532700 • Faics (021) 4532727



Subject :IPC Reg. No. P0136-03 Pfizer Overseas Pharmaceuticals and CP Pharmaceuticals International C.V. trading as Pfizer Ireland Pharmaceuticals, Little Island Co. Cork


15<sup>th</sup> June 2007

Dear Ms Roche,

I wish to acknowledge receipt of the correspondence regarding the IPPC determination due to be issued by the agency in respect of the above named facility.

Cork County Council wish to object to the temperature set at 32°C for the emission to sewer in respect of the process discharge PW1 from the above named site. The completed section 99 response set the temperature at 30°C. Following representations from the company to Cork County Council a temporary value of 32°C was permitted until further information was provided on the likely impact of an increase in temperature on the sewer. The discharge from the premises combines with discharges from other premises and Cork County Council are concerned that this may impact on the sewer network if the temperatures of the effluent are above ambient temperatures. The applicant is required to perform a temperature feasibility study and an impact assessment of temperature on the sewer network before the temperature can be increased above 30°C which is the permitted value in the Section 99 to 32°C. The applicant is furthermore required to perform VOC analysis of both the liquid effluent and the head space in the sewer above the effluent discharge location as part of this study. Upon receipt of this study Cork County Council will review the request and issue a formal decision in this regard in respect of the permitted temperature to sewer from the above licenced facility. Should you have any queries or clarification my contact details are supplied below  
Phone no. 021-4532700/E mail [valerie.hannon@corkcoco.ie](mailto:valerie.hannon@corkcoco.ie)

Yours Sincerely

  
Valerie Hannon,  
Executive Scientist,  
Environment Directorate,  
Cork County Council.

✓  
✓  
✓  
26/6/07 H

