

Fingal County Council Comhairle Contae Fhine Gall

Ms. Aoife Loughnane,
Office of Licensing and Guidance,
Environmental Protection Agency,
McCumiskey House,
Richview,
Clonskeagh Road,
Dublin 14.

1 2 JUL 2007

ENVIRONMENTAL PROTECTION AGENCY

OFFICE OF LICENSING & GUIDANCE

11 July 2007

Re: Fingal County Council Response to Swords Laboratory Objections.

Dear Madam.

Fingal County Council has reviewed the Objections made by Swords Laboratory regarding the Proposed Determination issued by the EPA on 20th April 2007. Several of the objections relate to conditions drafted by the EPA concerning Air / Waste 7 and general management of the IPPC Licence.

Consent conditions relating to the trade effluent discharge to sewer which were objected to were:

C.3.2 It has been requested that temperature be monitored <u>daily</u> rather than <u>continuously.</u>

Fingal County Council agrees to Sweed's Laboratory's request to monitor temperature daily rather than continuously.

It has been requested that effluent Toxicity testing (aquatic and activated sludge) be reduced from <u>quarterly</u> testing to <u>annual</u> testing.

Fingal County Council requests that effluent Toxicity testing be carried out <u>quarterly</u> in order to document protection of the performance of the Swords Wastewater Treatment Plant and the local receiving waters.

If you require any further information, please contact Mr. David Devine, A/Senior Executive Engineer on 01 8906776 or by email at david.devine@fingalcoco.ie.

Yours Faithfully,

David Devine

A/Senior Executive Engineer

Water Services Department Postal Address

P.O. Box 174, County Hall, Swords, Fingal,

Co. Dublin

An Roinn Seirbhísí Uisce

Bosca 174, Áras an Chontae, Sord, Fine Gall, Contae Átha Cliath

Office Address Grove Road, Blanchardstown, Fingal, Dublin 15

Telephone
01 890 5970
Facsimile
01 890 5919
Email

waterservices@fingalcoco.ie www.fingalcoco.ie



