


SUB (1)



AN ROINN COMHSHAOIL,
OIDHREACHTA AGUS
RIALTAIS ÁITIÚIL
DEPARTMENT OF
THE ENVIRONMENT, HERITAGE
AND LOCAL GOVERNMENT

28 November 2007

Our Ref: E2007/134
Your Ref: WO240 - 01



Ms Catherine O'Keeffe
Programme Officer
Office of Climate, Licensing & Resource Use
Environmental Protection Agency
Johnstown Castle Estate
Co. Wexford

Re: Waste Licence Application – Advanced Environmental Solutions, Nenagh, Co. Tipperary

DÚN SCÉINE
LÁNA FHEARCAIR,
BAILE ÁTHA CLIATH 2

A Chara,

DÚN SCÉINE
HARCOURT LANE
DUBLIN 2

I refer to the above-mentioned application for a waste licence. The Department of the Environment, Heritage and Local Government recommends, from a nature-conservation point of view, that the water drainage system should incorporate grit as well as oil interceptors.

Mise le meas,

Tel: +353 1 888 3109
Fax: +353 1 478 0806

Mary Boothman
Development Applications Unit

For inspection purposes only
Consent of copyright owner required for any other use.