

# Comhairle Contae Chorcaí Cork County Council

Environmental Department,  
Inniscarra, Co. Cork.  
Tel: (021) 4532700 • Fax (021) 4532727  
Web: [www.corkcoco.ie](http://www.corkcoco.ie)



An Rannóg Comhshaoil,  
Inis Cara, Co. Chorcaí.

For: (021) 4532700 • Faxes: (021) 4532727  
Email: [Grasainn@www.corkcoco.ie](mailto:Grasainn@www.corkcoco.ie)

Protection Agency

25 JAN 2008

Marie Harris,  
Licencing Unit  
Office of Climate Change,  
Licencing and resource Use,  
Environmental Protection Agency  
Johnstown Castle Estate  
County Wexford  
Ireland

22<sup>nd</sup> January 2008

Subject: IPPC Reg. No. 134-03 Corden Pharma Ltd., Wallingstown, Little Island Co. Cork

Dear Ms Harris,

I wish to acknowledge receipt of the correspondence regarding the objections to the IPPC determination issued by the agency in respect of the above named facility. Cork County Council wish to respond to the objections that relate to the discharge to sewer in the operational area of Cork County Council by the applicant in the letter of objections dated 11<sup>th</sup> October 2007 received by the agency.

### Section B.3 – Emissions To Sewer – Temperature

The sanitary authority have requested that the applicant monitor for temperature and that the applicant complies with an upper limit of 25°C on a continuous basis. After considering the response from the applicant the sanitary authority are agreeable to an upper temperature limit of 30 °C for the continuous monitoring that is undertaken on the site.

Cork County Council also request that the existing practice be maintained of daily recording of temperature as part of the operational practices and that this information is available upon request by Cork County Council from the applicant.

All other issues raised are a matter for the agency

Should you have any queries or clarification my contact details are supplied below  
Phone no. 021-4532700/E mail [valerie.hannon@corkcoco.ie](mailto:valerie.hannon@corkcoco.ie)

Yours Sincerely

*Valerie Hannon*

Valerie Hannon,  
A/Snr Executive Scientist,  
Environment Directorate,  
Cork County Council.

c.c. Kevin Sugrue, Senior Engineer Water Services, Cork County Council

IPPC Register number P0134-03

Cork County Council response to objections

Page 1 of 1

