

# Comhairle Contae Chorcaí Cork County Council

Josephine Kennedy,  
Office of Climate, Licencing and Resource Use  
Environmental Protection Agency  
HQ PO Box 3000  
Johnstown Castle Estate  
County Wexford  
Ireland

Subject :IPPC Reg. No. 0571-03 –Millipore Ireland B.V.

Environmental Directorate,  
Inniscarra, Co. Cork.  
Tel. No. (021) 4532700 • Fax No. (021) 4532727  
Web: [www.corkcoco.ie](http://www.corkcoco.ie)  
An Stiúrthóireacht Comhshaoil,  
Inis Cara, Co. Corcaigh.  
Fón: (021) 4532700 • Faics: (021) 4532727  
Suíomh Gréasáin: [www.corkcoco.ie](http://www.corkcoco.ie)



ENVIRONMENTAL PROTECTION  
AGENCY

18 NOV 2009

16<sup>th</sup> November 2009

Dear Ms Kennedy,

I wish to acknowledge receipt of the correspondence in relation to the objection received from Millipore regarding the sanitary Authority response to Section 99E request concerning a consent to discharge to sewer in relation to the above named premises.

**Company objection point number 1 (reference condition 5.1)**- Cork County Council are agreeable to the limit of 35°C at SE1 as requested by the company. The chief concern of Cork County Council is that the temperature limit at the final discharge is 30°C. This has been proven by Millipore in previous submissions and Cork County Council hereby give consent to the limit of 35°C at SE1.

**Company objection point number 2 (reference condition 5.1)** - Cork County Council are agreeable to the monitoring of the temperature limit of 35°C at SE1 at this location as requested by the company. Compliance monitoring for temperature purposes is acceptable at this location.

**Company objection point number 3 (reference condition 5.1)** Cork County Council are agreeable to the limit of 30mg/l of F.O.G. at SE1 however the company must have working fats oil grease control measures in place for canteen facilities in the site at all times. Millipore are also required to monitor the final discharge location annually for Fats, Oil and Grease and the limit at that location is set at 20mg/l of Fats Oil and Grease.

**Company objection point number 4 (reference condition 5.1)**- Cork County Council are agreeable to a limit of 500mg/l of Sulphate at SE3

**Company objection point number 5 (reference condition 5.1)**- Cork County Council are agreeable to a limit of 500mg/l of Sulphate at SE7

**Company objection point number 6 (reference condition 6.2)** related to IPPC licence & matter for the agency, outside the scope of Section 99 E from Cork County Council

Points of clarification- related to IPPC licence & matter for the agency, outside the scope of Section 99 E from Cork County Council

Should you have any queries or clarification my contact details are supplied below

Phone no. 021-4532707

E mail [valerie.hannon@corkcoco.ie](mailto:valerie.hannon@corkcoco.ie)

Yours Sincerely

Valerie Hannon,  
A/Senior Executive Scientist  
Wastewater Laboratory

c.c. Finbar O'Keefe Staff Officer, Environment Directorate, Cork County Council

c.c. Pat O'Mahony ,Senior Engineer Water Services South Cork County Council

