

Joe Reilly

From: Noeleen Keavey
Sent: 16 November 2010 15:31
To: Joe Reilly
Subject: FW: New submission entered for Reg no: W0269-01. (Reference Number: W0269-01-101116032303)
Attachments: FassaroeRstone2Epa.pdf
Importance: High
Follow Up Flag: Follow up
Flag Status: Flagged

Joe – Can you process – ta very much

From: Vincent O' Sullivan [<mailto:vincent.osullivan@dublincity.ie>]
Sent: 16 November 2010 15:23
To: Licensing Staff
Subject: New submission entered for Reg no: W0269-01. (Reference Number: W0269-01-101116032303)
Importance: High

Title: Mr
First Name: Vincent
SurName: O' Sullivan
Organisation Name: Dublin City Council
Address Line 1: 68-70 Marrowbone Lane
Address Line 2: Dublin 8
Address Line 3:
County: Dublin
Post Code:
Phone Number: 01 222 4252
Email: vincent.osullivan@dublincity.ie

*For inspection purposes only.
Consent of copyright owner required for any other use.*



Dublin City Council

Comhairle Cathrach Bhaile Átha Cliath

Water Services, Environment & Engineering Department,
68/70 Marrowbone Lane, Dublin 8

Rannóg Uisce, Roinn Comhshaoil agus Innealtóireachta,
68/70 Lána Mhuire Mhaith, Baile Átha Cliath 8
T. 01 222 4252 F. 01 4542 937 E. «vincent.osullivan@dublincity.ie»

Environmental Licensing Programme,
Office of Climate Change, Licensing & Resource Use,
Environmental Protection Agency,
PO Box 3000,
Johnstown Castle Estate,
Co. Wexford.

FAO Mr. Michael Owens

November 16th, 2010

Re : FASSAROE WASTE RECOVERY FACILITY

FASSAROE AVENUE, FASSAROE, BRAY CO. WICKLOW

WASTE LICENCE APPLICATION

REGISTER NUMBER W0269-01

Dear Mr Owens,

The following is the report of the Dublin City Council Water Services Division on the above application.

"Dublin City Council has no objection to the issuing of a waste licence at the above facility on the basis of the documentation submitted as the proposed works do not impact on the Dublin City Council 33inch arterial watermain which crosses the site.

We do however have a concern about the presence on the site of a septic tank in close proximity to the watermain. This matter requires further investigation and it is likely that the septic tank will have to be relocated."

Yours faithfully,

Vincent O' Sullivan,
Senior Executive Engineer,
Water Services Division,
Dublin City Council.