



COMHAIRLE CHONTAE LONGFOIRT

Longford County Council

ARAS AN CHONTAE • GREAT WATER STREET • LONGFORD
Tel: (043) 46231 Fax: (043) 41233 Website: www.longfordcoco.ie

Longford

County Council

Aras an Chontae
Great Water Street
Longford

Comhairle Chontae
Longfoirt

Economic Development,
Urban & Rural Renewal,
Cultural & Recreational

Community & Enterprise 43313

Corporate Services 43311

Cultural Services 41124

Human Resources 43309

Finance

Finance 43424

Motor Tax 43401

Housing & Social Policy,
Planning & Building Control

Housing 43409

Planning 43427

Sanitary Services
& Environmental

Civil Defence 46228


Environment 43356

Fire Station 47136

Water Services 43428

Transportation, Road
Development & Maintenance
& Road Safety

Roads 43341



Wednesday, 06 April 2011

FAO Josephine Kennedy
Environmental Protection Agency
Office of Climate, Licensing & Resource Use
Johnstown Castle Estate,
County Wexford.

Re: IPPC License Application – C & D Foods – Ref: P0908-01.

Dear Josephine,

I refer to your letter, dated 11th January 2011, Ref No: P0908-01, advising Longford County Council of application for IPPC license by C & D Foods Ltd.

Under the new IPPC license, Longford County Council confirms that it will allow a higher flow rate, up to **400m³/day**, at a daily maximum concentration of **400mg/ltr BOD**.

Please note that the existing maximum loading limit of 80 kg/day BOD still has to be adhered to.

Also note that the **16.66 m³/hour** maximum flow rate is for **effluent only** from the C&D wastewater process. LCC understands that there will be additional cooling waters and reverse osmosis backwash, giving an additional maximum clear water discharge of **10m³/h** to LCC sewer network. The effluent and clear water streams will be combined before discharge to sewer at point SEP1.

This continues the existing load limits and is acceptable to LCC with regard to the loading on our WWTP for the immediate future.

Please note that the existing and reserved loading will be subject to a review, to be conducted with C&D Ltd later this year, with regard to compliance with the relevant policy requirements, and in particular Department of the Environment Circular L4/02 (WSP) Re: Implementation of Water Services. Pricing Policy – Model Water and Waste Water Agreements and General Guidance.

Any queries, please contact the undersigned.

Yours sincerely,

Brian Ross

Brian Ross
Senior Executive Engineer
Water Services
Longford County Council
Direct Line: 043 3343447 / Mobile: 086 8204299 / E-Mail: bross@longfordcoco.ie