

## Grainne Oglesby

---

**Subject:** FW: P0057-03 Kingspan Insulation Limited - IW S99E Objection Response 160628  
**Attachments:** P0057-03 Kingspan Insulation Limited - IW S99E Objection Response 160628.pdf

---

**From:** Ronan Connolly  
**Sent:** 28 June 2016 15:48  
**To:** Orla Harrington  
**Subject:** P0057-03 Kingspan Insulation Limited - IW S99E Objection Response 160628

Hi Orla,

Please find attached Irish Water's response in relation to objections raised by Kingspan Insulation Limited in their letter to the Agency dated 20<sup>th</sup> May 2016.

Kind Regards,

Ronan

Ronan Connolly  
Environmental Policy and Licensing Support Officer

**Uisce Éireann**

Teach Colvill, 24-26 Sráid Thalbóid, Baile Átha Cliath 1, Éire

**Irish Water**

Colvill House, 24-26 Talbot Street, Dublin 1, Ireland

T: +353 1 8925386

[www.water.ie](http://www.water.ie)

 Please consider the environment before printing this e-mail

---

This email has been scanned by the Symantec Email Security.cloud service.  
For more information please visit <http://www.symanteccloud.com>

---

For inspection purposes only.  
Consent of copyright owner required for any other use.



Ms Orla Harrington  
Environmental Licensing Programme,  
Office of Climate Licensing & Resource Use  
EPA Headquarters,  
P.O. Box 3000,  
Johnstown Castle Estate,  
Co. Wexford.

Uisce Éireann  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

Irish Water  
PO Box 6000  
Dublin 1  
Ireland

T: +353 1 89 25000  
F: +353 1 89 25001  
www.water.ie

28 June 2016

Ref.: Kingspan Insulation Limited – P0057-03- Comments in relation to objection to Irish Water conditions attached to consent to discharge to sewer under Section 99E of the EPA Act, as amended.

Dear Ms Harrington,

Please find below Irish Water's comment in relation to objections made by Kingspan Insulation Limited in accordance with article 26 of the Environmental Protection Agency (Industrial Emissions) (Licensing) Regulations 2013. In making comment, Irish Water refer to Request 5, 6 and 8 of the Kingspan Insulation Limited letter dated 20<sup>th</sup> May 2016 and respond accordingly;

**Request 5: Modification of reporting frequency, Condition 11.13**

Irish Water is satisfied that the word "monthly" within Condition 11.13 of the Proposed Determination may be replaced by "quarterly".

**Request 6: Modification of wording in Condition 11.15 and Method of Sampling in Schedule C.3.2 (Monitoring of emissions to sewer).**

Irish Water is satisfied that a representative sample of trade effluent discharged to sewer may be obtained via a grab sample if certain onsite operational processes are adhered to. Therefore the following amendments to the proposed determination would be acceptable to Irish Water:

**Condition 11.15 of Proposed Determination:**

Delete the word "composite".

**Schedule C.3.2 (Monitoring of emissions to sewer) of Proposed Determination:**


Amend Note 1 to read as follows:

"Samples of trade effluent shall be obtained via representative grab samples unless otherwise requested in writing by Irish Water."

**Request 8: Details contained in Schedule B3.1: Emissions to Sewer**

Irish Water is satisfied that the changes to Schedule B3.1 as outlined in Request 8 of the Kingspan Insulation Limited letter dated 20<sup>th</sup> May 2016 can be incorporated into the Proposed Determination.

Yours sincerely,



Mark O' Callaghan

Authorised Signatory

Asset Strategy

Irish Water

For inspection purposes only.  
Consent of copyright owner required for any other use.