

Noeleen Keavey

From: Irish Water - Section 99
Sent: 03 September 2018 17:56
To: Noeleen Keavey
Subject: RE: P0096-03 Saint Gobain Performance Plastics Ireland Limited - Applicant Objection
Attachments: S99E_Saint Gobain P0096_03_objection response.pdf

Dear Ms Keavey,

Please find attached Irish Water's response in relation to the Saint Gobain Performance Plastics Ireland Limited objection dated 17 June 2018 which was forwarded to Irish Water by the Agency.

If you have any further queries in relation to this issue please do not hesitate in contacting me.

Kind Regards,

Ronan

Ronan Connolly
Licensing Manager – Wastewater Source Control & Licensing

Uisce Éireann
Teach Colvill, 24-26 Sráid Thalbóid, Baile Átha Cliath 1, Éire
Irish Water
Colvill House, 24-26 Talbot Street, Dublin 1, Ireland

T: +353 1 8925386


www.water.ie

 Please consider the environment before printing this e-mail

For inspection purposes only.
Consent of copyright owner required for any other use.

From: Noeleen Keavey [mailto:n.keavey@epa.ie]
Sent: 26 June 2018 14:33
To: Section99
Subject: FW: P0096-03 Saint Gobain Performance Plastics Ireland Limited - Applicant Objection

From: Noeleen Keavey
Sent: 26 June 2018 14:17
To: 
Subject: P0096-03 Saint Gobain Performance Plastics Ireland Limited - Applicant Objection

Mr. Ronan Connolly
Environmental Policy & Licensing Support Specialist
Irish Water
Colvill House
24/26 Talbot Street
Dublin 1

26 June 2018

Reg No: P0096-03

For inspection purposes only.
Consent of copyright owner required for any other use.

Dear Mr Connolly

I refer to the licence application by Saint Gobain Performance Plastics Ireland Limited, Kilrush, County Clare (Reg. No.P0096-03) and in particular to the proposed determination that issued on 22 May 2018.

The Agency has received an objection from the applicant on 19 June 2018. Part of the applicant's objection relates to conditions attached to your Council's consent to discharge to sewer under Section 99(E) of the EPA Act as amended.

In light of the above, I enclose a copy of the objection and I am to request your comments on the objection insofar as it relates to the conditions imposed by your Council.

An early response to this letter would be appreciated so that consideration of this application may proceed.

Yours sincerely

Environmental Licensing Programme
Office of Environmental Sustainability



Ms Noeleen Keavey
Environmental Licensing Programme,
Office of Climate Licensing & Resource Use
EPA Headquarters,
P.O. Box 3000,
Johnstown Castle Estate,
Co. Wexford.

Uisce Éireann
Bosca OP 6000
Báile Átha Cliath 1
Éire

Irish Water
PO Box GU00
Dublin 7
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

31 August 2018

Ref.: Saint Gobain Performance Plastics Ireland Limited (SGPPL) (Reg. No.P0096-03).- Comments in relation to objection particular to the proposed determination issued on 22 May 2018.

Dear Ms Keavey,

Please find below Irish Water's comments in relation to the objection items raised by SGPPL in correspondence dated 17 June 2018.

Objection Item 2 – Condition B.3 Emission to sewer

Irish Water has consulted further with SGPPL on the particulars of their objection related to the trade effluent emission to sewer. Irish Water is now satisfied to amend the original Section 99E consent to include the following revised emission limit values:

Emission Point Reference No : SE1

Location: East of site near PTFE production Building (E099837, N156035)

Volume of Trade effluent to be emitted: Maximum in any one day: 5 m³
Maximum in any hour: 5 m³

Parameter	Emission Limit Values	
pH	6-9 pH Units	
Temperature	35°C	
Toxicity	10 TU	
	Concentration (mg/l)	Daily Load (kg/day)
BOD	3,000	15
COD	10,000	50
Total Suspended Solids	800	4
Total Phosphorus	15	0.075

Total Nitrogen	100	0.5
FOG	100	0.5
Detergents	50	0.25
Sulphate	800	4
Chloride	1000	5

If you have any further query in relation to this issue please do not hesitate to contact me.

Yours sincerely,



Ronan Connolly

Licensing Manager

Wastewater Source Control & Licensing

Irish Water

For inspection purposes only.
Consent of copyright owner required for any other use.