

Noeleen Keavey

From: Licensing Staff
Sent: 22 October 2018 16:59
To: Noeleen Keavey
Subject: FW: New submission entered for Reg no: P1087-01. (Reference Number: P1087-01-181022043454)
Attachments: epa-dis-ai-1018.doc
Importance: High

FYI

From: Aisling Donegan [mailto:aisling.donegan@fisheriesireland.ie]
Sent: 22 October 2018 16:35
To: Licensing Staff <L.Staff@epa.ie>
Subject: New submission entered for Reg no: P1087-01. (Reference Number: P1087-01-181022043454)
Importance: High

Title: Ms
First Name: Aisling
SurName: Donegan
Organisation Name: Inland Fisheries Ireland
Address Line 1: Ardnaree House
Address Line 2: Abbey Street
Address Line 3: Ballina
County: Mayo
Post Code:
Email: aisling.donegan@fisheriesireland.ie



This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>

22 October 2018

Re: Industrial Emissions Licence Application by AbbVie Ireland NL B.V.Reg. No. P1087-01

Dear Sir/Madam,

This site is located adjacent to a watercourse which flows into the Shannon Eighter stream and onto the Doonally River or Willsbrough Stream. Surface water drainage is discharged directly into this watercourse. The Doonally River provides habitat for brown trout and sea trout which supports the local sea angling resource. This site drains into the Cummeen Strand/Drumcliff Bay (Sligo Bay) SAC less than one kilometre downstream of the site. This SAC is designated for the protection of sea and river lamprey. The Doonally River catchment has been allocated good ecological status in the River Basin Management Plan and this status must be protected. Having reviewed the proposed application, IFI has the following comments to make:

- 1 An emergency response plan must be drawn up with IFI included as a notifiable body in case of a polluting discharge to surface water or ground water.
- 2 A fire water recovery system must be in place to ensure no polluted water can enter the adjacent watercourse via the surface water drainage network
- 3 Irish Water is satisfied that the discharge will not have a negative impact on the sewer network or the final effluent discharge from the Sligo Waste Water Treatment Plant.

IFI requests an acknowledgement from the EPA of receipt of this submission.

Yours sincerely

Aisling Donegan
Senior Fisheries Environmental Officer

epa-dis-ai-1018

For inspection purposes only.
Consent of copyright owner required for any other use.