

## IRISH WATER RESPONSE



Irish Water  
Colvill House  
24/26 Talbot Street  
Dublin 1

**Name of Facility:** Forge Hill Recycling Unlimited Company    **Reg. No:** W0291-02

**Location Address:** Forge Hill Waste Transfer Station, Forge Hill, Cork, T12 AK44

Consent granted subject to the consent conditions outlined below.	Yes
Consent granted without conditions.	N/A
Consent refused <sup>Note 1</sup> .	N/A

Indicate either "Yes" or "No" to the request to include the condition(s) below in the licence as follows:

<b>GENERAL CONSENT CONDITIONS</b>	<b>Condition to be Included (Yes/No)</b>
1. Other than the trade effluent authorised to be discharged under this licence, the licensee shall at no time discharge or cause or permit to discharge into sewer trade effluent or any other matter unless authorised in writing by Irish Water.	Yes
2. Monitoring and analysis equipment shall be installed, operated and maintained as necessary, so that all monitoring, accurately reflects the emission/discharge.	Yes
3. The licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as set out below and as in accordance with <i>Schedule C: Control &amp; Monitoring</i> , of this licence. (i) Sampling and analysis shall be undertaken by competent staff in accordance with documented operating procedures. (ii) Such procedures shall be subject to a programme of Analytical Quality Control using appropriate control standards with evaluation of test responses. (iii) Where any analysis is sub-contracted it shall be outsourced to a competent laboratory.	Yes
4. The licensee shall ensure that any trade effluent generated from canteen activities shall pass through appropriate grease removal equipment prior to discharge to sewer.	Yes
5. The licensee shall maintain and implement a detailed programme for maintenance of all plant and equipment based on the instructions issued by the manufacturer/supplier or installer of the equipment or as otherwise approved in writing by IW.	Yes
6. A summary report of volumes of trade effluent and other matter discharged to the sewer along with monitoring and analysis data as specified in <i>Schedule B: Emission Limits to Sewer</i> and <i>Schedule C: Control &amp; Monitoring</i> , of this licence shall be forwarded to both Irish Water and the Local Authority in a manner and timeframe as may be specified by Irish Water.	Yes
7. The licensee shall <b>prepare, maintain and implement</b> (text highlighted in black bold for new licence only) / <b>maintain and implement</b> (text highlighted in green bold for reviews) a Schedule of Environmental Objectives and Targets. The Schedule shall, as a minimum, provide for a review of all operations and processes, including	Yes

<p>an evaluation of practicable options, for energy and resource efficiency, the use of cleaner technology, cleaner production and the prevention, reduction and minimisation of waste and shall include waste reduction targets, reduction and diversion of storm water runoff to sewer. The Schedule shall include time frames for the achievement of set targets and shall address a five-year period as a minimum. The schedule shall be reviewed annually and submitted to Irish Water as requested.</p>	
<p>8. The licensee shall pay to Irish Water such sum as may be determined from time to time, having regard to the variations in the cost of providing drainage and the variation in effluent reception and treatment costs. Payment is to be made on demand from Irish Water.</p>	Yes
<p>9. Silt Traps and Oil Separators The Licensee shall, within six months of date of grant of this licence, install and maintain silt traps and oil separators at the Facility:</p> <ul style="list-style-type: none"> <li>(i) Silt traps to ensure that all storm water discharges, other than from roofs, from the facility pass through a silt trap in advance of discharge;</li> <li>(ii) An oil separator on the storm water discharge from yard areas. The separator shall be a Class I Class II full retention/by-pass separator. &lt;&lt;EPA to select as appropriate&gt;&gt;</li> <li>(iii) The silt traps and separator shall be in accordance with I.S. EN-858-2: 2003 (separator systems for light liquids).</li> </ul>	Yes
<p>10. The licensee shall conclude an end user agreement with Irish Water.</p>	No
<p>11. In the event of any incident which relates to discharges to sewer having taken place, the licensee shall notify Irish Water and the Local Authority, in the manner prescribed by Irish Water, as soon as practicable after such an incident.</p>	Yes
<p>12. No alteration to, or reconstruction in respect of, the activity, or any part thereof, that would, or is likely to, result in</p> <ul style="list-style-type: none"> <li>(i) a material change or increase in: <ul style="list-style-type: none"> <li>▪ the nature or quantity of any emission;</li> <li>▪ the abatement/treatment or recovery systems;</li> <li>▪ the range of processes to be carried out;</li> <li>▪ the fuels, raw materials, intermediates, products or wastes generated, or</li> </ul> </li> <li>(ii) any changes in: <ul style="list-style-type: none"> <li>▪ site management, infrastructure or control with adverse environmental significance;</li> </ul> </li> </ul> <p>shall be carried out or commenced without prior notice to, and without the approval of, the Agency and/or Irish Water as appropriate.</p>	Yes

<p><b>ADDITIONAL GENERAL CONSENT CONDITIONS</b>  In respect of discharges or emissions to sewers, in accordance with Section 99E of the Environmental Protection Agency Act 1992, as amended.  <i>(Specify, if required)</i></p>

**Limit Values for Process Effluent to Sewer**

**Schedule B: Emission Limits**

Emission Point Reference No.: **FW1**

Emission to (*sewer description*): Irish Water Sewer.

Volume of Trade effluent emitted:      Maximum in any one day:      **100 m<sup>3</sup>**  
 Maximum in any hour:      **30 m<sup>3</sup>**

Parameter	Emission Limit Values		
pH	6-9 pH Units		
Temperature	25°C		
	Daily Concentration (mg/l)	Mean Daily Load (kg/day) <sup>Note 1</sup>	Max. Daily Load (kg/day)
BOD	1000	10	100
COD	2000	20	200
Total Suspended Solids	500	5	50
Fats, Oils and Greases (FOG)	100		-
Total Nitrogen (as N)	100		-
Sulphates (as SO <sub>4</sub> )	750		
Detergents (as MBAS)	10		
Cadmium (Cd)	0.005		
Chromium (Cr)	0.5		
Copper (Cu)	0.5		
Lead (Pb)	0.005		
Mercury (Hg)	0.001		
Nickel (Ni)	0.5		
Phenols	0.5		
Silver (Ag)	0.5		
Zinc (Zn)	0.5		

Total Heavy Metals	1		
Mineral Oils	5		
Total Hydrocarbons	5		
VOCs	1		
Toxicity	10TU		

**Note 1** Mean to be calculated over a monthly period

For inspection purposes only.  
 Consent of copyright owner required for any other use.

## Frequency of Monitoring Process Effluent to Sewer

### Schedule C

Emission Point Reference No.:

SE1

Parameter	Monitoring Frequency (Note 1)	Analysis Method/Technique
Flow to sewer	Continuous	On-line flow meter with recorder
Temperature	Continuous	On-line temperature probe with recorder
pH	Continuous	On-line pH probe & recorder
Chemical Oxygen Demand	Weekly	Standard Method
Total Suspended Solids	Weekly	Standard Method
cBiochemical Oxygen Demand	Monthly	Standard Method
Fats, Oils and Greases (FOG)	Monthly	Standard Method
Sulphates (as SO <sub>4</sub> )	Quarterly	Standard Method
Detergents (as MBAS)	Quarterly	Standard Method
VOCs	Quarterly	Standard Method
Total Nitrogen (as N)	Bi-annually	Standard Method
Mineral Oils	Bi-annually	Standard Method
Total Hydrocarbons	Bi-annually	Standard Method
Full Metal Suite	Annually	Standard Method
Respirometry	As requested	Standard Method
Toxicity	As requested	Standard Method

**Note 1:** All samples with the exception of Flow (Continuous), pH (Grab Sample) and Temperature (Grab Sample) shall be taken on a 24 hour flow proportionate composite sampling basis. In this regard, a composite sample for testing purposes shall be defined as any sample extracted from the sampling apparatus between 8.00 a.m. and 12.00 p.m. noon on any day for which normal operational activities have been ongoing for the previous 24 hours.

**Note 2:** Sampling shall take place on alternate week days on a rolling basis to ensure representative samples are obtained for site operations which may vary across the working week.

### Control of Emissions to Sewer

**Description of treatment: Removal of suspended solids, mineral oils and fats, oils and greases.**

Control Parameter	Monitoring	Key Equipment
Suspended solids & Mineral oils/Total hydrocarbons	Suspended solids/silt & Mineral oils/Total hydrocarbons removal	Class I Full Retention Interceptor
Fats, oil and grease removal	Fats, oil and grease content in trade effluent as a result of canteen activities.	Grease removal equipment <sup>Note 1</sup>

**Note 1:** Grease removal equipment shall comply with the requirements of European Standards (EN) or Plumbing and Drainage Institute (PDI) Standards or as otherwise specified by Irish Water

Signed on behalf of *Christina Wilson*

*M Deary*

Date *19/4/19*

For inspection purposes only  
Consent of copyright owner required for any other use.