

From: [Licensing Staff](#)
To: [Noeleen Keavey](#)
Cc: [Grainne Oglesby](#)
Subject: FW: Response to objection on licence P1087-01 EIMS:0680256
Date: 07 February 2020 16:40:50
Attachments: [Objection Response for Objection #OS005949 AbbVie.docx](#)

FYI

From: WWSCL@water.ie <WWSCL@water.ie>
Sent: 07 February 2020 16:13
To: Licensing Staff <licensing@epa.ie>
Subject: Response to objection on licence P1087-01 EIMS:0680256

Dear Sir /Madam,

Please find attached Irish Water's response to the letter of objection received on 15/01/2020 regarding AbbVie Ireland NL B.V. Old Bundoran Road Ballytivnan Co. Sligo .



Kind Regards,

Irish Water Team

Uisce Éireann

Teach Colvill, 24-26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86, Éire

Irish Water

Colvill House, 24-26 Talbot Street, Dublin 1, D01 NP86, Ireland

Phone : 1850 278 278

Email: WWSCL@water.ie

www.water.ie

@IrishWater

For inspection purposes only.
Consent of copyright owner required for any other use.

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential, commercially sensitive and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited and may be unlawful. Irish Water accepts no liability for actions or effects based on the prohibited usage of this information. Irish Water is neither liable for the proper and complete transmission of the information contained in this communication nor for any delay in its receipt. If you received this in error, please contact the sender and delete the material from any computer. E-Mail may be susceptible to data corruption, interception and unauthorised amendment. Irish Water accepts no responsibility for changes to or interception of this e-mail after it was sent or for any damage to the recipients systems or data caused by this message or its attachments. Please also note that messages to or from Irish Water may be monitored to ensure compliance with Irish Water's policies and standards and to protect our business. Irish Water, a designated activity company limited by shares, is a subsidiary of Ervia, established pursuant to the Water Services Act 2013, having its principal place of business at Colvill House, 24-26 Talbot Street, Dublin 1.



Environmental Licensing Programme
Office of Environmental Sustainability
EPA Headquarters,
PO Box 3000,
Johnstown Castle Estate,
Co. Wexford

Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Ref: Objection #OS005949 - Applicant objection for Reg No: [P1087-01]

07/Feb/2020

Dear Sir/Madam,

In relation to your letter dated 13th January 2020, we wish to respond as follows:

Condition 5.5.3 – Irish Water confirms that this condition supersedes the requirements of the sites existing Discharge to Sewer Licence number IW-DTS-927442-01, issued by Irish Water and thus means that AbbVie are no longer required to satisfy the conditions outlined in the Irish Water Licence.

Schedule B.3 – Discharge Location SE1 – Irish Water note that AbbVie have altered the location of SE1 from (169924E, 337330E) to (169925E, 337335N) grid coordinates.

Schedule B.3 – Volume to be emitted 12.7m³ – Irish Water confirm that this figure (12.7m³) solely covers the amount of trade effluent emitted from the low strength process waste tanks.

Schedule C.3.1 - Control of emissions to Sewer – Irish Water confirm that monitoring is to be undertaken immediately following the wastewater treatment plant at monitoring point SE1A.

Schedule C.3.2 - Monitoring of emissions to Sewer – Irish Water confirm that parameters are to be monitored following wastewater treatment at emission monitoring point SE1B.

Yours sincerely,

Wastewater Source Control & Licensing