

From: [Licensing Staff](#)
To: [Aisling F Kehoe](#)
Subject: FW: Section 99E Consent Request P1121-01 has been issued EIMS:0680000640
Date: Wednesday 24 February 2021 12:52:59
Attachments: [image.png](#)
[EPA Cover Letter.pdf](#)
[P1121_01_Dublin_Aerospace_Limited_Response_Consent.pdf](#)

From: WWSCL@water.ie <WWSCL@water.ie>
Sent: Wednesday 24 February 2021 09:18
To: Licensing Staff <licensing@epa.ie>
Cc: Enda Collins <ecollins@water.ie>; pricing <pricing@water.ie>; Irish Water - Section 99 <section99@water.ie>
Subject: Section 99E Consent Request P1121-01 has been issued EIMS:0680000640

Dear Sir/Madam,

Please find attached the S99E response P1121-01 for Dublin Aerospace Limited, Ashbourne Industrial Estate, Ashbourne, Co. Meath .

Best Regards,

Irish Water Team

Uisce Éireann

Teach Colvill, 24-26 Sráid Thalbóig, Baile Átha Cliath 1, D01 NP86, Éire

Irish Water

Colvill House, 24-26 Talbot Street, Dublin 1, D01 NP86, Ireland

Phone : 1850 278 278

Email: WWSCL@water.ie

www.water.ie

[@IrishWater](#)



The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential, commercially sensitive and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited and may be unlawful. Irish Water accepts no liability for actions or effects based on the prohibited usage of this information. Irish Water is neither liable for the proper and complete transmission of the information contained in this communication nor for any delay in its receipt. If you received this in error, please contact the sender and delete the material from any computer. E-Mail may be susceptible to data corruption, interception and unauthorised amendment. Irish Water accepts no responsibility for changes to or interception of this e-mail after it was sent or for any damage



Environmental Licensing Programme,
EPA Headquarters,
PO Box 3000,
Johnstown Castle Estate,
Co. Wexford

Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Reg No: P1121-01

22/Feb/2021

Dear Sir/Madam,

I refer to your correspondence dated 24/Jan/2020 relating to an application from Dublin Aerospace Limited, Ashbourne Industrial Estate, Ashbourne, Co. Meath for **Section 99E Consent Request**.

Please find attached Irish Water's consent to discharge to sewer subject to the consent conditions attached.

If you have any further queries please do not hesitate to contact us.

Yours sincerely

Wastewater Source Control & Licensing

Stiúrthóirí / Directors: Cathal Marley (Chairman), Niall Gleeson, Eamon Gallen, Yvonne Harris, Brendan Murphy, Maria O'Dwyer

Oifig Chláraithe / Registered Office: Teach Colvill, 24-26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86 / Colvill House, 24-26 Talbot Street, Dublin 1, D01 NP86

Is cuideachta ghníomhaíochta ainmnithe atá faoi theorainn scaireanna é Uisce Éireann / Irish Water is a designated activity company, limited by shares.

Uimhir Chláraithe in Éirinn / Registered in Ireland No.: 530363

HW-HP

REV012

IRISH WATER RESPONSE

Irish Water
Colvill House
24/26 Talbot Street
Dublin 1

Name of Facility: Dublin Aerospace Limited

Reg. No: P1121-01

Location Address: Dublin Aerospace Limited, Ashbourne Industrial Estate, Ashbourne, Co. Meath, A84 ND23

Consent granted subject to the consent conditions outlined below.	Yes
Consent granted without conditions.	N/A
Consent refused ^{Note 1} .	N/A

The sewer, to which this consent relates, is vested or controlled by Irish Water.	Yes
Does the consent constitute a material change with respect to the associated waste water discharge authorisation? ^{Note 2} (If 'Yes', you must attach to the consent a document describing the measures to be taken to bring about compliance with the waste water discharge authorisation including timeframes where appropriate.)	No

Indicate either "Yes" or "No" to the request to include the condition(s) below in the licence as follows:

GENERAL CONSENT CONDITIONS	Condition to be Included (Yes/No)
1. Other than the trade effluent authorised to be discharged under this licence, the licensee shall at no time discharge or cause or permit to discharge into sewer trade effluent or any other matter unless authorised in writing by Irish Water.	Yes
2. Monitoring and analysis equipment shall be installed, operated and maintained as necessary, so that all monitoring, accurately reflects the emission/discharge.	Yes
3. The licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as set out below and as in accordance with <i>Schedule C: Control & Monitoring</i> , of this licence. (i) Sampling and analysis shall be undertaken by competent staff in accordance with documented operating procedures. (ii) Such procedures shall be subject to a programme of Analytical Quality Control	Yes

using appropriate control standards with evaluation of test responses. (iii) Where any analysis is sub-contracted it shall be outsourced to a competent laboratory.	
4. The licensee shall ensure that any trade effluent generated from canteen activities shall pass through appropriate grease removal equipment prior to discharge to sewer.	Yes
5. The licensee shall maintain and implement a detailed programme for maintenance of all plant and equipment based on the instructions issued by the manufacturer/supplier or installer of the equipment or as otherwise approved in writing by IW.	Yes
6. A summary report of volumes of trade effluent and other matter discharged to the sewer along with monitoring and analysis data as specified in <i>Schedule B: Emission Limits to Sewer</i> and <i>Schedule C: Control & Monitoring</i> , of this licence shall be forwarded to both Irish Water and the Local Authority in a manner and timeframe as may be specified by Irish Water.	Yes
7. The licensee shall prepare, maintain and implement (text highlighted in black bold for new licence only) / maintain and implement (text highlighted in green bold for reviews) a Schedule of Environmental Objectives and Targets. The Schedule shall, as a minimum, provide for a review of all operations and processes, including an evaluation of practicable options, for energy and resource efficiency, the use of cleaner technology, cleaner production and the prevention, reduction and minimisation of waste and shall include waste reduction targets, reduction and diversion of storm water runoff to sewer. The Schedule shall include time frames for the achievement of set targets and shall address a five-year period as a minimum. The schedule shall be reviewed annually and submitted to Irish Water as requested.	No
8. The licensee shall pay to Irish Water such sum as may be determined from time to time, having regard to the variations in the cost of providing drainage and the variation in effluent reception and treatment costs. Payment is to be made on demand from Irish Water.	Yes
9. Silt Traps and Oil Separators The Licensee shall, within six months of date of grant of this licence, install and maintain silt traps and oil separators at the Facility: (i) Silt traps to ensure that all storm water discharges, other than from roofs, from the facility pass through a silt trap in advance of discharge; (ii) An oil separator on the storm water discharge from yard areas. The separator shall be a Class I Class II full retention/by-pass separator. <<EPA to select as appropriate>> (iii) The silt traps and separator shall be in accordance with I.S. EN-858-2: 2003 (separator systems for light liquids).	Yes
10. The licensee shall conclude an end user agreement with Irish Water.	Yes
11. In the event of any incident which relates to discharges to sewer having taken place, the licensee shall notify Irish Water and the Local Authority, in the manner prescribed by Irish Water, as soon as practicable after such an incident.	Yes
12. No alteration to, or reconstruction in respect of, the activity, or any part thereof, that would, or is likely to, result in (i) a material change or increase in: <ul style="list-style-type: none"> the nature or quantity of any emission; the abatement/treatment or recovery systems; the range of processes to be carried out; the fuels, raw materials, intermediates, products or wastes generated, or (ii) any changes in: <ul style="list-style-type: none"> site management, infrastructure or control with adverse environmental significance; shall be carried out or commenced without prior notice to, and without the approval of, the Agency and/or Irish Water as appropriate .	Yes
13. No specified emission from the installation shall exceed the emission limit values set out in Schedule B: Emission Limits, of this licence. There shall be no other emissions of environmental significance.	Yes

<p>14. The licensee shall undertake a desktop assessment and subsequent screening of trade effluent generated as a result of onsite activities for priority substances, priority hazardous substances and watchlist substances as listed in Tables 11,12 & 13 of S.I. No. 272/2009 – EC Environmental Objectives (Surface Waters) Regulations 2009, as amended. A report on the assessment and screening shall be submitted to Irish Water within twelve months of the date of grant of this licence.</p> <p>The licensee shall ensure that where substances are identified as being present in the trade effluent, measures are taken to reduce, eliminate or phase out their emission as required and each are assessed against risks posed to the biological processes at the receiving Irish Water wastewater treatment plant (D0034-01) and the sludge generated at the plant. The licensee shall also ensure that identified substances are assessed against potential risks to public health and the whole aquatic environment. The environmental assessment shall specifically assess resultant concentrations of substances in the receiving environment against their applicable environmental quality standards (EQS) and environmental objectives established by S.I. No. 272/2009.</p> <p>Subsequent desktop assessments, screenings and reports shall be repeated at intervals commensurate with changes to the characteristics of the trade effluent as a result of changes to onsite processes/materials to be processed or as requested by Irish Water.</p>	<p>Yes</p>
--	------------

<p>ADDITIONAL GENERAL CONSENT CONDITIONS In respect of discharges or emissions to sewers in accordance with Section 99E of the Environmental Protection Agency Act 1992, as amended. <i>(Specify, if required)</i></p>

Limit Values for Process Effluent to Sewer***Schedule B: Emission Limits***Emission Point Reference No.: **SE1**Emission to **(sewer description)**: IW sewer located at R135

Volume of Trade effluent emitted: Maximum in any one day: 57.5 m³
 Maximum in any hour: 2.5 m³

Parameter	Emission Limit Values	
pH	6-10 pH Units	
Temperature	35°C	
	Concentration (24 Hr. Composite Sample (mg/l))	Daily Load (kg/day)
BOD 5 days with inhibition (Carbonaceous BOD)	120	6.5
COD - Cr	200	11.5
Suspended Solids	500	28.5
Sulphate	500	28.5
Anionic Surfactants /Detergents (MBAs)	100	5.5
Fats, Oils & Greases	100	5.5
Ortho-Phosphate (as PO4)	50	2.5
Fluoride	50	2.5
Mineral Oils	10	0.5
Chromium	0.5	0.025
Copper	0.5	0.025
Nickel	0.5	0.025
Silver	0.1	0.005
Tin	2	0.1
Cyanide	0.2	0.01
Cadmium	0.05	0.01

Frequency of Monitoring Process Effluent to Sewer**Schedule C**

Emission Point Reference No.:

SE1

Parameter	Monitoring Frequency (Note 1)	Analysis Method/Technique
Flow to sewer	Continuous	On-line flow meter with recorder
pH	Continuous	pH electrode/meter & recorder
Temperature	Continuous	On-line Temperature probe with recorder
BOD 5 days with inhibition (Carbonaceous BOD)	Monthly ^{Note 1}	Standard Method
COD - Cr	Monthly ^{Note 1}	Standard Method
Suspended Solids	Monthly ^{Note 1}	Gravimetric
Sulphate	Monthly ^{Note 1}	Standard Method
Anionic Surfactants /Detergents (MBAs)	Monthly ^{Note 1}	Standard Method
Fats, Oils & Greases	Monthly ^{Note 1}	Standard Method
ortho-Phosphate (as PO ₄)	Monthly ^{Note 1}	Standard Method
Fluoride	Monthly ^{Note 1}	Standard Method
Mineral Oils	Monthly ^{Note 1}	Standard Method
Chromium	Monthly ^{Note 1}	Atomic Absorption/ICP
Copper	Monthly ^{Note 1}	Atomic Absorption/ICP
Nickel	Monthly ^{Note 1}	Atomic Absorption/ICP
Silver	Monthly ^{Note 1}	Atomic Absorption/ICP
Tin	Monthly ^{Note 1}	Atomic Absorption/ICP
Cyanide	Monthly ^{Note 1}	Atomic Absorption/ICP
Cadmium	Monthly ^{Note 1}	Atomic Absorption/ICP
Metals & Organic Compounds	Once Off & As Required Note 2	Standard Method

Note 1: All samples shall be collected on a 24 hour flow proportional composite sampling basis.

Note 2: Relevant Priority substances, Priority Hazardous substances and Watchlist substances (as per relevant Tables set out S.I. No. 272/2009 - European Communities Environmental Objectives (Surface Waters) Regulations 2009 – 2019, as amended) in trade effluent generated as a result of onsite activities (The list of parameters to be analysed shall be based on the assessment/ screening as per consent Condition 14).

Control of Emissions to Sewer

Description of treatment: Ion Exchange

Control Parameter	Monitoring	Key Equipment
Cadmium	Cartridge Filters	Resin Filled Ion Exchange Units

Note 1: The licensee shall maintain appropriate access to standby and/or spares to ensure the operation of the abatement system.

Signed on behalf of

DocuSigned by:



EBDF6E0E3CDD42C...

24/2/2021

Date

For inspection purposes only.
Consent of copyright owner required for any other use.