

UISCE ÉIREANN RESPONSE

Uisce Éireann
Colvill House
24/26 Talbot Street
Dublin 1

Name of Facility: Arrow Group Limited

Reg. No: P0812-02

Location Address: Arrow Group Limited, The Maudlins, Naas, Co. Kildare

Consent granted subject to the consent conditions outlined below.	Yes
Consent granted without conditions.	N/A
Consent refused ^{Note 1} .	N/A

The sewer, to which this consent relates, is vested or controlled by Uisce Éireann.	Yes
Does the consent constitute a material change with respect to the associated waste water discharge authorisation? ^{Note 2} (If 'Yes', you must attach to the consent a document describing the measures to be taken to bring about compliance with the waste water discharge authorisation including timeframes where appropriate.	No

Indicate either "Yes" or "No" to the request to include the condition(s) below in the licence as follows:

GENERAL CONSENT CONDITIONS	Condition to be Included (Yes/No)
1. Other than the trade effluent authorised to be discharged under this licence, the licensee shall at no time discharge or cause or permit to discharge into sewer trade effluent or any other matter unless authorised in writing by Uisce Éireann.	Yes
2. Monitoring and analysis equipment shall be installed, operated and maintained as necessary, so that all monitoring, accurately reflects the emission/discharge.	Yes
3. The licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as set out below and as in accordance with <i>Schedule C: Control & Monitoring</i> , of this licence. (i) Sampling and analysis shall be undertaken by competent staff in accordance with documented operating procedures. (ii) Such procedures shall be subject to a programme of Analytical Quality Control using appropriate control standards with evaluation of test responses.	Yes

(iii) Where any analysis is sub-contracted it shall be outsourced to a competent laboratory.	
4. The licensee shall ensure that any trade effluent generated from canteen activities shall pass through appropriate grease removal equipment prior to discharge to sewer.	No
5. The licensee shall maintain and implement a detailed programme for maintenance of all plant and equipment based on the instructions issued by the manufacturer/supplier or installer of the equipment or as otherwise approved in writing by UÉ.	Yes
6. A summary report of volumes of trade effluent and other matter discharged to the sewer along with monitoring and analysis data as specified in <i>Schedule B: Emission Limits to Sewer</i> and <i>Schedule C: Control & Monitoring</i> , of this licence shall be forwarded to both Uisce Éireann and the Local Authority in a manner and timeframe as may be specified by Uisce Éireann.	Yes
7. The licensee shall prepare, maintain and implement (text highlighted in black bold for new licence only) / maintain and implement (text highlighted in green bold for reviews) a Schedule of Environmental Objectives and Targets. The Schedule shall, as a minimum, provide for a review of all operations and processes, including an evaluation of practicable options, for energy and resource efficiency, the use of cleaner technology, cleaner production and the prevention, reduction and minimisation of waste and shall include waste reduction targets, reduction and diversion of storm water runoff to sewer. The Schedule shall include time frames for the achievement of set targets and shall address a five-year period as a minimum. The schedule shall be reviewed annually and submitted to Uisce Éireann as requested.	No
8. The licensee shall pay to Uisce Éireann such sum as may be determined from time to time, having regard to the variations in the cost of providing drainage and the variation in effluent reception and treatment costs. Payment is to be made on demand from Uisce Éireann.	Yes
9. Silt Traps and Oil Separators The Licensee shall, within six months of date of grant of this licence, install and maintain silt traps and oil separators at the Facility: (i) Silt traps to ensure that all storm water discharges, other than from roofs, from the facility pass through a silt trap in advance of discharge; (ii) An oil separator on the storm water discharge from yard areas. The separator shall be a Class I Class II full retention/by-pass separator. <<EPA to select as appropriate>> (iii) The silt traps and separator shall be in accordance with I.S. EN-858-2: 2003 (separator systems for light liquids).	Yes
10. The licensee shall conclude an end user agreement with Uisce Éireann.	Yes
11. In the event of any incident which relates to discharges to sewer having taken place, the licensee shall notify Uisce Éireann and the Local Authority, in the manner prescribed by Uisce Éireann, as soon as practicable after such an incident.	Yes
12. No alteration to, or reconstruction in respect of, the activity, or any part thereof, that would, or is likely to, result in (i) a material change or increase in: <ul style="list-style-type: none"> the nature or quantity of any emission; the abatement/treatment or recovery systems; the range of processes to be carried out; the fuels, raw materials, intermediates, products or wastes generated, or (ii) any changes in: <ul style="list-style-type: none"> site management, infrastructure or control with adverse environmental significance; shall be carried out or commenced without prior notice to, and without the approval of, the Agency and/or Uisce Éireann as appropriate.	Yes
13. No specified emission from the installation shall exceed the emission limit values set out in Schedule B: Emission Limits, of this licence. There shall be no other emissions of environmental significance.	Yes

<p>ADDITIONAL GENERAL CONSENT CONDITIONS In respect of discharges or emissions to sewers, in accordance with Section 99E of the Environmental Protection Agency Act 1992, as amended. <i>(Specify, if required)</i></p>

Limit Values for Process Effluent to Sewer***Schedule B: Emission Limits***Emission Point Reference No.: **WEP2**Emission to **(sewer description)**: Discharge from onsite wastewater treatment plant to Monread Road

Volume of Trade effluent emitted:	Maximum in any one day:	1200 m ³
	Maximum in any hour:	50 m ³

Parameter	Emission Limit Values		
pH	6-9 pH Units		
Temperature	35°C		
	Concentration (24 Hr. Composite Sample (mg/l))	Max Daily Load (kg/day)	Average Daily Load (kg/day)*
BOD 5 days with inhibition (Carbonaceous BOD)	400	140	60
COD - Cr	760	266	125
Suspended Solids	600	210	90
Fats, Oils & Greases	30	12	6
Total Nitrogen (as N)	70	25	
Total Phosphorus (as P)	30	17	
Orthophosphate (as P)	20	10.5	

*Quarterly averaging period

Frequency of Monitoring Process Effluent to Sewer***Schedule C***

Emission Point Reference No.: SE1

Parameter	Monitoring Frequency (Note 1 & 2)	Analysis Method/Technique
Flow	Continuous	On-line flow meter with recorder
pH	Continuous	pH electrode/meter & recorder
Temperature	Continuous	On-line Temperature probe with recorder
BOD 5 days with inhibition (Carbonaceous BOD)	Weekly	Standard Method
COD - Cr	Weekly	Standard Method
Suspended Solids	Weekly	Standard Method
Fats, Oils & Grease	Weekly	Standard Method
Total Nitrogen (as N)	Weekly	Standard Method
Total Phosphorus (as P)	Weekly	Standard Method
Ortho-phosphate (as P)	Weekly	Standard Method
Respirometry	As Requested	Standard Method
Toxicity	As Requested	Standard Method

Note 1: All samples, excluding those for flow, pH and temperature, shall be collected on a 24 hour flow proportional composite sampling basis. Note 2: Sampling shall take place on alternate week days on a rolling basis to ensure representative samples are obtained for site operations which may vary across the working week.


Control of Emissions to Sewer

Description of treatment:

Control Parameter	Monitoring	Key Equipment
Solids Removal from Screen	Screen Rakes	Spare rakes/brushes
Effluent (pH) Neutralisation	pH output from neutralisation tank	Caustic Dosing Pump
Effluent Transfer		Lift Pumps
DAF Unit	Skimming blades	Spares held on site
	Air Nozzles	Spares held on site
	Chemical dosing equipment	Spares held on site
Effluent Balancing	Level Indicator	Pumps
		Feed-forward pump
Dissolved Oxygen	DO in aeration basin	Fixed DO Meter
Sludge Dewatering	Sludge dry solids content	Double Belt Press Filter

Note 1: The licensee shall maintain appropriate access to standby and/or spares to ensure the operation of the abatement system.

Signed on behalf of

DocuSigned by:

 23AF15FC6196408...

14/3/2023

Date _____