



Submission

Submitter:	Mr. Michael McPartland
Organisation Name:	Inland Fisheries Ireland
Submission Title:	Submission Received by Email
Submission Reference No.:	S011274
Submission Received:	11 August 2023

Application

Applicant:	Uisce Éireann
Reg. No.:	D0056-02

See below for Submission details.

Attachments are displayed on the following page(s).

Eve O'Sullivan

Subject: Waste Water Discharge Licence application by Uisce Éireann, Colvill House, 24-26 Talbot Street, Dublin 1, in respect of Midleton agglomeration, Reference No: D0056-02
Attachments: 23-24.doc

From: Michael McPartland <Michael.McPartland@fisheriesireland.ie>
Sent: Friday 11 August 2023 12:14
To: Licensing Staff <licensing@epa.ie>
Subject: Waste Water Discharge Licence application by Uisce Éireann, Colvill House, 24-26 Talbot Street, Dublin 1, in respect of Midleton agglomeration, Reference No: D0056-02

A chara

Please find attached submission

Michael Mc Partland
Senior Fisheries Environmental Officer.

Iascach Intíre Éireann
Inland Fisheries Ireland


Tel + 353 (0)26 412 21/2
Fax + 353 (0)26 412 23
Email michael.mcpartland@fisheriesireland.ie
Web www.fisheriesireland.ie

Sunnyside House, Macroom, Co. Cork, Ireland. P12 X602

Help Protect Ireland's Inland Fisheries

Michael McPartland
Senior Fisheries Environmental Officer

✉ Michael.McPartland@fisheriesireland.ie • ☎ +353 (0)26 41222 • 🌐 www.fisheriesireland.ie • 🏠 P12 X602



Help us protect Ireland's rivers, lakes and coastlines by reporting illegal fishing, water pollution or invasive species.
Our confidential phone number is 0818 34 74 24, which is open 24 hours a day / 7 days a week.

To read our Privacy Policy and Email Disclaimer Notice, Please visit www.fisheriesireland.ie



Iascach Intíre Éireann
Inland Fisheries Ireland

Environmental Protection Agency
Johnstown Castle Estate
Co. Wexford
Y35 W821

11 August 2023

RE: Waste Water Discharge Licence application by Uisce Éireann, Colvill House,
24-26 Talbot Street, Dublin 1, in respect of Midleton agglomeration,
Reference No: D0056-02

A chara,

Thank you for your notification of the above-mentioned application.

While IFI welcomes all proposals to improve wastewater treatment facilities, it also considers that all improvements should be compatible with preserving and improving existing receiving water quality and meeting existing legislative requirements with respect to water quality standards. In this case the relevant water quality standards are prescribed by the Environmental Objectives (Surface Waters) Regulations 2009 and the Shellfish Waters Directive (79/923/EEC)

With respect to proposed pumping stations IFI would ask stations are designed and operated in a manner so that there is no overflow discharge to waters. Upgrades should prioritize the separation of combined networks to negate the need for overflows at either treatment plants or treatment plants.

Yours sincerely,

Michael Mc Partland.
Environmental Officer.