



### Submission

Submitter:	Mr. John Daly
Organisation Name:	Fingal County Council
Submission Title:	Submission Received by Email
Submission Reference No.:	S011463
Submission Received:	20 December 2023

### Application

Applicant:	Uisce Éireann
Reg. No.:	D0034-02

See below for Submission details.

Attachments are displayed on the following page(s).

## Eve O'Sullivan

---

**From:** Licensing Staff  
**Subject:** D0034-02 Uisce Eireann - Greater Dublin Area

---

**From:** John Daly <[John.Daly@fingal.ie](mailto:John.Daly@fingal.ie)>  
**Sent:** Wednesday 20 December 2023 16:23  
**To:** Licensing Staff <[licensing@epa.ie](mailto:licensing@epa.ie)>  
**Subject:** RE: D0034-02 Uisce Eireann - Greater Dublin Area

Dear EPA

Many thanks for the response, I have reviewed the documents below again. With regard to overflows the only relevant piece of information regarding my query is the column "compliant \*(y/n)". I presume this is in reference to the DECLG guidance on storm overflows which is quite old now and precedes the current bathing water regulations. A yes no answer to this question does not identify the element of the guidance which the overflow is compliant with eg. Overflow frequency, screening. Nor does it give information on the quantity of the storm overflow when it occurs. Nor does it give the critical storm duration or return period duration which would be quite helpful to the local authority in assessing the requirement to issue prior warning notices under the bathing water regulations

Regards

John Daly  
Senior Engineer  
Environment Division  
Fingal County Council  
087 283 9186