The Sola Treatment Works is to be provided for the treatment of the industrial wastewater issued from the plant. The effluent contains a high level of toxicity and as a result of this the EPA has imposed certain parameters on the wastewaters produced at the plant as follows:

Max. daily effluent discharge: 200 m<sup>3</sup>

Max. effluent temperature: 25°C

Max. effluent B.O.D.<sub>5</sub> conc.: 200 mg/l

Max. daily B.O.D.<sub>5</sub> load: 10 kg

Max. daily C.O.D. conc.: 500 mg/l

Max. effluent S.S.: 30.0 mg/l

Max. daily S.S. load: 30.0 mg

pH: 6.0-10.0 ( Control Range 5-7)


Toxicity: 10 TU

The objective is to achieve at least 80-85% of the E.P.A effluent parameters, with the new plant.

The Scheme uses the following processes: Balancing, Screening, Pressure Sand filtration, pH correction, Balancing, GAC contact.

The chemicals to be used in the plant are: 30% Sulphuric Acid, 30% Caustic(NaOH).

Consent of copyright owner required for any other uses



### 3.4 Maintenance Checks and Procedures

### Daily

- 1. Check daily or more regularly, if found to be necessary, the priming chamber on each pump is operating satisfactorily
- 2. Check operation of raw water pumps. Review owner's manuals for inspection operating and regular maintenance requirements. These manuals should already exist on site.
- 3 Check that there is no overflowing of the equalisation tank

### Monthly

- 1. Check for deposits of sludge and particles in sump. If excessive, wait until there is a planned shut down for the entire plant and close inlet valves on gravity main to the sump. Drain down sump as much as possible. Arrange for the sump to be decontaminated and a Permit to Work issued before entering the sump
- Remove any deposits of sludge, plastic particles, etc. from floors and sidewalls before setting back into service. Replace all guards and covers before going back into service.

### Yearly

- 1. Pump out and physically clean pump.
- 2. Check over pump support beams and fixings.
- 3 Check and calibrate raw effluent quality monitoring equipment.
- 4 Check fixings on flooring assembly.
- 5 Confirm flow rate from each pump could be as high as 28 m<sup>3</sup>/hr

### 3.5 EQUIPMENT SUPPLIERS

Raw Water Pump

Manufacturer

Gilkes.

&Canal Iron Works,

Kendal, Cumbria,

England LA9 7BZ.

Telephone No 01539 732110

Fax No 01539 720028



### SOLA RECOMMENDED SPARES LIST

Source : USF Bowen Water Kilkenny

SOLA ADC Spares List							elling		
Function	Model	Supplier	Description	Part Ref	Qty		ice	Tot	
Filter Backwash Pump	LM80-200/187	Grundfos	Shaft Seal	48527		1 £		£	70.60
			Impeller	48505		1 £	79.92	£	79.92
Screen Washwater Pump	CR2-110	Grundfos	Internals	40510		1 £	261.09	£	261.09
·			Shaft Seal	98516		1 £	53.28	£	53.28
Balance Tank mixer	RW 3021	ABS	Mechanical Seal	1111009	5	1 £	114.56	£	114.56
			Seal Kit	6119504	1	1 £	162.51	£	162.51
Blower		Aerzen	Air Filter Element	GR47		2 £	37.46	£	74.93
			Shaft Seal Ring	15333	3 .	1 £	43.71	£	43.71
			Shaft Seal Sleeve	15332	3	1 £		£	37.46
			Set Of Vee Belts	N/A 🞺 .		1 £	37.46	£	37.46
Chemical Dosing Pumps	A965 - 362 s1	FMI	Overhaul Kit	PPM/262		2 £	51.95	£	103.90
Screen Feed Pump	S40	Process	Mechanical Seal	16 x 21mm		1 £	139.87	£	139.87
			Mechanical Seal Gasket Set Outlet Hose Silicone	of o		1 £	53.28	£	53.28
Refridgerated Sampler		CSL	Outlet Hose Silicone	16 x 21mm	3m	£	23.98	£	23.98
			Melliplane Mr Comblesson			1 £	83.92	£	83.92
			Gasket Kit Sample Chamber			1 £	25.31	£	25.31
Pressure Sand Filter Feed Pump	MA 0060-1	Kecol	Mechanical Seal	NOV-23-0060-1-CCE	•	1 £	370.31	£	370.31
			Transmissions Shaft	NOV-12-0060-CT		1 £	556.80	£	556.80
			Rotor - SS + Stator	NOV-11-0060-1-A		1 £	249.10	£	249.10
			Stator	NOV-31-0060-1-NBR		1 £	199.81	£	199.81
GAC Contactor Feed Pump	MC 0060-1	Kecol	Mechanical Seal	NOV-23-0060-1-CCE		1 £	370.31	£	370.31
	•		Transmissions Shaft	NOV-12-0060-CT		1 £	556.80	£	556.80
			Rotor - SS	NOV-11-0060-1-C		1 £	189.15	£	189.15
			Stator	NOV-31-0060-1-NBR	•	1 £	199.81	£	199.81
								£4	,057.89

### WASTE WATER TREATMENT PLANT (WWTP) PROCESS CHECKS

### WEEK NO.

		MONDA	Y	Т	UESDA	Y	W	EDNESDA	AY	T	HURSDA	AY		FRIDAY	Υ	W	EEKEN	D
DATE																		
Shift	N/S	D/S	E/S	N/S	D/S	E/S	N/S	D/S	E/S	N/S	D/S	E/S	N/S	D/S	E/S	N/S	D/S	E/S
Time		-															_	
PH (Inlet)						-					-							
PH ( Outlet)			ļ					<del> </del>			other use.							
Inlet sump level (m)						_				Soft of all								
Balance tank level (m)		_							n Purkey	ille U							_	
Inlet rate ( m3/h)		_						inspection.	Wife									
Outlet rate ( m3/h)							ζ.	ODAIR									_	
Control panel ok							ansento											
Balance tank mixer on							Cox										_	
Sand filter pressure <2 bar		-						_					_			_		
Sampler running																		
Carbon backwash																		
SIGNED																		
Acid + Caustic bulk tank check (weekly)		-										SIGNE	ED					

### CALIBRATION OF HAND HELD PH METER

SERIAL	PH BUFFER 7	PH BUFFER 4	SIGNED
NUMBER			
	E		
			,
		7115°.	
	, a · a	other	
	ses official		
	purpo diffee		
	section retite	1	
	isht o		
i i i i i i i i i i i i i i i i i i i	S'		
nsent O			
	NUMBER	NUMBER	

Section 21

Ref.3 (TS-022-023) Rev. 1.

### SOLA ADC LENSES LTD EMISSION TO SEWER SW1

### **Surface Water Discharge MHCC1**

Week No:	
Start Date:	
Finish Date:	
Licence No:	62

	MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY	TOTALS
Date:								
Emission to Sewer (SW1)					2.			
Temp. of Effluent SW1					x 1150			
Quantity discharged to drain from balance tank. (Litres)				A purpose only any of	3			
pH/@25°C				es 3 for				_
*Qty. from Sip pit to balance tank. (Litres)				2 Purpostifice				
pH @ 25°C			c <sup>®</sup>	Willet				
Surface Water Discharge (MHCC-1)			or insplit	5				
pH (Weekly)			· cold					
Temperature (Weekly)			ator					
Visual Inspection (Daily)			c Oison					
Conductivity (Weekly)								
Signature:								
COMMENTS								


\*Volume of SIP Pit = 6000L

MISC:

SIGNED:

MODIFICATIONS TO THIS DOCUMENT MAY OCCUR AFTER THIS DATE OF PRINTING 8-Feb-05 DO NOT PHOTOCOPY THIS SHEET CIRCULATION ON THIS PROCEDURE: MASTER, Pat Morris, SIP Area

Ref 1 (TS-025) rev 2, 29.04.04



### 5.0 RESULTS

Tables 5.1 to 5.5 present the results of the monitoring carried out at the Sola ADC Lenses Ltd., facility.

TABLE 5.1: SAMPLING PARAMETERS FOR TOTAL PARTICULATES						
Stack Reference Code	Parameter	Date Sampled	Time Sampled			
1	Total Particulates	09/06/2004	12:30-13:01			

TABLE 5.2: SAMPLING PARAMETERS FOR TA LUFT ORGANICS							
Stack Reference Code	Parameter Parameter	Date Sampled	Time Sampled				
Semi Finish Casting Filling	TA Luft Organics Class I, II and Uf	09/06/2004	12.03 – 15.02				
Semi Finish Casting OSI	TA Luft Organics Class I, If and III	09/06/2004	12.02 – 15.01				
46	TA Luft Organics Class I, II and III	09/06/2004	13.01 – 12.30				

TABLE 5.3: VOLUMETRIC FLOWS AND TEMPERATURES						
Stack Reference Code	Temperature (°C)	Vol Flow (Nm³/hr)	Limit Value (m³/hr)			
1	30	3052	-			
Semi Finish Casting Filling			-			
Semi Finish Casting OSI			-			
46			1			

TABLE 5.4:	RESULTS OF TO	TAL PARTICUL	ATE EMISSIONS
Stack Reference	Conc.	Massiflow	Mass Flow Limit
Code	(mg/Nm <sup>3</sup> )	old of kg/hr)	(kg/hr)
1	<0.31	9.5 x 10 <sup>-4</sup>	-
	Consent of copyright owner of		

### 6.0 COMMENT

Tables 5.1 to 5.5 present the results of the recent monitoring programme carried out at the Sola ADC Lenses Ltd. plant, including the relevant Licence limit values for volumetric flow and mass emission values.

Schedule 1(i) of Sola ADC Lenses Ltd., Integrated Pollution Control licence only stipulates limits for Stack References 46 and 1. However, for the purposes of comment, the VOC results from non-licenced emission points, the Semi Finish Casting Filling and OSI areas are also compared to the T.A. Luft 1986 guidelines.

### Integrated Pollution Control Licence Register No. 62, Emission Point Reference No. 1, Plant 2:

Emission point 1 was monitored for particulate matter. No dust was detected at a concentration greater than 0.31mg/Nm<sup>3</sup>.

### Integrated Pollution Control Licence Register No. 62, Emission Point Reference No. 46:

A significant amount of acetonitrile was detected in the emissions from emission point 46. As a result the total TA Luft Class III emissions significantly exceed the licence emission limit value.

### Non-licenced emission points, the Semi Finish Casting Filling and OSI stacks:

As previously mentioned, in the absence of Integrated Pollution Control Licence emission limit values for the above stacks, the results are compared to the T.A. Luft 1986 guidelines. As these guidelines have been updated comparisons have also been made with the latest 2002 TA Luft guideline limits.

For both emission points no Acrolein (TA Luft Class I) was detected at concentrations greater than the method limit of detection. Only low levels of Toluene (TA Luft Class II) and in the case of the Semi Finish Casting OSI area, acetone (TA Luft Class III) were detected in the emissions from these points.

In summary, aside from the quantity of TA Luft Class III emissions from emission point 46, the results demonstrate that the recommended TA Luft emission limit values (1986 and 2000 limits) are not being exceeded for all of the stacks monitored.

# SIZES 400-1000

### **MEDIUM DUTY**

The 400 to 1,000 range of envelope filters is designed to cater for the medium size dust problem, usually involving a ducted system. The unit size, i.e. 400 etc, designates the square footage of filtration cloth in that particular unit.

To cater for the wide range of air volumes and system pressures encountered in ducted systems we can offer a variety of fan options, or the units can be supplied without fans for multiple banking and separate fan applications. Our engineers are at hand to select the correct fan for your particular requirement.

### FILTER MEDIA

The filtration of air is achieved by using a nigh efficiency cloth in a multi pocket envelope form with standard units being supplied in cotton material. Other medias are available for greater efficiency or special applications.

### FABRIC CLEANING

For cleaning of the units, each filter is supplied complete with an electromechanical shaking device which raps the filter element thoroughly after the main fan switches off. This is dealt with automatically by a control panel supplied free issue with each unit wired 3 phase 50 cycles supply

### **FANS**

The fan impellors are of the backward curved plate type and are mounted direct onto the motor shaft on top of the unit. This allows easy access for wiring and servicing and in the event of fire keeps the motor out of the air-stream and gives greater protection. All motors are totally enclosed fan cooled and flange mounted.

### **DUST DISPOSAL**


Each unit is complete with a valley type hopper to channel the shaken dust into a square type bin having a quick felease system at the base. This is released after shaking down and taken away for emptying at intervals according to the dust loading.

### CONSTRUCTION

The casings of all units are robustly constructed from heavy gauge sheet in welded panel form with stiffening sections where required. The unit door is of the quick release type to allow easy access for filter changing.

#### FINISH

Black mild steel etch primed and finished with one coat of hammer finish.



SIZE 400 UNIT WITH EXPLOSION DOOR AND SILENCER.


### **OPTIONS**

**Silencers** are offered as an extra item if required for areas where noise must be kept to a minimum.

Flange Mounting units are offered for silo mounting where required.

Explosion Relief features including antispark fans, earthed filter elements, reinforced construction and blast relief doors are available for hazardous applications.

Manometer which provide visual indication of the pressure drop across the filter where it is essential to monitor filter efficiency.



## Placeholder

This page has been inserted to indicate that content has been extracted from this location in the document and has been stored in a separate file.

(This is due to file size issues.)

The extracted content can be found in the following electronic pdf file:

Application Form-Drawing-7

Licence: P0062-02