

Mr Seamus Kelly

"Amberlea"  
Courtnacuddy  
Co Wexford

Headquarters, PO Box 3000  
Johnstown Castle Estate  
County Wexford, Ireland

Ceanncheathrú, Bosca Poist 3000  
Eastát Chaisleán Bhaile Sheáin  
Contae Loch Garman, Éire

T: +353 53 60600  
F: +353 53 60699  
E: info@epa.ie  
W: www.epa.ie

LoCall: 1890 33 55 99

17/01/2005

202-1/Art14(2)(b)(ii)03BM

Re: Notice in accordance with Article 14(2)(b)(ii) of the Waste Management  
(Licensing) Regulations

Dear Mr Kelly,

I am to refer to the above referenced application for a waste licence relating to a facility at Seamus Kelly & Sons, Ramstown, Gorey, Co Wexford, and correspondence dated 08/11/2004 and 15/11/2004. The Agency notes certain items were omitted from the documentation.

You are therefore requested, in accordance with Article 14(2)(b)(ii) of the regulations, to take the steps and supply the information detailed below:

**C1 Air**

1. Please provide Figure No 2.2.1 showing the location of dust monitoring gauges D1, D2 and D4.

**C8 Noise**

1. In addition to the tonal noise element recorded at a frequency of 5kHz at N6, the noise graphs show that a further tonal noise element was recorded at 63Hz. Please provide an interpretation/explanation for these tonal noise elements given that noise from the business park was audible at monitoring locations N5 to N9 and the tonal elements recorded at N6 correspond to tonal noise elements recorded at on site locations N2 and N3.



Further tonal noise elements were recorded at the following NSLs all of which correspond to tonal noise elements recorded on site. Please provide an explanation/interpretation therefore.

NSL	Frequency
N10	63Hz
N13	250Hz 500Hz
N14	1.25kHz

#### **D1 Site Infrastructure**

1. Revised Figure No 2.6.1 shows the surface water drainage in blue going to drain at the site entrance however documentation provided relating to the planning application states that the surface water is to be disposed of to existing surface water drain in centre of the existing yard. This proposal is supported in the site lay out plan, which constitutes part of the planning application. Please clarify and revise Figure No 2.6.1 accordingly.
2. Reproduce Figure No 2.6.1 (*Site Drainage*) showing the precise location of the proposed wheel wash facility, vehicle wash bay and corresponding drainage within the site.

#### **J5 Discharge to Sewer**

1. In estimating the quantity of waste water effluent arising from the toilet, canteen, floor wash, shredder and vehicle wash bay it is stated '*it is planned that there will be 12 permanent staff on site*'. This conflicts with the waste Licence application non-technical summary, which states that '*the Company employs a total of 35 full time staff*'. Please clarify this discrepancy in employee numbers, and with an accurate final figure for staff numbers, estimate the quantity of wastewater effluent arising from the toilet, canteen, floor wash, shredder and vehicle wash bay.

Your reply to this notice should include a revised non-technical summary (Application Form and EIS) which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.


In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to

annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information in the form of a one original plus two copies within **three** (3) weeks of the date of this notice. In addition submit eleven CD-ROM copies of the requested information to the Agency. The e-file should be saved as a 'pdf' file, read only status.

Please note that the application's register number is **202-1**. Please direct all correspondence in relation to this matter to the *Licensing Unit, Office of Licensing & Guidance, Environmental Protection Agency, Headquarters, PO Box 3000, Johnstown Castle Estate, County Wexford* quoting the register number.

Yours sincerely,



**Bernie Murray**

Inspector

Office of Licensing & Guidance