

Attachment F.1 – Emissions and Abatement

The emissions from the site are generated by five process areas. These are addressed below:

Emissions to Atmosphere

- **Emissions from shredders (release points A2-1 and A2-3)**

Emissions to atmosphere from the shredders consist of air contaminated with airborne organisms and particulate that has been generated by the shredding process. A small quantity of volatile organic compounds may also be present. The air from the shredder is drawn through a HEPA filter to reduce the mass of particulate and organisms present in the gas stream. The HEPA removal efficiency is not less than 99.95% for a maximum particle size of 0.3µm. An interlock prevents the introduction of waste unless the negative pressure system is functional.

- **Emissions from STI Model 2000 (release points A2-2)**

Emissions to atmosphere from the STI process consist of water vapour and volatile organic compounds. A very small number of organisms may also be present. Both the existing and the proposed new STI Model 2000 treatment processes will be vented to atmosphere via the existing abatement system. The abatement system consists of a single pass condenser, a coalescing vessel and a carbon filter. The condenser acts to reduce the temperature of the gas stream leaving the STI process. As the gases cool, steam is condensed and removed as water. The coalescing vessel acts to remove more water out of the gas stream. The coalescing vessel consists of a large vessel that causes the gas flow to decelerate. As the gas stream is slowed, any droplets of water present fall out of the gas stream, as it no longer has the velocity necessary to keep them suspended. Next, the gas stream passes through a carbon filter that absorbs volatile organic compounds released by the heating of the healthcare waste in the STI process. The effect of the system is to reduce the presence of VOC's (and potential odours) to less than 50 mg/Nm³.

- **Emissions from Natural Gas Fired Packaged Steam Boiler (release point A2-4)**

Emissions to atmosphere from the boiler predominately consist of carbon dioxide, oxygen, and nitrogen with very low concentrations of oxides of nitrogen and carbon monoxide. The regular servicing of the package boiler and its integral boiler will control the concentrations of oxides of nitrogen and carbon monoxide. No abatement is proposed.

- **Emissions from Bin Washer (release points A2-5)**

Emissions to atmosphere from the bin wash predominately consist of steam contaminated with very low concentrations of bacteria, fungi, and VOC's. The concentrations of these are monitored on a regular basis as required by Waste Licence 55-1 and meet the requirements of the licence without the need for abatement equipment. Therefore, STI do not propose abatement equipment to control emissions to atmosphere from the bin wash.

- **Emissions from Rotary Drier (release points A2-6)**

Emissions to atmosphere from the rotary dryer are passed firstly through a cyclone to remove large particulate matter and dust. The gas stream then passes through a reverse jet filter that reduces the concentration of dust in the gas stream to very low levels before it is expelled through the roof of the building by an induced draft fan.

Emissions to Sewer

- **Emissions from Unit 430 (release points SE-1)**

Emissions to sewer from Unit 430 consist of condensate from the condenser and coalescing system attached to the STI Model 2000 treatment process and a purge stream from the bin wash system. The discharge is therefore predominately water mixed with small amounts of particulate, organic matter, and detergent. The bin washer is fitted with a solids sieve to reduce the concentrations of solids prior to discharge.

- **Emissions from Unit 420 (release points SE-2)**

Emissions to sewer from Unit 420 consist of a purge stream from the water treatment tank. The discharge is therefore predominately water mixed with small amounts of particulate and organic matter. The discharge passes through a solids sieve to reduce the concentration of solids prior to discharge.

Table F.1: Abatement / Treatment Control

Emission point reference number: A2-1 (shredder – existing treatment plant)

Control parameter	Equipment	Equipment maintenance	Equipment calibration	Equipment backup
Pressure drop across HEPA filter	a) HEPA filter media	Replace every six months	N/a	Replacement media kept
	b) Magnahelix differential pressure gauge	None	Calibrated every 6 months	Spare kept
Bacterial loading of filter	a) HEPA filter media	Replace every six months	N/a	Replacement media kept
	b) Accredited laboratory	N/a	Accredited laboratory	N/a

For inspection purposes only. Consent of copyright owner required for any other use.

Control parameter	Monitoring to be carried out	Monitoring equipment	Monitoring equipment calibration
Pressure drop across HEPA filter	Differential Pressure	Magnahelix differential pressure gauge	Calibrated every six months
Bacterial loading of filter	Monthly swab test of filter	Accredited laboratory	Accredited laboratory

Table F.1: Abatement / Treatment Control

Emission point reference number: A2-2 (STI Model 2000 – both treatment plants)

Control parameter	Equipment	Equipment maintenance	Equipment calibration	Equipment backup
Pressure drop across carbon filter	a) carbon filter media	Replace every six months	N/a	Replacement media kept
	b) Magnahelix differential pressure gauge	None	Calibrated every 6 months	Spare kept
VOC	a) carbon filter media	Replace every six months	N/a	Replacement media kept
	b) Accredited laboratory	N/a	Accredited laboratory	N/a

For inspection purposes only. Consent of copyright owner required for any other use.

Control parameter	Monitoring to be carried out	Monitoring equipment	Monitoring equipment calibration
Pressure drop across HEPA filter	Differential Pressure	Magnahelix differential pressure gauge	Calibrated every six months
VOC	Six monthly extractive test	Accredited laboratory	Accredited laboratory

Table F.1: Abatement / Treatment Control

Emission point reference number: A2-3 (shredder – proposed treatment plant)

Control parameter	Equipment	Equipment maintenance	Equipment calibration	Equipment backup
Pressure drop across HEPA filter	a) HEPA filter media	Replace every six months	N/a	Replacement media kept
	b) Magnahelix differential pressure gauge	None	Calibrated every 6 months	Spare kept
Bacterial loading of filter	a) HEPA filter media	Replace every six months	N/a	Replacement media kept
	b) Accredited laboratory	N/a	Accredited laboratory	N/a

Control parameter	Monitoring to be carried out	Monitoring equipment	Monitoring equipment calibration
Pressure drop across HEPA filter	Differential Pressure	Magnahelix differential pressure gauge	Calibrated every six months
Bacterial loading of filter	Monthly swab test of filter	Accredited laboratory	Accredited laboratory

Table F.1: Abatement / Treatment Control

Emission point reference number: A2-4 (Natural Gas Fired Packaged Steam Boiler)

Control parameter	Equipment	Equipment maintenance	Equipment calibration	Equipment backup
None	Burner	Annual Burner/Boiler Service	None	None

Control parameter	Monitoring to be carried out	Monitoring equipment	Monitoring equipment calibration
None	None	None	None

Table F.1: Abatement / Treatment Control

Emission point reference number: A2-5 (bin washer)

Control parameter	Equipment	Equipment maintenance	Equipment calibration	Equipment backup
None	Exhaust fan	Annual maintenance	None	None

Control parameter	Monitoring to be carried out	Monitoring equipment	Monitoring equipment calibration
None	None	None	None

Table F.1: Abatement / Treatment Control

Emission point reference number: A2-6 (Rotary dryer)

Control parameter	Equipment	Equipment maintenance	Equipment calibration	Equipment backup
Pressure drop across reverse jet filter	a) filter media	Replace every six months	N/a	Replacement media kept
	b) Magnahelix differential pressure gauge	None	Calibrated every 6 months	Spare kept

Control parameter	Monitoring to be carried out	Monitoring equipment	Monitoring equipment calibration
Pressure drop across HEPA filter	Differential Pressure	Magnahelix differential pressure gauge	Calibrated every six months

Table F.2 to F.8: Emissions Monitoring and Sampling Points

Emissions Point Reference No(s): A2-1, A2-2, A2-3, A2-5, A2-6

Parameters	Monitoring Frequency	Accessibility of Sampling Points
VOC	Twice Yearly	Ground level or via permanent platform
Biological organisms (as TVC (total viable count))	Twice Yearly	Ground level or via permanent platform

For inspection purposes only.
Consent of copyright owner required for any other use.

Table F.2 to F.8: Emissions Monitoring and Sampling Points**Emissions Point Reference No(s): SE-1, SE-2**

Parameters	Monitoring Frequency	Accessibility of Sampling Points
Flow	Monthly	Ground level
Temperature	Continuous	Ground level
pH	Continuous	Ground level
BOD	Monthly	Ground level
COD	Monthly	Ground level
Suspended Solids	Monthly	Ground level
Detergents (as MBAS)	Monthly	Ground level

*For inspection purposes only.
Consent of copyright owner required for any other use.*