



- NOTES**
1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS.
 2. ALL EXISTING SERVICES TO BE TRACED AND IDENTIFIED PRIOR TO COMMENCEMENT OF ANY EXCAVATIONS.
 3. NEW UNDERGROUND WATERMAIN TO BE CEMENT LINED DUCTILE IRON CLASS KR.
 4. FIRE HYDRANT COVERS TO BE KAVANAGH CHEETAH.
 5. ALL TRENCHES TO BE BACKFILLED IN CL.804.
 6. DO NOT SCALE - USE FIGURED DIMENSIONS ONLY.
 7. ALL DIMENSIONS ARE GIVEN IN MILLIMETRES.
 8. ALL DIMENSIONS TO BE CHECKED ON SITE.

- LEGEND**
- 2000 WATERMAIN
 - - - SITE FEED WATERMAIN
 - (H) FIRE HYDRANT
 - (M) PROPOSED WATER METER
 - (X) SLUICE VALVE
 - (TB) THRUST BLOCK

A	ISSUED FOR PLANNING	BCR	LB	12/11/04
ISSUE	DESCRIPTION	DRN	DRD	ALPH
			APP	DATE
		4 HARRINGTON TICE DUN LAOGHAIRE CO. DUBLIN TEL: +353 1 2148350 FAX: +353 1 2807655		
PROJECT WASTE MANAGEMENT FACILITY-RINGASKIDDY				
TITLE MAIN PROCESS BUILDING WATERMAIN LAYOUT PLAN				
CLIENT REF.	COS/APP/92/	CLIENT DRD No.		
PROJECT No.		CONTR DRD No.	104	
A1	SCALE 1:500			

FIREMAIN WILL INCORPORATE A VERTICAL RISER AT THIS LOCATION IN ORDER TO OVERCOME THE DIFFERENCE IN HEIGHT.
FIREMAIN WILL BE RESTRAINED TO THE WALL IN ORDER TO PREVENT MOVEMENT.

FIREMAIN WILL INCORPORATE A VERTICAL RISER AT THIS LOCATION IN ORDER TO OVERCOME THE DIFFERENCE IN HEIGHT.
FIREMAIN WILL BE RESTRAINED TO THE WALL IN ORDER TO PREVENT MOVEMENT.