


Comhairle Contae Chorcaí Cork County Council

Environmental Department,
Inniscarra, Co. Cork.
Tel: (021) 4532700 • Fax (021) 4532727
Web: www.corkcoco.ie
An Rannóg Comhshaoil,
Inis Cara, Co. Chorcaí.
Fón: (021) 4532700 • Faics (021) 4532727
Suíomh Gréasáin: www.corkcoco.ie



Ciara Maxwell
Licencing Unit
Office of Licencing & Guidance
Environmental Protection agency
Johnstown Castle Estate
County Wexford
Ireland

ENVIRONMENTAL PROTECTION AGENCY

31 AUG 2006

RICHVIEW
OFFICE OF LICENSING & GUIDANCE

Subject: IPPC Reg No. 211-1 (AVR-Environmental Solutions Ltd Foxhole, Youghal, Co. Cork)

29th August 2006

Dear Ms Maxwell,


I wish to acknowledge receipt of correspondence regarding the sanitary Authority response to Section 52 (Waste Management Act) regarding a consent to discharge to sewer.

The Section 52 response request was completed and sent to the agency. The applicant SWS on behalf of AVR-Environmental Solutions Ltd Foxhole, Youghal have subsequently requested that the Section 52 response be revised to reflect the Urban Wastewater Regulation limits for B.O.D.

Cork County Council as the sanitary authority will consent to the discharge of B.O.D. at 20mg/l of BOD in the discharge to sewer

Should you have any queries or clarification my contact details are supplied below
Phone no. 021-4532700
E mail valerie.hannon@corkcoco.ie

Yours Sincerely


Valerie Hannon,
Executive Scientist
Wastewater Laboratory

