

SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CONTAE ÁTHA CLIATH THEAS

office

Halla an Chontae, Tamhlacht,  
Baile Átha Cliath 24.  
Telefon: 01-4149211  
01-4149101



Environmental Services Department,  
County Hall, Tallaght,  
Dublin 24.  
Telephone: 01-4149211  
01-4149101

Ms. Eva Babiarczyk,  
Programme Officer,  
Licensing Unit,  
Environmental Protection Agency,  
P.O. Box 3000,  
Johnstown Castle Estate,  
Co. Wexford.

**Our Ref:** EPA 050  
**Reg. No.** W0227-01

**Date:** 12<sup>th</sup> April 2007


**Re/ Waste Reg. No. W0227-01 - Access Skip Hire**


Dear Ms. Babiarczyk,

I refer to the above application for a Waste Licence, requesting consent under Section 52 of the Waste Management Act 1996, of the Environmental Protection Agency Act 1992 for discharge of trade effluent.

Please find attached the consent conditions of South Dublin County Council.

Yours sincerely,

  
Patricia O'Reilly,  
Staff Officer,  
Water & Drainage.



**Do business with South Dublin County Council**

**Online:-** [www.southdublin.ie](http://www.southdublin.ie) — **email:-** [ccccounter@sdblincoco.ie](mailto:ccccounter@sdblincoco.ie)

or **send SMS:-** simply text "counter" and your message to 086 1731707

**24 / 7 online customer query facility**

**SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CONTAE ÁTHA CLIATH THEAS**

Halla an Chontae  
Lár an Bhaile, Tamhlacht  
Baile Átha Cliath 24.  
Telefon: 01-4149211  
Facs: 01-4149101  
www.southdublin.ie



Environmental Services Department  
County Hall, Town Centre  
Tallaght, Dublin 24  
Telephone 01-4149211  
Fax: 01-4149101  
e-mail: poreilly@sdblincoco.ie

**SANITARY AUTHORITY CONSENT CONDITIONS**

**Name of Sanitary Authority:** South Dublin County Council.

**Address:** County Hall, Town Centre, Tallaght, Dublin 24.

**Waste Facility:** Access Skip Hire, Unit 28, John F. Kennedy Road, JFK Industrial Estate, Naas Road, Dublin 12.

**Waste Reg. No.** WO227-01

**Waste Licence Application:** Lawlor Brothers Waste Disposal Ltd.  
t/a Access Skip Hire.

Consent granted subject to consent conditions outlined below.	Yes
Consent granted without conditions.	
Consent refused.	

In respect of discharges or emissions to sewer the Sanitary Authority requires the conditions indicated by a "Yes" in the right-hand column below, to be included in any waste licence, which are the Agency may proposed to grant, in respect of the above referenced waste licence application, in accordance with Section 52 of the Waste Management Act 1996.

<b>GENERAL CONSENT CONDITIONS</b>	<b>Condition to be included (Yes/No)</b>
1. No specified emission to sewer shall exceed the emission limit value or load set out in Schedule B : <i>Emission Limits to Sewer</i> . There shall be no other emission to sewer of environmental significance.	<b>Yes</b>
2. The Licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as set out in <i>Schedule C</i> .	<b>Yes</b>
3. Monitoring and analyses equipment shall be operated and maintained as necessary so that monitoring accurately reflects the emission or discharge.	<b>Yes</b>
4. The licensee shall permit authorised persons of the Agency and the Sanitary Authority to inspect, examine and test, at all reasonable times, any works a apparatus installed in connection with the trade effluent and to take samples of the process effluent.	<b>Yes</b>

5. All automatic monitors and samplers shall be functioning at all times (except during maintenance and calibration) when the activities are being carried out unless alternative sampling or monitoring has been agreed in writing by the Agency for a limited period. In the event of the malfunction of any continuous monitor, the licensee shall contact the Agency as soon as practicable and alternate sampling and monitoring facilities shall be put in place. Prior written agreement for the use of alternative equipment, other than in emergency situations, shall be obtained from the Agency.	Yes
6. The licensee shall record all sampling, analyses, measurements, examinations, calibrations and maintenance carried out in accordance with the requirements of this licence.	Yes
7. The licensee shall provide safe and permanent access to all on-site sampling and monitoring points and off-site points as required by the Agency.	Yes
8. The licensee shall at no time discharge or permit to be discharged into the sewer any liquid matter or thing which is or may be liable to set or congeal at average sewer temperature or is capable of giving off any inflammable or explosive gas or any acid, alkali or other substance in sufficient concentration to cause corrosion to sewer pipes, penstock and sewer fittings or the general integrity of the sewer.	Yes
9. In the event of any incident which relates to discharges to sewer having taken place, the Licensee shall notify the Agency, Local Authority and Sanitary Authority as soon as practicable after the incident.	Yes
<p><b>ADDITIONAL GENERAL CONSENT CONDITIONS</b>  <u>in respect of discharges or emissions to sewers, in accordance with Section 52 of the Waste Management Act, 1996</u>  <i>(specify, if required)</i></p>	
10. A report of the results of analysis of effluent discharged to the sewer with relevant volumes discharged shall be forwarded to the sanitary authority on a quarterly basis to enable the calculation of charges under the Mogden Formula. Yes	
11. No emission to sewer shall take place which gives rise to any reaction within the sewer or to the liberation of by-products which may be of environmental significance.	
12. A report of the results of analysis of effluent discharged to the sewer with relevant volumes discharged shall be forwarded to the sanitary authority on a quarterly basis to enable the calculation of charges under the Mogden Formula.	
13. Non-trade effluent wastewater (e.g. firewater, accidental spillages) which occurs on site shall not be discharged to the sewer without the prior authorisation of South Dublin County Council.	



<b>ADDITIONAL PARAMETERS</b> <i>(if required)</i>			
Detergents	100	1.0	Yes
Fats, Oils, Grease	100	1.0	Yes
Phosphates ( as PO <sub>4</sub> -P )	100	1.0	Yes
Mineral Oils (mg/l)	10	0.10	Yes

**SCHEDULE C**  
**of Sanitary Authority Consent per s52 of the Waste Management Act, 1996**

**Emissions to Sewer - Frequency of Monitoring**

Waste Licence Register No.

W022701

Emission Point Reference No:

Not Supplied

<b>Parameter</b> <i>(delete parameters which are not applicable)</i>	<b>Monitoring Frequency</b>	<b>Sampling Method/Type</b> <i>(grab, continuous)</i>
Flow to sewer		
BOD	Quarterly	24-hr composite
COD	Quarterly	24-hr composite
Suspended Solids	Quarterly	24-hr composite
Temperature	Quarterly	Grab
pH	Quarterly	Grab
<b>ADDITIONAL PARAMETERS</b> <i>(if required)</i>		
Mineral oil	Quarterly	Grab
Phosphates	Quarterly	24-hr composite
Detergents (as MBAS)	Quarterly	24-hr composite
Fats, Oils, Grease	Quarterly	24-hr composite

<b>SANITARY AUTHORITY CHARGES</b>	
Charge per cubic metre of trade effluent or other matter (per s52 of the Waste Management Act, 1996)	As per Mogden formula used by South Dublin County Council
Payment Frequency	Quarterly
Annual Monitoring Costs	€3800

**NOTE:** Charges are subject to price variation in the future as may be ordered by the Council.

I concur with the recommendation of the Senior Engineer.

Signed on behalf of Sanitary Authority:

*Helia O'Neil*

For inspection purposes only.  
Consent of copyright owner required for any other use.