

Mr. Gearoid McCarthy  
Monaghan County Council  
Water services  
County Offices  
The Glen  
Monaghan

Regional Inspectorate  
McCumiskey House, Richview,  
Clonskeagh Road, Dublin 14, Ireland  
Cigireacht Réigiúnach, Teach Mhic Chumascaigh  
Dea-Radharc, Bóthar Cluain Sceach  
Baile Atha Cliath 14, Éire  
T: +353 1 268 0100  
F: +353 1 268 0199  
E: info@epa.ie  
W: www.epa.ie  
LoCall: 1890 33 55 99

30 June 2008

D0061-01

re: Notice in accordance with Regulation 18(3)(b) of the Waste Water Discharge (Authorisation) Regulations 2007

Dear Mr. McCarthy

I am to refer to the above referenced application for a waste water discharge licence relating to the agglomeration covering Monaghan Town and its environs. Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below:

## **REGULATION 16 COMPLIANCE REQUIREMENTS**

### ***Section A: Non-Technical Summary***

- Update the non-technical summary, as necessary, to reflect the information provided in response to this notice.

### ***Section B – General Information***

- Please provide the name of the agglomeration to which the Waste Water Discharge Licence Application relates.

### ***Section B.5 – Location of Storm Water Overflow Points***

- The grid reference required for each SWO (labelled as SW3-SW7) under Section B.5 is the grid location of the actual discharge point of the SWO rather

than the location of the SWO itself. Please clarify the basis for the grid references given in Section B.5. and provide the grid reference of the discharge point if different

### ***Section B.6 Planning Authority***

- Provide details of the planning permission granted for the WWTP.

### ***Section B.10 – Capital Investment Programme***

- Section B.10 of the application details a programme of works for Monaghan Town Sewerage Scheme, please provide an update of the proposed development. Clarify if the proposed sewerage scheme will result in all, or some, of the SWO becoming redundant, please identify which SWO will be redundant or upgraded.

### ***Section C.2 - Outfall Design and Construction***

- For emission point labelled as SW-3 provide details of the following:
  - (i) the emergency power generation capacity and standby pumping capacity at the pumping station (in the event of power failure or pump malfunction);
  - (ii) the measures to be undertaken in the event of a power failure or pump malfunction;
  - (iii) the storage capacity, and storage time in hours, at the pumping station (and the basis for the calculations, e.g. rainfall intensity/duration), and
  - (iv) clarify whether the emergency overflow from the pumping station has been known to activate in the last 12 months. If so provide the reason for the activation, and give details of the frequency, duration and discharge volumes, where available.
- Assess the design criteria of storm water overflows SW-4 to SW-7 inclusively. Demonstrate (providing available evidence) whether all storm water overflows meet the design criteria established in 'Procedures and Criteria for Storm Water Overflows', published by the Dept. of the Environment, 1995. Clarify whether there are screens on all of the overflows and identify any SWOs that may be impacting on surface water quality. Where a storm water overflow does not comply with these guidelines, give details of the plans, for improvement.

### ***Section D – Discharges to the Aquatic Environment***

- Complete Table D.1(i)(a) and table D.1(i)(b) for the existing primary discharge (current emission) to include details of the dry weather flow in the receiving water and the River Blackwater.
- Provide information on any landfill leachate introduced to the treatment works. Indicate the approximate quantities of leachate accepted and the source(s) of the leachate. Outline any operating procedures for acceptance of leachate.
- Provide details of any other tankered wastes delivered to the treatments works.

### ***Section E - Monitoring***

- Identify on a suitable scaled map the location of the upstream and down stream surface water monitoring points.

### ***Section F – Existing Environment and Impact of the Discharges***

- Give summary details and an assessment (based on appropriate water quality standards) of the impacts of the existing emissions on the environment/surface water.
- Carry out assimilative capacity calculations for the existing primary discharge. 95%ile flow shall be used to calculate the capacity of the receiving waterbody for BOD, Suspended Solids, Total nitrogen, COD, and total phosphorus. In addition a calculation shall be presented for the capacity of the surface water body based on the 50<sup>th</sup> percentile flow for ortho-phosphate which is considered to represent the standard for molybdate reactive phosphate
- Describe the existing environment in terms of water quality with particular reference to environmental quality standards or other legislative standards. Provide a copy of the most recent water quality management plan or catchment management plan in place for the receiving water body.
- Provide a statement as to whether or not emissions or main polluting substances (as defined in the Dangerous Substances Regulations S.I. No. 12 of 2001) to water are likely to impair the environment.
- Indicate whether or not emissions from the agglomeration or any plant, methods, processes, operating procedures or other factors which affect such emissions are likely to have a significant effect on a designated site (as identified on page 19 of 25 of the licence application form). Provide details of any correspondence engaged in with the National Parks and Wildlife Service in

relation to a determination as to the likelihood of discharges from the waste water works having a significant effect on a European site.

***Section G – Programmes of Improvements***

- For all SWOs, other than the surface water overflow at the WWTP, designated in the licence application provide a detailed timescale for compliance of each SWO with the minimum specified design criteria (i.e. less than 6 spills per year) or for removal of the SWO from the system.

Your reply to this notice should include a revised non-technical summary which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

## REGULATION 12 REQUIREMENT

I am to advise you of a failure of compliance with Regulations 9, of the Waste Water Discharge (Authorisation) Regulations 2007. In particular a period of more than two weeks has elapsed between the publication of the notice and the making of this application (date of receipt of licence application fee, 14/01/08).


The Agency therefore requires you, in accordance with Regulation 12 of the regulations, to

- Publish a further newspaper notice in accordance with Regulation 10 of the Waste Water Discharge (Authorisation) Regulations 2007; and
- Submit an original page of the newspaper in which the revised newspaper notice is placed.

Please supply all the information requested above in the form of a one original plus one copy within **5** weeks of the date of this notice. In addition please submit one copy of the requested information in electronic searchable PDF format on a CD-ROM to the Agency. Please note that all maps/drawings should not exceed A3 in size.

Please note that the application's register number is D0061-01. Please direct all correspondence in relation to this matter to *Administration, Environmental Licensing Programme, Office of Climate, Licensing & Resource Use, Environmental Protection Agency, Headquarters, PO Box 3000, Johnstown Castle Estate, County Wexford* quoting the register number.

Yours sincerely,



**Patrick Byrne**

**Inspector**

**Office of Climate, Licensing & Resource Use**