

Thermocouples

The boiler temperature will be measured by three or more thermocouples. The probes normally used comprise Nickel-Chromium-Nickel or Platinum-10%Rhodium-Platinum which can be used up to a temperature of approximately 1,350°C. The probes have a lifetime of approximately 5-8 months.

Sludge Moisture Content

The following two types of sludge are produced at the Ringsend WWTP:

- dried sludge at 92% dry solids and 8% moisture (heat dried)
- cake sludge at 25% dry solids and 75% moisture (belt press)

OH Sub No. 20

Recd From: Dublin City Council

Environmental Protection Agency
16 APR 2008
ORAL HEARING
RECEIVED

For inspection purposes only.
Content of copyright notice required for any other use.