

**Article 12 (Part 1)****Section C: Management: Provide further details, including the number of staff on site, the hours the facility is to be manned, i.e. other than security, and details of any contingency arrangements**

The operations management of the Waterford Waste water Treatment works at Gorteens will be structured to provide all the necessary technical, analytical, supervisory and administrative management necessary to enable the proper operation and maintenance of the works, safely and efficiently on a continuous basis throughout the contracts Operation and Maintenance Period.

The Plant will be manned Monday to Friday from 8am to 5:00pm during the week, by the following qualified personal:

- 1 Operations and Maintenance Manager, and reporting to him:
  - . 1 x Electrical Technician
  - . 1 x Mechanical Technician
  - . 2 x Plant Operatives

Outside of the normal day time operations of the works there will be a callout Rota system in place consisting of the Electrical Technician, Mechanical Technician and two Operatives. The on-call Rota period for each member of staff will be for one week (Friday to Friday) in four. The call-out rota for the facility is shown below.

The Waste water Treatment works will be fully automated and controlled by a SCADA system which monitors & logs all plant equipment and process flows & levels. All critical plant will have standby systems in the event of plant failure. The SCADA system will also be equipped to send priority alarm messages to the on-call personnel, via the mobile phone text messaging service, alerting them to a potential problem at the works. The on-call member of staff will be equipped with a Laptop capable of logging into the plant SCADA system remotely for interrogation purposes.

In order to provide adequate duty cover during the whole of the Operations and Maintenance Period, a personnel rosta will be arranged so that no more than one member of staff shall be absent from the Works at any one time on holidays, training or otherwise. Where Operation and Maintenance personal leave the employment during the Operation and Maintenance period, they will be replaced with staff of equivalent experience and qualifications.

Waterford WwTW Call out Rota

Week = Friday to Friday

CAW Staff	Week 1	Week 2	Week 3	Week 4	Week 5	Week 6	Week 7	Week 8	Week 9
Operator 1	Yellow				Yellow				Yellow
Operator 2		Red				Red			
Electrical			Blue				Blue		
Mechanical				Green				Green	

CAW Staff	Week 10	Week 11	Week 12	Week 13	Week 14	Week 15	Week 16	Week 17	Week 18
Operator 1				Yellow				Yellow	
Operator 2	Red				Red				Red
Electrical		Blue				Blue			
Mechanical			Green				Green		

CAW Staff	Week 19	Week 20	Week 21	Week 22	Week 23	Week 24	Week 25	Week 26	Week 27
Operator 1			Yellow				Yellow		
Operator 2				Red				Red	
Electrical	Blue				Blue				Blue
Mechanical		Green				Green			

CAW Staff	Week 28	Week 29	Week 30	Week 31	Week 32	Week 33	Week 34	Week 35	Week 36
Operator 1		Yellow				Yellow			
Operator 2			Red				Red		
Electrical				Blue				Blue	
Mechanical	Green				Green				Green

CAW Staff	Week 37	Week 38	Week 39	Week 40	Week 41	Week 42	Week 43	Week 44	Week 45
Operator 1	Yellow				Yellow				Yellow
Operator 2		Red				Red			
Electrical			Blue				Blue		

Waterford WwTW Call out Rota

Week = Friday to Friday



CAW Staff	Week 46	Week 47	Week 48	Week 49	Week 50	Week 51	Week 52
Operator 1							
Operator 2							
Electrical							
Mechanical							

For inspection purposes only.  
Consent of copyright owner required for any other use.

**Article 12 (Part 2)**  
**Section D.1: Infrastructure**

**Provide further details on site infrastructure including appropriately scaled labelled drawings for:**

**(a) Overall site layout showing all process areas**

The overall site area showing all process areas is shown in Drawing No. C1197-3014.

It should be noted that the sequence is not always in numerical order, e.g. there is no Item 4 on the drawing. However, all items of the WWTP are included.

**(b) Primary and secondary treatment: plant and infrastructure**

The inlet works, where the main primary treatment is carried out is shown in Drawing C1197-2000. The storm tanks, to which excess flow passes during storm conditions, is shown in Drawing No. C1197-1013. The overall flow diagram detailing the preliminary treatment is shown in Drawing C1197-1012.

The secondary works, excluding the sludge treatment area, which is shown in 2(d) are shown in Drawing No. C1197-1017 and C1197-2005, (Final Settlement Tanks), Drawing C1197-1027 (Wash water, i.e. settled effluent that passes to the Final Effluent sampling and wash water pumping station), Drawing C1197-1016 (Aeration Tanks) and Drawing C1197-2006 (Selector and Aeration Tanks).

**(c) Works Inlet building internal layout details**

The works inlet building internal layout details are provided as Drawing No. C1197-2000, which shows the plan view of the sludge building and Drawing No. C1197-2001 shows the section detail of the building. Here the incoming flow is screened by the automatic screens prior to passing to grit traps. From the inlet works, the sewage passes on to a distribution chamber to the primary settlement tanks. The preliminary treatment for grease and grit details are shown in Attachment C1197-8402.

**(d) Sludge building internal layout details**

The sludge thickening and dewatering building internal layout details are shown in Drawing No. C1197-2011. Activated sludge is thickened here by the gravity belt thickeners. It is transferred to the sludge treatment building (See section (e)). Note - Also detailed on this drawing is the boiler room, where the two boilers are located. These plant items can also be seen in Drawing No. C1197-3006, where the buildings location in relation to the overall treatment area can be seen. The boiler specification is shown in Attachment C1197-8417.

**(e) Sludge Treatment Area**

Drawing No. C1197-3006 shows the layout details of the overall sludge treatment area, which includes the sludge thickening and dewatering area, and the sludge treatment area, where the following processes take place: Primary sludge is thickened by means of the picket fence thickener and added to the thickened

secondary sludge by means of a blending tank. The blended sludge is pasteurised and then fed to the anaerobic digesters.

From the digesters, the digested sludge flows to a digested sludge tank, and from there to one of the two dewatering sludge belt presses, to produce the final sludge cake.

**(f) Wastewater drainage infrastructure**

The pipework showing all the drainage from the plant, including the wastewater infrastructure, is shown in Drawing C1197-3002. The drainage for the sludge area is shown in Drawing No. J300-SK-009-250808.

**(g) Surface water site drainage including location of SW-01, sampling location, interceptors, trunk pipe**

The surface water drainage is shown in Drawing No. J300-SK-007-220808 and also in Drawing No. C1197-3002. The surface water sampling chamber is shown in the overall drawing for the site, i.e. Drawing No. C1197-3014, as mentioned in Section 2(a). The surface water sampling location is Item 29 on the drawing.

**(h) Odour Control Units, process and areas served, pipework and open tanks**

There are two odour control units (OCUs), one to serve the inlet works (OCU-1) and one to serve the sludge building (OCU-2). The P&ID diagram for the odour units is included as Drawing No. C1197-1026. This shows the 2 no. odour units, and which items or areas of the plant that may produce odours that are directed to the odour units. These include:

**OCU 1 (Odour Control Unit 1) – Inlet Works**

- Inlet Works
- Grit Classifier
- Screenings Wash
- Inlet Works Building
- Screen/Grit Skips
- Primary Settlement Tank

The odours from the primary settlement tanks are directed through an odour unit biofilter before entering a droplet eliminator. Final effluent washwater is also added to the process at this point. All of the remaining areas/items listed above are directed straight to the droplet eliminator, then through two exhaust fans, through a carbon filter and the cleaned air is released to atmosphere via a stack.

**OCU 2 (Odour Control Unit 2) – Sludge Works**

- Picket Fence Thickener
- Gravity Belt Thickeners
- Sludge Blending Tanks
- Emergency Sludge Holding Tanks (Primary and Secondary)
- Sludge Building
- Sludge Dewaterers and Dewaterers Skip
- Liquor Returns

All items are directed into the odour unit biofilter, including final effluent washwater, then directed to the droplet eliminator, through two no, exhaust fans and a carbon filter before being the cleaned air is released to atmosphere via a stack.

OCU-1 and OCU-2 are shown in the overall drawing for the site, i.e. Drawing C1197-3014, and are labelled as items 20/1 and 20/2.

OCU-2 is shown in more detail within the sludge treatment building in Drawing No. C1197-3006. Both OCUs are the same make and model and so OCU-1 is the same as OCU-2 shown in this drawing.

The process design details for the odour control design for the WWTP is included as Attachment C1197-8419. This data sheet provides information for each of the sources identified above. The average and maximum odour concentrations for each source is given, with the average and peak H<sub>2</sub>S (hydrogen sulphide) concentrations. The flow rate for the air from each source is also provided along with the dimensions and details of the vessels or tanks for each odour source are given.

The attached sheet also provides the calculations that were used to determine the ventilation rates and the resulting ventilation rates. Calculations for the Odour concentrations are also included, along with H<sub>2</sub>S and airflow rates. This data was then used for the air dispersion model, to predict odours at sensitive receptors and boundaries.

There will be open tanks within the plant, these are the activated sludge areas, i.e. the final settlement tanks, the aeration tanks and selector tank. These tanks contain activated sludge, which would not be considered a common source of odour and are not typically covered. The OCUs do not treat air from these tanks, i.e. there is no odour control treatment, as it is not considered necessary given the nature of the material and the location of the plant.

**(i) Biogas Storage, collection system and pipework; and waste burner**

Biogas is produced as a product of digestion of the sludge in the digester tanks. This is utilised to provide the prime fuel source for the boilers, providing hot water for the pasteuriser system. Excess gas (or unused gas) is diverted to the waste gas flare for burning. Should there be insufficient gas available then the boiler system is designed to operate with gas oil. There is no provision for scrubbing.

The biogas collection system is located in the sludge treatment area, as shown in Drawing No. C1197-3006 (see attached). The pipework is shown, and the direction of flow of the biogas, from the 2 no. digesters to the biogas condensate holder, shown in Drawing No. C1197-2023 and Drawing No. C1197-1024.

Biogas from the Sludge Digesters flows to the flexible membrane gasholder. Water from the gas condenses in the gas pipework and gravitates forward to the condensate trap/chamber. See Attachment C1197-8418.

Gas is prevented from escaping from the condensate trap by means of a water trap, condensate discharges into a small pumping chamber for subsequent return to the liquors treatment plant. A system of valves in the condensate trap allows isolation of

the gasholder if necessary. Low-pressure fans pressurising the space between the outer membrane of the gasholder and the internal membrane bag maintain gas pressure. Vacuum and pressure relief valves on the gasholder allow discharge under abnormal circumstances. The set pressures of the relief valves will be lower on top of the digesters than at the gas holder so that if there is a high gas pressure the relief will be at high level to make the best use of dispersion for safety and odour reasons.

The gas holder (Drawing No. C1197-1024) is a flexible membrane gas holder of 100m<sup>3</sup> capacity, which buffers the flow of biogas from the digesters and provides a reservoir of gas for semi-continuous operation of the boilers. The gas holder is constructed from two reinforced fabric membranes. The inner membrane is a hemispheric – cylindrical gas- holder, which is attached at its equator to the external, truncated spherical membrane, which is inflated by air pressure thus providing support to the inner membrane. The exterior membrane is inflated by two blowers, which maintain a constant air pressure in the outer membrane. The gas pressure is maintained by the exterior air pressure acting on the inner membrane.

The system operates at a working pressure of 200 mm wg. As the gas is utilised the inner membrane of the holder deflates under the constant pressure from the low-pressure fans. As the inner bag deflates an ultrasonic detector mounted in the top of the gasholder monitors the degree of deflation and computes a gas volume. Various set points will trigger various operations. As the inner membrane expands and fills with gas, the enclosed air volume between the inner and the outer membrane reduces, and to protect against this causing any excess air pressure, the air is automatically released through an air release valve mounted on the outer membrane. When gas consumption exceeds gas production the air blower provides air to replace the reducing gas volume whilst maintaining constant gas pressure.

Two air blowers configured as duty standby provide inflation air for the membrane Gasholder. These run continually in automatic and are rated for the maximum gas utilisation rate by the waste gas burner.

From the gas holder, the biogas is directed to the boilers, which are shown on Drawing No. C1197-3006. Gas is drawn from the gasholder via the condensate trap to the Boiler room for usage by the boilers (as the prime fuel source). The details of the gas use and flow rate for the boilers are shown in the P&ID for the boilers, included as Attachment C1197-8417.

A waste gas burner, located away from the gas holder, burns any excess Biogas, though as the hot water demand is high within the plant, use of this equipment will be limited and should be viewed as a standby route for the gas. This is shown in Drawing No. C1197-1024.

This low level waste gas burner operates under control of the SCADA (the operation control system). If the biogas level in the gasholder exceeds a set point the burner starts and biogas is drawn from the gasholder through a series of actuated valves and flame arrestors. In order that sufficient temperature is reached within the burner fresh air is added to the biogas at the burners to increase the oxygen/biogas mixture.

**(j) Location of boiler emission points**

The location of the boiler emission points A-01 (a&b) are shown in Drawing 07\_4084E.1.2Rev.1 (Figure E.1.2 Emissions to Atmosphere).

The 2 no. boilers can be seen in detail on Drawing No. C1197-3006. A P&ID diagram of the boilers is shown in Drawing No. C1197-1028. This shows the loop system from the pasteurisers to the boilers and also where water is added from the service water pipe to the boilers.

The underground pipework for the boilers is also provided as Drawing No. C1197-2031. This shows the pipe work for the hot water/service water, the electrical ducts serving the boiler, the sump and drainage points and the gas/fuel oil pipework (as already mentioned, diesel will only be used to power the boilers in the rare event that sufficient biogas is not available).

**(k) Provide further details of bunded areas and tanks**

The sludge treatment area will be bunded, as shown in Drawing No. C1197-3006. The hatched area is the bund that will surround the sludge treatment area.

The bund is an earth structure and is designed to contain sludge spillages should any of the structures within the bunded area rupture or if a pipe bursts. Its area is approximately 90m x 40 m x 1.5m deep giving a volume of approximately 5500 m<sup>3</sup>. In particular the largest individual item within the sludge area is a digester tank, which has a design volume of 1,721m<sup>3</sup>.

There is no installed provision for pumping out this sludge should there be a spill or leak. It will be done on an individual incident basis by external licensed contractors. An "Incident Response Plan" for dealing with this will be written as part of the O&M (Operations and Maintenance manual) manual for the operational phase of the Plant.

Also shown in Drawing No. C1197-3006 is the fuel tanks for the boilers and the generator, which will be diesel fuelled. These tanks are outlined in blue on the drawing. The tanks are double skinned and so no additional containment is provided.



DO NOT SCALE - IF IN DOUBT ASK



NOTE  
TREES INDICATED ARE TO BE RETAINED  
**THIS DRAWING TO BE READ IN CONJUNCTION WITH TEXT OF 3 o) (i) WATER LICENCE**

**PLANT LEGEND:**

- ① INLET CHANNEL
- ② SCREENING & GRT REMOVAL BUILDING
- ③ PRIMARY SETTLEMENT TANK
- ④ SELECTOR TANK
- ⑤ AERATION TANK
- ⑥ FINAL SETTLEMENT TANK
- ⑦ OUTFALL
- ⑧ AERATION BLOWERS (3 No.)
- ⑨ STORMWATER TANK
- ⑩ PICKET FENCE THICKENER
- ⑪ SLUDGE BLENDING TANK
- ⑫ SLUDGE PASTEURISATION
- ⑬ SLUDGE DICESTER
- ⑭ DICESTED SLUDGE TANK
- ⑮ GAS HOLDING TANK
- ⑯ ODOUR CONTROL UNIT
- ⑰ ODOUR CONTROL UNIT - INLET
- ⑱ ODOUR CONTROL UNIT - SLUDGE
- ⑲ ODOUR CONTROL UNIT - SLUDGE
- ⑳ WASTE GAS BURNER
- ㉑ DISCHARGE MONITORING CHAMBER
- ㉒ ADMINISTRATION BUILDING
- ㉓ SLUDGE THICKENING, DEWATERING & DIGESTION CONTROL BUILDING
- ㉔ FUEL TANK
- ㉕ SFP HOLDING AREA
- ㉖ SURFACE WATER MONITORING CHAMBER
- ㉗ THICKENED PRIMARY SLUDGE TANK
- ㉘ THICKENED SECONDARY SLUDGE TANK
- ㉙ BELIEW SEWER PUMPING STATION
- ㉚ RETURN LIQUORS PUMPING CHAMBER
- ㉛ RAS PUMPS (6 No. TOTAL)
- ㉜ PRIMARY SLUDGE PUMPS (3 No)

A.W.I. CONTRACT No 1002



Enpure Limited  
 Empire House,  
 Birmingham Road,  
 Kidderminster, DY11 0 2SH,  
 UK  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: WWW.ENPURE.CO.UK



Customer: WATERFORD CITY COUNCIL  
 Title: SITE LAYOUT  
 MAIN FEATURES  
 WATERFORD WWTW

Drawn	Checked	Approved	Checked	Scale
P/White				A1
Date: 23/09/2008	Date:	Date:	Date:	Scale:

IN REVIEW



Drg. No. C1197-3014

Rev. A



Grid lines: L, K, J, I, H, G, F, E, D, C, B, A (vertical)  
 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16 (horizontal)

DO NOT SCALE - IF IN DOUBT ASK



**NOTES**  
 1. SEE DRAWING NO C1197-9403 FOR DUCT SIZING AND ROUTING INFORMATION.

- H<sub>2</sub> (LOW LEVEL)
- O<sub>2</sub> (1.5 - 1.8m)
- CH<sub>4</sub> (HIGH LEVEL)
- ▨ STATUS INDICATOR

**APPROVED FOR CIVIL DESIGN**  
 REV. 6 DATE 03/07/2007  
 SIGNATURE JMNORTON

ISSUED APPROVED FOR CONSTRUCTION / SHE 2 REVIEW  
 COMPLETED  
 DATE: 08/03/2007 SIGNATURE: JMNORTON

**A.W.I. CONTRACT No 1002**

**enpure**

**enpure**

WATERFORD CITY COUNCIL

INLET WORKS  
 GENERAL ARRANGEMENT - PLAN  
 WATERFORD WWTW


Rev.	Date	Description	Drawn
9		GAS DETECTION SYSTEM ADDED.	

Drawn	Checked	Approved	Scale
DJL/Tidesley			A1
Date	Date	Date	Scale
07/11/2006			1:100

**AFC UNDER REVISION**

DO NOT SCALE - IF IN DOUBT ASK



For inspection purposes only.  
Consent of copyright owner required for any other use.

NOTE 1


- NOTES**
1. ALL PUMPED HYDRAULIC PIPE SIZES TO BE CONFIRMED BY EPS.

See Previous Issues For Past Revision Details

Rev#	Date	Description	Drawn
2	27/06/2008	HOSE POINT 5 NOTE ADDED	

CHECKED	PROCESS ENG. DGH	APPROVED	PROCESS TECH SPECIALIST DGG
	PROJECT ENG. JMN		PROJECT MAN. CGP
	LEAD MECH ENG.		MECH ENG MAN. BM
	LEAD ELEC ENG. AMT		ELEC ENG MAN. JL

A.W.I. CONTRACT No 1002



Empure Limited  
Empure House,  
Birmingham Road,  
Kidderminster, DY10 2SH,  
Tel: +44 (0)1562 820 010  
Fax: +44 (0)1562 820 008  
Internet: www.empure.co.uk

Customer: WATERFORD CITY COUNCIL  
Title: STORM TANKS  
P & I DIAGRAM  
WATERFORD WWTW


Drawn	Checked	Approved	Original
DUTTLESLEY	RJ MILLER	RAMSACKIN	Size A1
Date 20/10/2006	Date 26/06/2008	Date 27/06/2008	Scale NTS

ISSUED AFC

Drg. No. C1197-1013 Rev2



DO NOT SCALE - IF IN DOUBT ASK



- NOTES**
1. ALL PUMPED HYDRAULIC PIPE SIZES TO BE CONFIRMED BY EPS.
  2. DRAWING PREVIOUSLY E8374-1017

Rev	Date	Description	Drawn
1	27/06/2008	LINE REMOVED FROM P101705 ELEC TAG. (C/S#1701A,B,C & D ARE NOW CS1701A,B,C & D (PARK).	

For inspection purposes only. Copying of copyright owner required by any other use.

**LEGEND:**  
 NEW PIPEWORK/CHANNEL BY CIVLS CONTRACTOR.  
 NEW PIPEWORK BY MAE CONTRACTOR.  
 FUTURE PIPEWORK

CHECKED	PROCESS ENG. DGH	APPROVED	PROCESS TECH SPECIALIST DGG
	PROJECT ENG. JMN		PROJECT MAN. CGP
	LEAD MECH. ENG. JAM		MECH ENG MAN. BM
	LEAD ELEC. ENG. AMT		ELEC ENG MAN. JL

**A.W.I. CONTRACT No 1002**



Empure Limited  
 Empire House,  
 Birmingham Road,  
 Kidderminster, DY11 2SH,  
 UK  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: www.enpure.co.uk

**Customer:** WATERFORD CITY COUNCIL  
**Title:** FINAL SETTLEMENT TANKS  
**P & I DIAGRAM**  
 WATERFORD WWTTW


Drawn	Checked	Approved	Original Size
DJL/tdsley	RJ/Miller	RJ/Meakin	A1
Date	Date	Date	Original Scale
20/10/2006	26/06/2008	27/06/2008	NTS

**ISSUED AFC**

Dr. No. C1197-1017



DO NOT SCALE - IF IN DOUBT ASK



ISSUED AFC

Rev/	Date	Description	Drawn
1	27/06/2008	GENERAL MODS	

**NOTES**  
1. DRAWING PREVIOUSLY E837A-1027

**HOLDS**  
1. AWT TO CONFIRM SUPPLY SOURCE.

**LEGEND:**

- NEW PIPEWORK/CHANNEL BY CIVIL CONTRACTOR: (Solid blue line)
- NEW PIPEWORK BY M&E CONTRACTOR: (Dashed blue line)
- FUTURE PIPEWORK: (Dotted blue line)
- ENPURE PIPEWORK: (Solid yellow line)

PROCESS ENG.	DGH	PROCESS TECH SPECIALIST	DGG
PROJECT ENG.	JMN	PROJECT MAN.	CGP
LEAD MECH ENG.	JAM	MECH ENG MAN.	BM
LEAD ELEC ENG.	AMT	ELEC ENG MAN.	JL

**A.W.I. CONTRACT No 1002**


**coffeey** **enpure**

Enpure Limited  
Empire House,  
Birmingham Road,  
Kidderminster, DY11 2SH,  
UK  
Tel: +44 (0)1562 820 010  
Fax: +44 (0)1562 820 008  
Internet: www.enpure.co.uk

**enpure**

AS Copyright and Design Right subsisting in this document is the property of Enpure Limited of Enpure without Enpure's written consent. This document and the information contained within it is confidential to Enpure. Enpure and any firm related to Enpure may not be disclosed to any third party without Enpure's written consent.

Title		Customer	
WASHWATER & POTABLE WATER P & I DIAGRAM		WATERFORD CITY COUNCIL	
Drawn: D.J. Liddesley		Checked: R.J. Miller	
Date: 26/06/2008		Date: 27/06/2008	
Dwg. No. C1197-1027		Original Size: A1	
		Original Scale: NTS	




- NOTES**
1. REMOVED
  2. REMOVED
  3. REMOVED

**LEGEND:**  
 NEW PREWORK/CHANNEL BY CIVILS CONTRACTOR.  
 NEW PREWORK BY M&E CONTRACTOR.

PROCESS ENG. DGH	PROJECT MGR. DGG
PROJECT ENG. JMN	PROJECT MAN. CGP
LEAD MECH. JAM	MECH ENG. MAN. BM
LEAD ELEC. AMT	ELEC ENG. MAN. JL

**A.W.I. CONTRACT No 1002**



Empure Limited  
 Empire House,  
 Birmingham Road,  
 Kidderminster, DY11 2SH,  
 UK  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: www.empure.co.uk

**enpure**  
 WATERFORD CITY COUNCIL

**WATERFORD WWTTW**  
 P & I DIAGRAM







Drawn: DUTLIDSELEY	Checked: RUMMELER	Approved: RUMMELER	Original Size: A1
Date: 26/06/2008	Date: 27/06/2008	Date: 27/06/2008	Scale: NTS
Drg. No. C1197-1016			Rev: 1

**ISSUED AFC**

Rev	Date	Description	Drawn
1	27/06/2008	TS-1601 to 5 & PS-1601 to 5 ADDED	



DO NOT SCALE - IF IN DOUBT ASK



# AFC UNDER REVISION

Rev.	Date	Description	Drawn
5	07/11/2006	TML 7980 WAS 7935, TML 8872 WAS 8885, TML 7840 WAS 7553	

APPROVED FOR CIVIL DESIGN  
 REV. 5  
 DATE  
 SIGNATURE

ISSUED APPROVED FOR CONSTRUCTION / SHEET REVIEW  
 C/P/W: I. CONTRACT No 1002  
 DATE: 03/07/2007 SIGNATURE: DUTTIDSELEY

enpure










Empure Limited  
 Empure House,  
 Birmingham Road,  
 Kidderminster, DY10 2SH,  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: WWW.EMPURE.CO.UK

WATERFORD CITY COUNCIL  
 SELECTOR AND AERATION TANKS  
 WATERFORD WWTTW

Date	Checked	Approved	Checked	Checked
07/11/2006				

Scale: 1:175  
 Rev: 5

DO NOT SCALE - IF IN DOUBT ASK



For inspection purposes only.  
Consent of copyright owner required for any other use.

**AFC UNDER REVISION**

Rev.	Date	Description	Drawn
8		SECTION C-C REWISED TO EPS DRG.	

APPROVED FOR CIVIL DESIGN  
REV. 8 DATE  
SIGNATURE

ISSUED APPROVED FOR CONSTRUCTION / SHE 2 REVIEW  
COMPLETED  
DATE: 08/03/2007 SIGNATURE: JMN/KCN

A.W.I. CONTRACT No 1002

enpure

enpure

WATERFORD CITY COUNCIL

INLET WORKS  
GENERAL ARRANGEMENT - SECTIONS  
WATERFORD WWTW

Dwg. No.	Rev.
C1197-2001	8



PURAC				Project-Specific Data	
Grit / Grease Removal				Document Ref	8402
Standard Process Calculation: Project-specific data input is permitted to highlighted areas only.				Project No	C1197
				Project Name	Waterford
Calc Ref:	PCS001	Rev 1	Page 1	Process area code	
Author	D Garnett	Refer to PCS index for full details		Tag No(s)	
Calculation status:				Process Engineer	D. Hemmings
				Date	21-Nov-06
<b>Description</b>					
Two longitudinal, spiral flow type aerated grit and grease removal tanks are to be utilised. A bypass channel capable of taking 50% of the flow is also included should one lane be out of service.					
<b>Plant Flows</b>					
Peak flow		1.685	m <sup>3</sup> /s		
Mean flow		0.413	Cumecs		
Minimum flow		0.318	Cumecs		
<b>Design parameters</b>					
Detention time					
At maximum flow		3.0	Mins	Ref: Metcalf and Eddy 4th Edition page 389	
Adopt maximum flow		1.685	Cumecs		
No. of channels	Select	2	No.	Ref: Vol 4 section 7.3.2	
No. of channels as standby	Select	0	No.		
No. of operational channels		2	No.		
Total volume required		303	m <sup>3</sup>		
Volume per channel		152	m <sup>3</sup>		
Detention time					
At average flow		12.2	Mins		
Channel cross section - see also sketch					
D1 : Depth of channel	Select	4.00	m	Ref: Metcalf and Eddy 4th Edition page 389	
W1 : Width of Grit channel		3.40	m		
W2 : Width of grease channel		1.70	m		
W1 approx 0.85*D					
W2 approx W1/2 and between 1 - 2m					
W4 Width : Wall to grit sump	Select	0.75	m		
W3 Width of grit sump	Select	0.75	m		
D2 Depth of grit sump	Select	0.85	m		
Angle A of benching	Select	60			
Angle B of channel floor	Select	45			
<b>Area</b>					
Area a		20.4	m <sup>2</sup>		
Area b		0.5	m <sup>2</sup>		
Area c		4.8	m <sup>2</sup>		
Cross sectional area of channel		15.1	m <sup>2</sup>		
<b>Length of channel</b>					
Length of channel		10.01	m		
Actual Length	Rounded	10.00	m		
Actual W1	Rounded	3.40	m		
Actual W2	Rounded	1.70	m		
Total channel width		5.10	m		
<b>Check hydraulic rate at maximum flow</b>					
Check hydraulic rate at maximum flow		59.5	m/h	Note: don't consider surface of grease removal normally.	
		0.017	m/s		
Check hydraulic rate in non-aerated section		178.39	m/h		
<b>Purac AB design notes:</b>					
Take cross section area around	10 and 15		m <sup>2</sup>		
Take typical airflow as	40		m <sup>3</sup> /hr		
The airflow will be set on site.					
Use one Saunders valves per down comer and perforated stainless steel pipes DN40-50 as aerators.					
Fat removal zone width between	1 and 2		m		
Retention time at maximum flow	3 to 5		min		
Hydraulic load in non aerated zone	25		m/hr		


**Air Requirement**

Metcalf and Eddy states that an airflow of between 12 and 30 m<sup>3</sup>/h per m length of tank is required.


Nm <sup>3</sup> /h of air per m length of tank	Nm <sup>3</sup> /h	20.0
Air Requirement	Nm <sup>3</sup> /h	200.0

Expected grit quantities	m <sup>3</sup> /1000 m <sup>3</sup>	0.0150	Ref Metcalf and Eddy 4th Edition page 389
Grit quantities @ average flow	m <sup>3</sup> /d	0.54	

**Cross Section - Grit and Grease Channel**



DO NOT SCALE - IF IN DOUBT ASK



ELEVATION A-A


Scale 1:200

- H<sub>2</sub> (LOW LEVEL)
- O<sub>2</sub> (1.5 - 1.8m)
- CH<sub>4</sub> (HIGH LEVEL)
- ▨ STATUS INDICATOR

**SCHEDULE OF PIPE INSTALLATIONS**

Quantity of Gas for the specific schedule of corresponding pipe passing through unless noted otherwise

Ref	Pipe Size (W x H)	Invert Level	Qty.
1	TRW 500x600	8.465m	7
2	TRW 500x450	8.257m	2
3	ODOUR 500x400	8.800m	1




For inspection purposes only. Content of copyright owner required for any other use.

# DESIGN ISSUE

<p>See Previous Issues For Past Revision Details</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Rev.</th> <th>Date</th> <th>Description</th> <th>Drawn</th> </tr> </thead> <tbody> <tr> <td>P</td> <td>01/09/2008</td> <td>GENERATOR &amp; BOILER FUEL TANKS ADDED.</td> <td></td> </tr> </tbody> </table>		Rev.	Date	Description	Drawn	P	01/09/2008	GENERATOR & BOILER FUEL TANKS ADDED.					
Rev.	Date	Description	Drawn										
P	01/09/2008	GENERATOR & BOILER FUEL TANKS ADDED.											
<p><b>APPROVED FOR CIVIL DESIGN</b></p> <p>REV. P DATE 01/09/2008</p> <p>SIGNATURE CGPage</p>													
<p><b>A.W.I. CONTRACT No 1002</b></p> <p>enpure</p> <p>Empure Limited Empure House, Birmingham Road, Kidderminster, DY10 2SH. Tel: +44 (0)1562 820 010 Fax: +44 (0)1562 820 008 Internet: www.empure.co.uk</p>													
<p><b>WATERFORD CITY COUNCIL</b></p> <p>Sludge Thickening/De-watering Building General Arrangement Waterford WWTW</p>													
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Drawn</th> <th>Checked</th> <th>Approved</th> <th>Original</th> </tr> </thead> <tbody> <tr> <td>DJITidesley</td> <td>RJMakin</td> <td>CGPage</td> <td>Scale 1:125</td> </tr> <tr> <td>Date 15/11/2006</td> <td>Date 21/08/2008</td> <td>Date 01/09/2008</td> <td>Rev. P</td> </tr> </tbody> </table>		Drawn	Checked	Approved	Original	DJITidesley	RJMakin	CGPage	Scale 1:125	Date 15/11/2006	Date 21/08/2008	Date 01/09/2008	Rev. P
Drawn	Checked	Approved	Original										
DJITidesley	RJMakin	CGPage	Scale 1:125										
Date 15/11/2006	Date 21/08/2008	Date 01/09/2008	Rev. P										

DO NOT SCALE - IF IN DOUBT ASK



See Previous Issues For Past Revision Details

Rev. No.	Date	Description	Drawn
G	05/09/2008	OIL PIPEWORK AND VALVES DELETED. GENERATOR & BOILER FUEL TANKS ADDED.	

PIPELINE No.	DN (mm)	DESCRIPTION
P18	100	FROM BELT THICKENERS TO SLUDGE BLENDING TANK (PUMPED)
P19	100	FROM DIGESTED SLUDGE TANK TO PUMP SET (GRAMM)
P20	150	SLUDGE FROM P.S.T. TO PRIMARY SLUDGE PUMP (GRAMM) AND ONTO POCKET FENCE THICKENER (PUMPED)
P21	150	EXCESS GAS FROM GAS HOLDING TANK TO WASTE GAS BURNER
P22	100	SCUM FROM PRIMARY SETTLEMENT TANKS TO SLUDGE BLENDING TANK (PUMPED)
P23	100	SCUM FROM POCKET FENCE THICKENER TO SLUDGE BLENDING TANK (PUMPED)
P24	100	RETURN LIQUORS FROM RETURN LIQUORS PUMPING STATION TO PRIMARY SETTLEMENT DISTRIBUTION (PUMPED)
P25	150	BIOGAS FROM GAS HOLDER TO BOILERS (PUMPED)
P26	150	FINAL EFFLUENT WASTEWATER FROM DISCHARGE MONITORING CHAMBER TO SCREENING & GRIT REMOVAL BLDG. SLUDGE & STORM TANK HOSE POINTS (PUMPED)
P27	80	FINAL EFFLUENT RETURN FROM PASTERISER COOLER TO FINAL EFFLUENT CHAMBER (GRAMM)
P28	150	GAS FROM DIGESTERS TO CONDENSATE TRAP (GRAMM)
P29	200	HOT WATER FROM BOILERS TO HEAT EXCHANGERS (PUMPED)
P30	100	WARM WATER FROM HEAT EXCHANGERS TO BOILERS (PUMPED)
P31	150	FROM SLUDGE BLENDING TANK TO PASTERISER (PUMPED)
P32	150	FROM PASTERISERS TO DIGESTER TANKS (PUMPED)
P33	150	RETURNED SLUDGE FROM PASTERISERS TO THICKENED SECONDARY SLUDGE TANK (PUMPED)
P34	100	RETURN LIQUORS FROM LIQUOR CONTROL UNIT NOT DRAIN TO RETURN LIQUORS SUPPLY (GRAMM)
P35	250	CONNECTION BETWEEN STORM TANKS (GRAMM).
P36	100	SCUM FROM PUMP STATION TO SLUDGE BLENDING TANK (GRAMM)
P37	150	DEWATER FEED PUMP TO DEWATERER (PUMPED).
P38	X	DIESEL FUEL TO GENERATOR (PUMPED).
P39	38	DIESEL FUEL TO BOILERS (GRAMM).
P40	50	AIR LINE FROM COMPRESSOR TO PASTERISER (PUMPED).

**NOTE:-**  
 1. PIPEWORK COLOURED MAGENTA IS EPS SUPPLY  
 2. PIPEWORK COLOURED BLUE IS COFFEY SUPPLY  
 3. PIPEWORK COLOURED GREEN IS ENPURE SUPPLY

ISSUED APPROVED FOR CONSTRUCTION / SHE 2 REVIEW  
 DATE: 31/07/2007 SIGNATURE: CGPage  
 COMPLETED

**A.W.I. CONTRACT No 1002**

enpure

Enpure Limited  
 Empire House,  
 Birmingham Road,  
 Kiddlington, DY10 2SH.  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: www.enpure.co.uk

WATERFORD CITY COUNCIL

UPDATED SLUDGE AREA LAYOUT  
 PROPOSED CIVIL OUTLINE  
 WATERFORD WWWTW

Drawn	Checked	Approved	Original Sheet No.
DJ.Dittlesley	R.Meehan	CGPage	A1

Date: 21/06/2007 Date: 03/09/2008 Date: 05/09/2008

Drg. No. **C1197-3006** Rev. **G**

**APPROVED FOR CIVIL DESIGN**  
 REV. G DATE 05/09/2008  
 SIGNATURE CGPage

# DESIGN ISSUE






<b>BOILER SIZING</b>						
		Case 1	Case 2	Case 3	Case 4	
Total Heat Required by all Digesters	kW	253	314	744	921	Ref: 8416 Heat Exchanger Design
Number of Duty Boilers Selected		1	1	2	2	
Output Required by Each Boiler	kW	253	314	372	461	
Boiler output required to be specified to suppliers. Suppliers to select actual boiler model to meet the required output and advise actual output, efficiency and fuel input requirements. Calculation given below is for preliminary assessment purposes only.						
Boiler Output Selected (Each)	kW	500	500	500	500	
Boiler Efficiency (Assumed)	%	80	80	80	80	
Estimated Fuel Input Required (Each)	kW	625	625	625	625	
<b>Sludge Gas Usage</b>						
Gas Net Calorific Value	MJ/Nm <sup>3</sup>	22.5	22.5	22.5	22.5	
Approximate Gas Flowrate (Each)	Nm <sup>3</sup> /h	100	100	100	100	
Approximate Gas Flowrate (Total)	Nm <sup>3</sup> /h	100	100	200	200	
Minimum Gas Yield (Total)	m <sup>3</sup> /d	2291	2291	3776	3776	8413 Gas Production
Proportion of Minimum Gas Yield Consumed by all Boilers	%	105	105	127	127	
<b>Standby Fuels</b>						
Fuel Oil Net Calorific Value	MJ/m <sup>3</sup>	36900.00	36900.00	36900.00	36900.00	
Fuel Oil Flowrate (approx)	m <sup>3</sup> /h	0.06	0.06	0.06	0.06	
	l/h	61	61	61	61	
LPG Net Calorific Value	MJ/m <sup>3</sup>	93.90	93.90	93.90	93.90	
LPG Flowrate (approx)	Nm <sup>3</sup> /h	23.96	23.96	23.96	23.96	
Natural Gas Net Calorific Value	MJ/Nm <sup>3</sup>	38.62	38.62	38.62	38.62	
Natural Gas Flowrate (approx)	Nm <sup>3</sup> /h	58.26	58.26	58.26	58.26	

For inspection purposes only. Consent of copyright owner required for any other use.



DO NOT SCALE - IF IN DOUBT ASK



See Previous Issues For Past Revision Details

Rev.	Date	Description	Drawn
A		FIRST ISSUE	

**NOTE**  
TREES INDICATED ARE TO BE RETAINED  
**THIS DRAWING TO BE READ IN CONJUNCTION WITH TEXT OF 3 o) (i) WATER LICENCE**

- PLANT LEGEND:**
- ① INLET CHANNEL
  - ② SCREENING & GRIT REMOVAL BUILDING
  - ③ PRIMARY SETTLEMENT TANK
  - ④ SELECTOR TANK
  - ⑤ AERATION TANK
  - ⑥ FINAL SETTLEMENT TANK
  - ⑦ OUTFALL
  - ⑧ AERATION BLOWERS (5 No.)
  - ⑨ STORMWATER TANK
  - ⑩ PICKET FENCE THICKENER
  - ⑪ SLUDGE BLENDING TANK
  - ⑫ SLUDGE PASTEURISATION
  - ⑬ SLUDGE DIGESTER
  - ⑭ DIGESTED SLUDGE TANK
  - ⑮ GAS HOLDING TANK
  - ⑯ ODOUR CONTROL UNIT - INLET
  - ⑰ ODOUR CONTROL UNIT - SLUDGE
  - ⑱ WASTE GAS BURNER
  - ⑲ DISCHARGE MONITORING CHAMBER
  - ⑳ ADMINISTRATION BUILDING
  - ㉑ SLUDGE THICKENING, DEWATERING & DIGESTION CONTROL BUILDING
  - ㉒ FUEL TANK
  - ㉓ SFP HOLDING AREA
  - ㉔ SURFACE WATER MONITORING CHAMBER
  - ㉕ THICKENED PRIMARY SLUDGE TANK
  - ㉖ THICKENED SECONDARY SLUDGE TANK
  - ㉗ BETWEEN SEWER PUMPING STATION
  - ㉘ RETURN LIQUORS PUMPING CHAMBER
  - ㉙ RAS PUMPS (6 No. TOTAL)
  - ㉚ PRIMARY SLUDGE PUMPS (3 No.)

A.W.I. CONTRACT No 1002



Customer: WATERFORD CITY COUNCIL


Title: SITE LAYOUT  
MAIN FEATURES  
WATERFORD WWTW

Date	Drawn	Checked	Approved	Checked	Scale
23/09/2008	P/White				A1

Dwg. No. C1197-3014

**IN REVIEW**

DO NOT SCALE - IF IN DOUBT ASK



For inspection purposes only.  
Consent of copyright owner required for any other use.

See Previous Issues For Past Revision Details

Rev	Date	Description	Drawn
1	27/06/2008	UPDATED TO SUPPLIERS INFORMATION	

NOTES  
1. REMOVED

**LEGEND:**  
NEW PIPEWORK/CHANNEL BY CIVILS CONTRACTOR.  
NEW PIPEWORK BY MECH CONTRACTOR.

CHECKED	PROCESS ENG. DGH	APPROVED	PROCESS TECH SPECIALIST DGG
	PROJECT ENG. JMN		PROJECT MAN. CGP
	LEAD MECH ENG. JAM		MECH ENG MAN. BM
	LEAD ELEC ENG. AMT		ELEC ENG MAN. JL

A.W.I. CONTRACT No 1002



Empure Limited  
Empire House,  
Birmingham Road,  
Kidderminster, DY11 2SH,  
UK  
Tel: +44 (0)1562 820 010  
Fax: +44 (0)1562 820 008  
Internet: www.empure.co.uk

Customer  
WATERFORD CITY COUNCIL

Title  
ODOUR CONTROL  
P & I DIAGRAM  
WATERFORD WWTTW

Drawn	Checked	Approved	Original
DJL/Didsley	RJ/Miller	RJ/Meakin	Size A1
Date 20/10/2006	Date 26/06/2008	Date 27/06/2008	Scale NTS

ISSUED AFC

Drg. No. C1197-1026



<b>PURAC Contract No.</b>	<b>C:1197</b>
<b>Contract Title</b>	<b>Waterford WwTW</b>
<b>PURAC Document No.</b>	<b>8419</b>
<b>Date</b>	<b>09/02/07</b>
<b>Revision</b>	<b>2</b>

List/Odour Control Unit Names	P&ID no.	Tag No.	Ave Odour concentration (OU <sub>E</sub> /m <sup>3</sup> )	Max Odour concentration (OU <sub>E</sub> /m <sup>3</sup> )	Ave H <sub>2</sub> S conc (ppm)	Peak H <sub>2</sub> S conc (ppm)	Air flowrate (m <sup>3</sup> /hr)
Combined Treatment OCU	C1197-1026	TBC	0	0	0.0	0.0	0
Inlet Treatment OCU	C1197-1026	TBC	63533	63533	0.0	0.0	0
Sludge Treatment OCU	C1197-1026	TBC	97976	97976	19.2	19.2	13815
Other discharges			0	0	49.0	49.0	5042
			0	0	0.0	0.0	0
			72743	72743	27.1	27.1	18857

Check calc integrity OK OK OK OK

Orange cells require input

Areas to be odour controlled

Process Area	Process Fluid	P&ID no. & GA no.	No.	Tag No(s)	Air extracted to:	Ave Odour concentration (OU <sub>E</sub> /m <sup>3</sup> )	Max Odour concentration (OU <sub>E</sub> /m <sup>3</sup> )	Converted average H <sub>2</sub> S conc. (ppm)	Converted peak H <sub>2</sub> S conc. (ppm)	Air flowrate (m <sup>3</sup> /hr)
Pre-screen and post-grit channels	Raw Sewage	C1197-1012 & 2000/1	1	T-1201	Inlet Treatment OCU	131243	131243	39	39	388
Fine Screens including bypass	Raw Sewage	C1197-1012 & 2000/1	4	A-1201A/B/C & A-1202	Inlet Treatment OCU	81000	81000	24	24	704
Screenings Compactors	Raw Sewage	C1197-1014 & 2000/1	1	A-1401	Inlet Treatment OCU	80000	80000	40	40	32
Grit Classifier	Grit	C1197-1014 & 2000/1	1	A-1402	Inlet Treatment OCU	160000	160000	80	80	32
Grit Channel	Raw Sewage	C1197-1012 & 2000/1	2	T-1202A/B	Inlet Treatment OCU	65833	65833	20	20	1004
Preliminary Treatment Building	N/A	C1197-1012 & 2000/1	1		Inlet Treatment OCU	150	150	0	0	7247
Primary Sedimentation Tank	Screened Sewage	C1197-1015 & 2004	2	T-1501A/B	Inlet Treatment OCU	157664	157664	47	47	4407
Pasturiser	Sludge	C1197-1020	3	T-2001A/B/C	Sludge Treatment OCU	630000	630000	315	315	246
Picket Fence Thickener	Primary Sludge	C1197-1018	1	T-1801	Sludge Treatment OCU	420000	420000	210	210	178
Secondary Sludge Thickener	Secondary Sludge	C1197-1018 & 2011	2	A-1802A/B	Sludge Treatment OCU	280000	280000	140	140	60
Sludge Building	N/A	C1197-1018 & 2011	1		Sludge Treatment OCU	800	800	0	0	3580
Emergency Primary Sludge Tank	Primary Sludge	C1197-1019	1	T-1903	Sludge Treatment OCU	315000	315000	158	158	276
Emergency Secondary Sludge Tank	Secondary Sludge	C1197-1019	1	T-1902	Sludge Treatment OCU	315000	315000	158	158	329
Sludge Blending Tank	Sludge	C1197-1019	1	T-1901	Sludge Treatment OCU	630000	630000	315	315	41
Sludge Dewaterer	Sludge	C1197-1023 & 2011	2	A-2301A/B	Sludge Treatment OCU	96000	96000	48	48	90
Liquor Return PS	Sludge Liquors	C1197-1030	1	C-3001	Sludge Treatment OCU	78750	78750	39	39	240

**C1197 - Waterford WwTW  
Ventilation, Odour Control and Declassification of Zoned Areas Calculations**

PURAC Document No. 8419

Date 09/02/2007

Revision 2

Orange cells require input

Process Area	Process fluid	No.	Vessel Shape	Working Dimensions / Details						Headspace / Gross Vessel Dimensions / Details						Process volume / Gross volume (per unit) m <sup>3</sup>	Headspace / Gross volume m <sup>3</sup>	Tank Perimeter (per unit) m	Cover Perimeter m	Actual Perimeter	Max fill rate or specified (per unit) m <sup>3</sup> /hr
				52.4 m length	1.8 m deep	1.5 m width	52.4 m length	0.5 m deep	1.5 m width	1.5 m width	52.4 m length	0.5 m deep	1.5 m width	1.5 m width							
Pre-screen and post-grit channel	Raw Sewage	1	Rectangular	52.4 m length	1.8 m deep	1.5 m width	52.4 m length	0.5 m deep	1.5 m width	1.5 m width	52.4 m length	0.5 m deep	1.5 m width	141.5	39.3	107.8		Perimeter			
Fine Screens including bypass	Raw Sewage	4	Rectangular	10 m length	2.2 m deep	2.2 m width	10 m length	1 m deep	2.2 m width	2.2 m width	10 m length	1 m deep	2.2 m width	48.4	22.0	24.4		Perimeter			
Screenings Compactors	Raw Sewage	1	Other	4 m <sup>3</sup> volume										4.0	4.0	N/A		N/A			
Grit Classifier	Grit	1	Other	4 m <sup>3</sup> volume										4.0	4.0	N/A		N/A			
Grit Channel	Raw Sewage	2	Rectangular	10 m length	2.2 m deep	5.1 m width	10 m length	0.5 m deep	5.1 m width	5.1 m width	10 m length	0.5 m deep	5.1 m width	112.2	25.5	30.2		Perimeter	400		
Preliminary Treatment Building	N/A	1	Rectangular	29.3 m length	6.38 m deep	19.4 m width	29.3 m length	6.38 m deep	19.4 m width	19.4 m width	29.3 m length	6.38 m deep	19.4 m width	3623.7	3623.7	97.4		N/A			
Primary Sedimentation Tank	Screened Sewage	2	Circular	32 m diam	3 m deep		32 m diam	1.37 m deep			32 m diam	1.37 m deep		2412.7	1101.8	100.5		Perimeter			
Pasteuriser	Sludge	3	Other	41 m <sup>3</sup> volume										41.0	41.0	N/A		N/A			
Picket Fence Thickener	Primary Sludge	1	Circular	8.7 m diam	4.5 m deep		8.7 m diam	0.5 m deep			8.7 m diam	0.5 m deep		267.5	29.7	27.3		Perimeter	8		
Secondary Sludge Thickener	Secondary Sludge	2	Rectangular	5.6 m length	0.75 m deep	1.2 m width	5.6 m length	0.75 m deep	1.2 m width	1.2 m width	5.6 m length	0.75 m deep	1.2 m width	5.0	5.0	13.6		Cover			
Sludge Building	N/A	1	Rectangular	19.5 m length	6.38 m deep	14.4 m width	19.5 m length	6.38 m deep	14.4 m width	14.4 m width	19.5 m length	6.38 m deep	14.4 m width	1790.1	1790.1	67.8		N/A	2		
Emergency Primary Sludge Tank	Primary Sludge	1	Circular	9.38 m diam	5.6 m deep		9.38 m diam	2 m deep			9.38 m diam	2 m deep		387.0	138.2	29.5		Cover			
Emergency Secondary Sludge Tank	Secondary Sludge	1	Circular	10.2 m diam	5.6 m deep		10.2 m diam	2 m deep			10.2 m diam	2 m deep		461.2	164.7	32.2		Cover			
Sludge Blending Tank	Sludge	1	Circular	5.12 m diam	2.9 m deep	2 m width	5.12 m diam	1 m deep	2 m width	2 m width	5.12 m diam	1 m deep	2 m width	59.7	20.6	16.1		Cover			
Sludge Dewaterer	Sludge	2	Rectangular	5 m length	0.75 m deep	2 m width	5 m length	0.75 m deep	2 m width	2 m width	5 m length	0.75 m deep	2 m width	7.5	7.5	14.0		Cover			
	0.0	0	Rectangular	m length	m deep	m width	m length	m deep	m width	m width	m length	m deep	m width	0.0	0.0	0.0		N/A			
Liquor Return PS	Sludge Liquors	1	Rectangular	3 m length	4 m deep	5 m width	3 m length	4 m deep	5 m width	5 m width	3 m length	4 m deep	5 m width	60.0	60.0	16.0		Perimeter	240		

**C1197 - Waterford WwTW  
Ventilation, Odour Control and Declassification of Zoned Areas Calculations**

PURAC Document No. 8419

Date 09/02/2007

Revision 2

Process Area	CH <sub>4</sub> rate of emission m <sup>3</sup> m <sup>3</sup> sec <sup>-1</sup> x 10 <sup>-6</sup>	Air changes per hour	Temp °C	LEL %	Density kg / m <sup>3</sup>	Grade of release	BS safety factor k	Gas production rate kg/s	Temperature corrected rate kg/s	Actual gas production rate kg/s	Calculations for zoning declassification ventilation rate				Safety Factor	Final rate per unit (Max X SF) m <sup>3</sup> /hr	Choose flowrate per unit	Actual flowrate per unit m <sup>3</sup> /hr	Actual air changes per hour (based on headspace)
											Rate 1	Rate 2	Rate 3	Rate 4					
Pre-screen and post-grit channel	6.9	8.0	20	5.3	0.72	Secondary	0.5	7.03E-06	5.35E-06	Corrected	388.1	1.1	N/A	314.4	0%	388.1	Max xSF	388.1	9.9
Fine Screens including bypass	6.9	8.0	20	5.3	0.72	Secondary	0.5	2.40E-06	1.83E-06	Corrected	87.8	0.4	N/A	176.0	0%	176.0	Max xSF	176.0	8.0
Screenings Compactors	0.0	8.0	20	5.3	0.72	Secondary	0.5	0.00E+00	0.00E+00	Corrected	N/A	0.0	N/A	32.0	0%	32.0	Max xSF	32.0	8.0
Grit Classifier	0.0	8.0	20	5.3	0.72	Secondary	0.5	0.00E+00	0.00E+00	Corrected	N/A	0.0	N/A	32.0	0%	32.0	Max xSF	32.0	8.0
Grit Channel	6.9	4.0	20	5.3	0.72	Secondary	0.5	5.57E-06	4.25E-06	Corrected	108.7	0.9	400.0	102.0	26%	502.0	Max xSF	502.0	19.7
Preliminary Treatment Building	0.0	2.0	20	5.3	0.72	Secondary	0.5	0.00E+00	0.00E+00	Corrected	N/A	0.0	N/A	7247.4	0%	7247.4	Max xSF	7247.4	2.0
Primary Sedimentation Tank	6.9	2.0	20	5.3	0.72	Secondary	0.5	1.20E-04	9.13E-05	Corrected	361.9	18.6	N/A	2203.6	0%	2203.6	Max xSF	2203.6	2.0
Pasteuriser	163.0	2.0	55	5.3	0.72	Secondary	0.5	4.81E-05	6.07E-05	Corrected	N/A	13.9	N/A	82.0	0%	82.0	Max xSF	82.0	2.0
Picket Fence Thickener	289.0	6.0	20	5.3	0.72	Secondary	0.5	5.57E-04	4.24E-04	Corrected	98.4	86.5	8.0	178.3	0%	178.3	Max xSF	178.3	6.0
Secondary Sludge Thickener	163.0	6.0	20	5.3	0.72	Secondary	0.5	5.91E-06	4.50E-06	Corrected	0.0	0.9	N/A	30.2	0%	30.2	Max xSF	30.2	6.0
Sludge Building	0.0	2.0	20	5.3	0.72	Secondary	0.5	0.00E+00	0.00E+00	Corrected	N/A	0.0	2.0	3580.2	0%	3580.2	Max xSF	3580.2	2.0
Emergency Primary Sludge Tank	289.0	2.0	20	5.3	0.72	Secondary	0.5	8.08E-04	6.13E-04	Corrected	0.0	125.2	N/A	276.4	0%	276.4	Max xSF	276.4	2.0
Emergency Secondary Sludge Tank	163.0	2.0	20	5.3	0.72	Secondary	0.5	5.41E-04	4.12E-04	Corrected	0.0	84.1	N/A	329.4	0%	329.4	Max xSF	329.4	2.0
Sludge Blending Tank	289.0	2.0	20	5.3	0.72	Secondary	0.5	1.24E-04	9.46E-05	Corrected	0.0	19.3	N/A	41.2	0%	41.2	Max xSF	41.2	2.0
Sludge Dewaterer	110.0	6.0	20	5.3	0.72	Secondary	0.5	5.94E-06	4.52E-06	Corrected	0.0	0.9	N/A	45.0	0%	45.0	Max xSF	45.0	6.0
0	0.0	2.0	20	5.3	0.72	Secondary	0.5	0.00E+00	0.00E+00	Corrected	N/A	0.0	N/A	0.0	0%	0.0	Max xSF	0.0	#DIV/0!
Liquor Return PS	110.0	2.0	20	5.3	0.72	Secondary	0.5	4.75E-05	3.62E-05	Corrected	57.6	7.4	240.0	120.0	0%	240.0	Max xSF	240.0	4.0



**C1197 - Waterford WwTW  
Ventilation, Odour Control and Declassification of Zoned Areas Calculations**

PURAC Document No. 8419


Date 09/02/2007

Revision 2

Process Area	OU concentration calculation						Final Calculated Odour, H <sub>2</sub> S and airflow rates							
	Frechen data E <sub>f</sub> (OU / s / m <sup>2</sup> )	North data E <sub>n</sub> (OU / s / m <sup>2</sup> )	UKWIR value OU <sub>E</sub> ·s <sup>-1</sup> ·m <sup>-2</sup>	Surface area per tank A (m <sup>2</sup> )	Superficial air velocity V (m / s)	Emission rate E <sub>out</sub> (OU / s)	Specified Odour concentration (OU <sub>E</sub> / m <sup>3</sup> )	Odour concentration (OU <sub>E</sub> / m <sup>3</sup> )	Chosen H <sub>2</sub> S correlation factor ppb H <sub>2</sub> S/OU <sub>E</sub>	Direct H <sub>2</sub> S correlation (ppm)	Factor of safety (peaking factor)	Odour concentration using SF (OU <sub>E</sub> / m <sup>3</sup> )	Estimated H <sub>2</sub> S conc. using SF (ppm)	Total flow m <sup>3</sup> /hr
Pre-screen and post-grit channels			180	78.6	0.004	14148		131243	0.3	39.4	1.0	131243	39.4	388
Fine Screens including bypass			180	22.0	0.002	3960		81000	0.3	24.3	1.0	81000	24.3	704
Screenings Compactors			180	N/A	N/A	N/A	80000	80000	0.5	40.0	1.0	80000	40.0	32
Grit Classifier			360	N/A	N/A	N/A	160000	160000	0.5	80.0	1.0	160000	80.0	32
Grit Channel			180	51.0	0.003	9180		65833	0.3	19.7	1.0	65833	19.7	1004
Preliminary Treatment Building				568.4	0.004	0	150	150	0.3	0.05	1.0	150	0.05	7247
Primary Sedimentation Tank			120	804.2	0.001	96510		157664	0.3	47.3	1.0	157664	47.3	4407
Pasteuriser			480	N/A	N/A	N/A	630000	630000	0.5	315.0	1.0	630000	315.0	246
Picket Fence Thickener			350	59.4	0.001	20806		420000	0.5	210.0	1.0	420000	210.0	178
Secondary Sludge Thickener			350	6.7	0.001	2352		280000	0.5	140.0	1.0	280000	140.0	60
Sludge Building				280.8	0.004	0	800	800	0.5	0.4	1.0	800	0.4	3580
Emergency Primary Sludge Tank			350	69.1	0.001	24186		315000	0.5	157.5	1.0	315000	157.5	276
Emergency Secondary Sludge Tank			350	82.4	0.001	28824		315000	0.5	157.5	1.0	315000	157.5	329
Sludge Blending Tank			350	20.6	0.001	7206		630000	0.5	315.0	1.0	630000	315.0	41
Sludge Dewaterer			120	10.0	0.001	1200		96000	0.5	48.0	1.0	96000	48.0	90
0.0				0.0	0.000	0	0	0	0.2	0.0	1.0	0	0.0	0
Liquor Return PS			350	15.0	0.004	5250		78750	0.5	39.4	1.0	78750	39.4	240
								72742.7		27.1		72742.7	27.1	18857

DO NOT SCALE - IF IN DOUBT ASK


Rev. 1  
C1197-2023



SECTION B-B

For inspection purposes only.  
Consent of copyright owner required for any other use.

SEEPEC CONDENSATE TRANSFER VERTICAL PUMPS  
PROGRESSIVE CAVITY PUMPS. TYPE:  
BE 5-6L / AS-A7-R0-GAM3.2-X  
DISCHARGE FLANGE: DN50 PN16 3m/1.36AR 224RPM  
FITTED GEARED MOTOR: 1.1KW 1390 RPM  
DRG. No. 271-A32/0020-C-018A3  
OFFER No. 1903/1322 OF 25/06/2007  
PUMPS TO BE FREE ISSUED TO TANK SUPPLIER FOR  
INSTALLATION INTO TANK BEFORE DELIVERY TO SITE.



Rev.	Date	Description	Drawn
1	24/09/2007	REBRAM, WAS IN ROUND CHAMBER	

NOTE : THE DIGESTER BIOGAS IS AT A PRESSURE OF 200mm Wg (20 mBAR) ABOVE ATMOSPHERIC CONDITIONS AND THE DIGESTER PRESSURE RELIEF VALVES WILL BE SET TO DISCHARGE AT 275mm Wg.

NOTE : IT IS OF PARAMOUNT IMPORTANCE THAT THE BIOGAS PIPEWORK BETWEEN DIGESTERS AND CONDENSATE TRAP (CT), GROUND FLARE AND CT GAS HOLDER AND CT AND HOT WATER BOILERS AND CT ALL SLOPE, WITH CONSTANT GRADIENT "DOWN" TOWARDS THE PIPEWORK ABOVE THE CONDENSATE TRAP. TYPICAL CONSTANT GRADIENT 1:100. DIGESTER BIOGAS AT 36°C IS SATURATED WITH WATER VAPOUR AND ANY COOLING OF THE GAS WILL RESULT IN CONDENSATE CONTAINING SULPHUR. THIS LIQUOR MUST FLOW DOWNHILL TO THE CONDENSATE TRAP. ANY DIP IN THE GRADIENT MAY RESULT IN THE GAS FLOW/RATES BEING THROTTLED OR COMPLETELY STOPPED. DUE TO THE PURPOSE OF THE CT IS TO FULLY REMOVE THE LIQUOR FROM THE SYSTEM AND THEREBY ALLOW THE UNRESTRICTED FLOW OF BIOGAS THROUGH THE SYSTEM.

ISSUED AFC

ISSUED APPROVED FOR CONSTRUCTION / SHE 2 REVIEW  
COMPLETED  
DATE: 02/11/2007 SIGNATURE: JMK/ncn

**A.W.I. CONTRACT No 1002**

*was the* **enpure**

Enpure Limited  
Enpure House,  
Birmingham Road,  
Kidderminster, DY10 2SH,  
Tel: +44 (0)1562 820 010  
Fax: +44 (0)1562 820 008  
Internet: [www.enpure.co.uk](http://www.enpure.co.uk)

**enpure**


Customer  
WATERFORD CITY COUNCIL

The  
CONDENSATE TRAP  
GENERAL ARRANGEMENTS  
WATERFORD WWTTW

Date	Checked	Approved	Scale
12/02/2007	CW/Thomas	RJ/Weakin	CG/Pege
19/09/2007			24/09/2007

Scale: 1:20  
Rev: 1

DO NOT SCALE - IF IN DOUBT ASK



For inspection purposes only. Consent of copyright owner required for any other use.

See Previous Issues For Past Revision Details		
Rev	Date	Description
1	27/06/2008	ELEC TAGS UPDATED AND GAS HOLDER REVISED.

**NOTES**  
1. DRAWING PREVIOUSLY E8374-1024

CHECKED		APPROVED	
PROCESS ENG.	DGH	PROCESS TECH SPECIALIST	DGG
PROJECT ENG.	JMN	PROJECT MAN.	CGP
LEAD MECH ENG.	JAM	MECH ENG MAN.	BM
LEAD ELEC ENG.	AMT	ELEC ENG MAN.	JL

**A.W.I. CONTRACT No 1002**



Empure Limited  
Empure House,  
Birmingham Road,  
Kidderminster, DY11 2SH,  
Tel: +44 (0)1562 820 010  
Fax: +44 (0)1562 820 008  
Internet: [www.empure.co.uk](http://www.empure.co.uk)

**ISSUED AFC**

Drawn	Checked	Approved	Original
DUTTIDESLEY	RJ MILLER	RAMSACKIN	A1
Date	Date	Date	Original
20/10/2008	26/06/2008	27/06/2008	NTS
Drw. No. <b>C1197-1024</b>			Rev <b>1</b>



**GAS HOLDER, EXCESS GAS BURNER AND DIGESTER PRESSURE/VACUUM RELIEF VALVES SIZING**

		Case 1	Case 2	Case 3	Case 4
<b>Gas Holder</b>					
Number of Gas Holders		1	1	1	1
Average Gas Production Rate	m <sup>3</sup> /h	193	164	157	95
Retention Time in each Gas Holder	min	20	20	20	20
Capacity of each Gas Holder	m <sup>3</sup>	64	55	52	32
Selected Capacity of each Gas Holder	m <sup>3</sup>	65	65	65	65
Retention Time at Minimum Production Rate	min	23	27	28	46
Retention Time at Average Production Rate	min	20	24	25	41
Retention Time at Maximum Production Rate	min	18	21	22	37

**Excess Gas Burner**

Maximum Gas Production Rate	m <sup>3</sup> /h	215	182	175	106
Gas Burner Oversizing Margin	%	25	25	25	25
Gas Burner Capacity Required	m <sup>3</sup> /h	268	228	219	133

**Digester Pressure/Vacuum Relief Valve - Pressure Relief Condition**

Maximum Gas Production Rate	m <sup>3</sup> /h	107	91	87	53	
Mixing Compressor Flowrate	m <sup>3</sup> /h	0	0	0	0	Mechanical Mixing
Digester Feed Volume	m <sup>3</sup> /h	15	15	15	15	Ref: Pasteurisation design sheets 8420
Pressure Relief Rate Required	m <sup>3</sup> /h	122	106	102	68	

**Digester Pressure/Vacuum Relief Valve - Vacuum Relief Condition**


Digester Height (Centre of Cone to TWL)	m	13.173	13.173	13.173	13.173
Drain Pipe Diameter (ID)	m	0.20	0.20	0.20	0.20
Drain Pipe Length	m	0.0	15.0	18.0	20.0
Roughness	mm	0.5	0.5	0.5	0.5
Fittings K <sub>T</sub>		2	2	2	2

Maximum vacuum relief rate will occur when the friction loss in the outlet line is equal to the static head above the outlet. To evaluate this, the flowrate at which the static head is equal to the friction loss must be determined. Note that the friction factor and hence the friction loss is dependent on the flowrate so the equations must be solved by iteration.

To solve, use the following procedure :

From "Tools" menu choose "Goal Seek"  
 In "Set cell" box enter "C64", "D64", "E64", "F64"  
 In "To value" box enter number contained in cell C39, D39, E39, F39  
 In "By changing cell" box enter "C56", "D56", "E56", "F56"

Maximum Flowrate	m <sup>3</sup> /h	882	824	794	776
Water Temperature for Design	°C	35.0	35.0	35.0	35.0
Water Density	kg/m <sup>3</sup>	994	994	994	994
Water Viscosity	mNs/m <sup>2</sup>	0.7204	0.7204	0.7204	0.7204
Velocity	m/s	7.80	7.28	7.02	6.86
Reynolds Number		2152745	2010124	1937033	1892508
Friction Factor	f <sub>us</sub>	0.02495	0.02495	0.02496	0.02496
Dynamic Head Loss	m H <sub>2</sub> O	13.17	13.17	13.17	13.17
Vacuum Relief Flowrate Required	m <sup>3</sup> /h	882	824	794	776



- Odour Emission Points
- Boiler Emission Points

Site Boundary

Scale 1:2500

**Project**  
Waterford WWTP Waste Licence Application


**Reference**  
07/4084E.1.2

**Figure E.1.2Rev.1**  
Location of Points of Emissions to Atmosphere (2)



Unit 5, ATS Building, Carrigaline Industrial Park, Carrigaline, Co. Cork  
T: +353 21 438 7400 F: +353 21 483 4617

DO NOT SCALE - IF IN DOUBT ASK



See Previous Issues For Past Revision Details


Rev	Date	Description	Drawn
1	27/06/2008	GENERAL MODS	

- NOTES**
1. REMOVED
  2. REMOVED

**LEGEND:**  
 NEW PIPEWORK/CHANNEL BY CIVLS CONTRACTOR  
 NEW PIPEWORK BY M&E CONTRACTOR  
 ENPURE PIPEWORK

CHECKED		APPROVED	
PROCESS ENG.	DGH	PROCESS TECH SPECIALIST	DGG
PROJECT ENG.		PROJECT MAN.	CGP
LEAD MECH ENG.	JAM	MECH ENG MAN.	BM
LEAD ELEC ENG.	AMT	ELEC ENG MAN.	JL

A.W.I. CONTRACT No 1002



Empure Limited  
 Empure House,  
 Birmingham Road,  
 Kidderminster, DY11 2SH,  
 UK  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: www.empure.co.uk


Customer: WATERFORD CITY COUNCIL  
 Title: BOILER SYSTEM P & I DIAGRAM  
 WATERFORD WWTTW

Drawn	Checked	Approved	Original Size
DUTTIDESLEY	RJ MILLER	RAMSAY	A1
Date: 20/10/2008	Date: 26/06/2008	Date: 27/06/2008	Original Scale: NTS

Drg. No. C1197-1028

ISSUED AFC

DO NOT SCALE - IF IN DOUBT ASK



**BOILER ROOM**  
 HOT/SERVICE WATER-LAYER PIPE-1  
 ELEC DUCTS-LAYER PIPE-2  
 SUMP AND DRAINAGE POINTS-LAYER PIPE-3  
 GAS/FUEL OIL-LAYER PIPE-4

# DESIGN ISSUE


Rev.	Date	Description	Drawn
A	04/09/2007	FIRST ISSUE	DDF

**NOTE:-**  
 THIS DRAWING TO BE READ IN CONJUNCTION WITH DRAWING C1197-2013 FOR ALL DIMENSIONS ETC.

A.W.I. CONTRACT No 1002

.\Coffey Logo.JPG **enpure**

Enpure Limited  
 Enpure House,  
 Birmingham Road,  
 Kibblesworth, DY10 2SH,  
 Tel: +44 (0)1562 820 010  
 Fax: +44 (0)1562 820 008  
 Internet: www.enpure.co.uk



All Copyright and Design Right subsisting in this document is the property of Enpure Limited of Enpure without Enpure's written consent. This document and the information contained within it is confidential to Enpure Limited and may not be disclosed to any third party without Enpure's written consent.

Customer: WATERFORD CITY COUNCIL  
 Title: BOILER ROOM COMBINED UNDERGROUND PIPEWORK  
 GENERAL ARRANGEMENT  
 WATERFORD WWTW

Date	By	Checked	Approved	Checked	Scale
31/08/2007	DDF	DDF	JMN	DDF	A1
04/09/2007	DDF	DDF	JMN	DDF	A1
04/09/2007	DDF	DDF	JMN	DDF	A1

Dwg. No. C1197-2031

Rev. A