



CLARE COUNTY COUNCIL  
COMHAIRLE CONTAE AN CHLÁIR

Shannon Environmental Services.  
Smithstown Industrial Estate,  
Shannon.  
Co. Clare.

07 DEC 2005

**Re: Discharge limits to Clare County Council sewer for the year 2006.**

2<sup>nd</sup> December 2005

David Burke,

Further to your letter of 29<sup>th</sup> November 2005, Clare County Council is in a position to allow Shannon Environmental Services discharge 250m<sup>3</sup> per day (max 20m<sup>3</sup>/hr) for the year January to December 2006. Also, the existing ELV's (as attached to your letter) can be taken as being the discharge limits for the year 2006.

There is one exception to this. It is requested that FOG be maintained at a limit of 50mg/L or less if possible. This request is to limit the possibility of blockages in the County Council sewer network. All Section 16 licenses will have this limit or less and as IPC's are being reviewed, Clare County Council are and will be requesting the Agency to impose limits of 50mg/L or less FOG.

Regards.

Cathal Brodie  
Assistant Scientist.

Environment Section  
Block B  
I.A.P.E.  
Gort Road  
Ennis  
Co. Clare

Roinn Comhshaoil  
Block B  
Pairc Aois Eolais na hInse  
Bóthar Ghoirt  
Inis  
Contae an Chláir

T: +353 65 682 1616  
F: +353 65 684 6444  
E: [enviroff@clarecoco.ie](mailto:enviroff@clarecoco.ie)  
W: <http://clarecoco.clare.ie>



Caring for  
  
Clare's Environment

100% Recycled Paper