



**Cathal Brodie,  
Environment Division,  
Clare County Council,  
IAPE,  
Gort Road,  
Ennis,  
Co. Clare.**

**9<sup>th</sup> January 2008**

Dear Mr. Brodie,

I wish to request an extension of our existing arrangements with respect to discharges to the waste water treatment facility operated by Clare County Council at the site in Tradaree.

The ELVs as agreed previously are outlined on the following page. We are seeking to retain these ELVs until such time as the Tradaree facility undergoes the anticipated upgrade and is fully operational.

I trust this is satisfactory and look forward to receiving your confirmation that the above is acceptable to Clare County Council. If you have any queries in relation to this matter please do not hesitate to contact me.

Yours sincerely,

David Burke,  
HSE & Compliance Manager.

Clonminam Industrial Estate,  
Portlaoise, Co. Laois  
Tel: 057 8678600  
Fax: 057 8678699  
Callsave 1850 504 504  
Email: portlaoise@enva.ie

Smithstown Industrial Estate,  
Shannon,  
Co. Clare  
Tel: 061 707400  
Fax: 061 707401  
Email: shannon@enva.ie

Raffeen Industrial Estate,  
Ringaskiddy, Co. Cork  
Tel: 021 4387200  
Fax: 021 4387299  
Email: cork@enva.ie

JFK Road, Naas Road,  
Dublin 12  
Tel: 01 4508111  
Fax: 01 4568197  
Email: dublin@enva.ie

www.enva.ie

**EXISTING ELVs FOR DISCHARGE FROM ENVA TO TRADAREE WASTE  
WATER TREATMENT PLANT**

Parameter	Units	Existing ELV
COD	mg/l	3,000
BOD	mg/l	2,000
Suspended Solids	mg/l	400
Sulphides (as S)	mg/l	10
Sulphates (as SO <sub>4</sub> )	mg/l	1,500
Detergents	mg/l	80
Phosphorous (as P)	mg/l	50
Phenols	mg/l	3
Ammonia (Total)	mg/l	250
Nitrates	mg/l	100
Silver	mg/l	2
Aluminium	mg/l	10
Cadmium	mg/l	0.5
Cobalt	mg/l	10
Chromium (III)	mg/l	10
Chromium (VI)	mg/l	0.05
Copper	mg/l	10
Mercury	mg/l	0.05
Iron	mg/l	20
Nickel	mg/l	20
Lead	mg/l	0.5
Tin	mg/l	2.0
Zinc	mg/l	20
Arsenic	mg/l	1
Cyanide	mg/l	0.5
Chlorides	mg/l	3,000
Fluoride	mg/l	10
Organohalogens	mg/l	0.15
pH		6-10
Temperature	°C	43°C
Colour	mg/l	200 mg/l Pt/Co
Fats, Oils and Grease	mg/l	50
Daily Flow Rate	m <sup>3</sup> /day	250