



Environmental Protection Agency
An Ghníomhaireacht um Chaomhnú Comhshaoil

Mr. Mark Johnston
Monaghan County Council
County Offices
The Glen
Monaghan

Regional Inspectorate
McCumiskey House, Richview,
Clonskeagh Road, Dublin 14, Ireland
Cigireacht Réigiúnach, Teach Mhic Chumascaigh
Dea-Radharc, Bóthar Cluain Sceach
Baile Átha Cliath 14, Éire
T: +353 1 268 0100
F: +353 1 268 0199
E: info@epa.ie
W: www.epa.ie
LoCall: 1890 33 55 99

15th April 2009

D0062-01

re. Notice in accordance with Regulation 20(1)(a) of the Waste Water Discharge (Authorisation) Regulations 2007

Dear Mr. Johnston,

I am to refer to the above referenced application for a waste water discharge licence relating to the Carrickmacross agglomeration. Having examined the documentation submitted, application received on the 14 January 2008 and further information received on the 11 December 2008, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007.

You are therefore requested, in accordance with Regulation 20(1)(a) of the regulations, to take the following steps to supply the information detailed below:

ARTICLE 16 COMPLIANCE REQUIREMENTS


1. Provide an update in relation to your proposals to upgrade the waste water treatment plant (WWTP) in Carrickmacross, please include details in relation to the current loading (domestic sanitary effluent, industrial etc.), current treatment capacity and proposed treatment capacity;
2. Provide updated discharge parameters, if there is any changes to the WWTP as proposed in the original licence application received on the 14th January 2008;
3. Revise the assimilative capacity calculations, as appropriate, to reflect any changes in the discharge parameters;
4. Re-confirm the dates by which the proposed WWTP shall be operational and the effluent discharge pipeline shall be installed and confirm the funding for such development works; and
5. Update the licence application to reflect any changes since submission of the licence application.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information in the form of one original plus one copy within **1 month**, of the date of this notice, as specified under Regulation 20(1). In addition, please submit one copy of the requested information in electronic searchable PDF format on a CD-ROM to the Agency. Please note that all maps/drawings should not exceed A3 in size.

Please note that the application's register number is **D0062-01**. Please direct all correspondence in relation to this matter to *Administration, Environmental Licensing Programme, Office of Climate, Licensing & Resource Use, Environmental Protection Agency, PO Box 3000, Johnstown Castle Estate, County Wexford*, quoting the register number.

Yours sincerely,



Patrick Byrne

Inspector

Office of Climate, Licensing & Resource Use