

Comhairle Contae Chorcaí Cork County Council

Annabella,
Mallow,
Co. Cork.
Tel: (022) 21123 • Fax: (022)21983
Email: northcork@corkcoco.ie
Web: www.corkcoco.ie
Annabella,
Mala,
Co. Chorcaí.



Environmental Protection Agency,
Office of Climate change and resource Unit,
Licensing Unit,
P.O. Box 3000,
Johnstown Castle Estate,
Co. Wexford.

Fón: (022) 21123 • Faics: (022) 21983
R-phost: northcork@corkcoco.ie
Suíomh Gréasáin: www.corkcoco.ie

June 2009

Re: Waste Water Discharge Licence Application for the Agglomeration of Glanworth

Dear Sir / Madam,

Please find enclosed Cork County Council's Waste Water Discharge Licence Application for the agglomeration of Glanworth.

The following documentation is enclosed.

- 1 Nr. signed original in hardcopy
- 1 Nr. copy in hardcopy
- 2 Nr. CD-ROM with all documentation in electronic searchable PDF
- 1 Nr. CD-ROM with AutoCAD, Excel Data, Table D.2, Table E.3 and F.2

The content of the electronic files is a true copy of the original hardcopy.

Payment of €10,000 Licence Fee is by Electronic means.

Signed:

Frank Cronin
Senior Engineer – Water Services



This is a draft document and is subject to revision.



Waste Water Discharge Licence Application Form

*For inspection purposes only
Consent of copyright owner required for any other use.*

EPA Ref. N^o: <i>(Office use only)</i>	<input type="text"/>
--	----------------------

Environmental Protection Agency
PO Box 3000, Johnstown Castle Estate, Co. Wexford
Lo Call: 1890 335599 Telephone: 053-9160600 Fax: 053-9160699
Web: www.epa.ie Email: info@epa.ie

Tracking Amendments to Draft Application Form

Version No.	Date	Amendment since previous version	Reason
V. 1.	11/10/07	N/A	
V. 2.	18/10/07	Inclusion of a Note 1 superscript for Orthophosphate in Tables D.1(i)(b) & D.1(ii)(b).	To highlight the requirement for filtered samples in measurement of O-Phosphate for waste water discharges.
V.3.	13/11/07	Amend wording of Section F.2 to include 'abstraction'. Amend wording of Checklist in Annex to reflect wording of Regulation 16(5) of S.I. No. 684 of 2007. Inclusion of unique point code for each point of discharge and storm water overflow.	To accurately reflect the information required To accurately reflect the Regulations and to obtain the application documentation in appropriate format. To aid in cross-referencing of application documentation.
V.4	18/04/08	Inclusion of requirement to provide name of agglomeration to which the application relates. Amend wording of Section B.7. (iii) to reflect the title of Water Services Authority. Addition of new Section B.9 (ii) in order to obtain information on developments yet to contribute to the waste water works. Addition of sub-sections C.1.1 & C.1.2 in order to clarify information required for Storm water overflow and pumping stations within the works. Amend Section D.1 to include a requirement for monitoring data for influent	To accurately determine the agglomeration to be licensed. To accurately reflect the Water Services Act, 2007. To obtain accurate population equivalent figures for the agglomeration. To obtain accurate information on design and spill frequency from these structures. To acquire information on the population loading onto the plant and to provide information on performance rates within



Waste Water Discharge Authorisation Application Form

		to waste water treatment plants, where available. Amend wording of Section E.1 to request information on composite sampling/flow monitoring provisions.	the plant. To acquire accurate information on the sampling and monitoring provisions for discharges from the works.
V.5	07/07/2008	Amend wording of B.7 (iii) to include reference to Water Services Authorities. Amend Section G.1 to include Shellfish Waters Directive.	To accurately reflect the Water Services Act, 2007 requirements.
V.6	26/08/2007	Amendments to Section D to reflect new web based reporting. Amended requirements for reporting on discharges under E.1 Waste Water Discharge Frequency and Quantities. Amendment to Section F.1 to specify the type of monitoring and reporting required for the background environment. Removal of Annexes to application form.	To clarify the reporting requirements. To streamline reporting requirements. To clarify the reporting requirements for ambient monitoring. To reflect the new web based reporting requirements.

For inspection purposes only. Consent of copyright owner required for any other use.



Environmental Protection Agency
Application for a Waste Water Discharge Licence
Waste Water Discharge (Authorisation) Regulations 2007.

CONTENTS

	Page
ABOUT THIS APPLICATION FORM	4
PROCEDURES	6
SECTION A NON-TECHNICAL SUMMARY	8
SECTION B GENERAL	9
SECTION C INFRASTRUCTURE & OPERATION	20
SECTION D DISCHARGES TO THE AQUATIC ENVIRONMENT	22
SECTION E MONITORING	20
SECTION F EXISTING ENVIRONMENT & IMPACT OF THE DISCHARGE(S)	26
SECTION G PROGRAMME OF IMPROVEMENTS	25
SECTION H DECLARATION	27
SECTION I JOINT DECLARATION	28
 ANNEX 1: TABLES/ATTACHMENTS	
 ANNEX 2: CHECKLIST	

ABOUT THIS APPLICATION FORM

This form is for the purpose of making an application for a Waste Water Discharge Licence under the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. No. 684 of 2007) or for the review of an existing Waste Water Discharge licence.

The Application Form **must** be completed in accordance with the instructions and guidance provided in the *Waste Water Discharge Licensing Application Guidance Note*. The Guidance Note gives an overview of Waste Water Licensing, outlines the licence application process (including the number of copies required) and specifies the information to be submitted as part of the application. The Guidance Note and application form are available to download from the Licensing page of the EPA's website at www.epa.ie.

A valid application for a Waste Water Discharge Licence must contain the information prescribed in the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. No. 684 of 2007). Regulation 16 of the Regulations sets out the statutory requirements for information to accompany a licence application. The application form is designed in such a way as to set out these questions in a structured manner and not necessarily in the order presented in the Regulations. In order to ensure a legally valid application in respect of Regulation 16 requirements, please complete the Regulation 16 Checklist provided in Annex 2.

This Application Form does not purport to be and should not be considered a legal interpretation of the provisions and requirements of the Waste Water Discharge (Authorisation) Regulations, 2007. While every effort has been made to ensure the accuracy of the material contained in the Application Form, the EPA assumes no responsibility and gives no guarantee, or warranty concerning the accuracy, completeness or up-to-date nature of the information provided herein and does not accept any liability whatsoever arising from any errors or omissions.

Should there be any contradiction between the information requirements set out in the Application Form and any clarifying explanation contained in the accompanying Guidance Note, then the requirements in this Application Form shall take precedence.

PROCEDURES

The procedure for making and processing of applications for waste water discharge licences, and for the processing of reviews of such licences, appear in the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. No. 684 of 2007) and is summarised below. The application fees that shall accompany an application are listed in the Third Schedule to the Regulations.

Prior to submitting an application the applicant must publish in a newspaper circulating in the area, and erect at the point nearest to the waste water treatment plant concerned or, if no such plant exists, at a location nearest the primary discharge point, a notice of intention to apply. An applicant, not being the local authority in whose functional area the relevant waste water discharge, or discharges, to which the relevant application relates, takes place or is to take place, must also notify the relevant Local Authority, in writing, of their intention to apply.

An application for a licence must be submitted on the appropriate form (available from the Agency) with the correct fee, and should contain relevant supporting documentation as attachments. The application should be based on responses to the form and include supporting written text and the appropriate use of tables and drawings. Where point source emissions occur, a system of unique reference numbers should be used to denote each discharge point. These should be simple, logical, and traceable throughout the application.

The application form is divided into a number of sections of related information. The purpose of these divisions is to facilitate both the applicant and the Agency in the provision of the information and its assessment. **Please adhere to the format as set out in the application form and clearly number each section and associated attachment, if applicable, accordingly.** Attachments should be clearly numbered, titled and paginated and must contain the required information as set out in the application form. Additional attachments may be included to supply any further information supporting the application. Any references made should be supported by a bibliography.

All questions should be answered. Where information is requested in the application form, which is not relevant to the particular application, the words "not applicable" should be clearly written on the form. The abbreviation "N/A" should not be used.

Additional information may need to be submitted beyond that which is explicitly requested on this form. Any references made should be supported by a bibliography. The Agency may request further information if it considers that its provision is material to the assessment of the application. Advice should be sought from the Agency where there is doubt about the type of information required or the level of detail.

Information supplied in this application, including supporting documentation will be put on public display and be open to inspection by any person.

Applicants should be aware that a contravention of the conditions of a waste water discharge licence is an offence under the Waste Water Discharge (Authorisation) Regulations, 2007.

The provision of information in an application for a waste water discharge licence which is false or misleading is an offence under Regulation 35 of the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. No. 684 of 2007).

Note: Drawings. The following guidelines are included to assist applicants:

- *All drawings submitted should be titled and dated.*
- *All drawings should have a unique reference number and should be signed by a clearly identifiable person.*
- *All drawings should indicate a scale and the direction of north.*
- *All drawings should, generally, be to a scale of between 1:20 to 1:500, depending upon the degree of detail needed to be shown and the size of the facility. Drawings delineating the boundary can be to a smaller scale of between 1:1000 to 1:10560, but must clearly and accurately present the required level of detail. Drawings showing the waste water treatment plant location, if such a plant exists, can be to a scale of between 1:50 000 to 1:126 720. All drawings should, however, be A3 or less and of an appropriate scale such that they are clearly legible. Provide legends on all drawings and maps as appropriate.*
- *In exceptional circumstances, where A3 is considered inadequate, a larger size may be requested by the Agency.*

It should be noted that it will not be possible to process or determine the application until the required documents have been provided in sufficient detail and to a satisfactory standard.

*For inspection purposes only.
Consent of copyright owner required for any other use.*

For inspection purposes only.
Consent of copyright owner required for any other use.

SECTION A: NON-TECHNICAL SUMMARY

Advice on completing this section is provided in the accompanying Guidance Note.

A non-technical summary of the application is to be included here. The summary should identify all environmental impacts of significance associated with the discharge of waste water associated with the waste water works. This description should also indicate the hours during which the waste water works is supervised or manned and days per week of this supervision.

The following information must be included in the non-technical summary:

A description of:

- the waste water works and the activities carried out therein,
- the sources of emissions from the waste water works,
- the nature and quantities of foreseeable emissions from the waste water works into the receiving aqueous environment as well as identification of significant effects of the emissions on the environment,
- the proposed technology and other techniques for preventing or, where this is not possible, reducing emissions from the waste water works,
- further measures planned to comply with the general principle of the basic obligations of the operator, i.e., that no significant pollution is caused;
- measures planned to monitor emissions into the environment.

Supporting information should form **Attachment N^o A.1**

For inspection purposes only
Consent of copyright owner required for any other use

SECTION A: NON-TECHNICAL SUMMARY

Glanworth is situated 10km north-west of Fermoy and 56Km north-west of Cork City, in the Blackwater valley. The village is well developed from the point of public services such as a primary school, shops and amenities.

The waste water from the Glanworth allglomeration is currently treated by a package treatment plant prior to been discharged to the River Funshion.

The Waste Water Works and the Activities Carried Out Therein

Glanworth wastewater treatment plant (WWTP) was constructed in 2001. The compound is located adjacent to the River Funshion and the Glanworth Bridge.

The main elements of the WWTP are;

1. Preliminary Treatment: Grit Trap and Automatic Screen
2. Secondary treatment: Biofilm process, 'all in one' treatment plant.
3. Discharge to River Funshion

The wastewater in Glanworth is collected in a partially combined foul and sewer drainage network and gravitates to the wastewater treatment plant.

In a high storm water event, the inlet works surcharge and the excess waste stream is diverted to a storm water holding tank where it is stored until the storm surge has abated.

Glanworth WWTP is operated by the staff of Cork County Council whose duties also involve the maintenance of a number of other small WWTP's in the area. The caretaker is on duty from 8.00am to 5.30pm Monday – Saturday.

The sources of emissions from the waste water works

The pollution load from the Glanworth agglomeration arises from the following areas:

- Domestic population
- Commercial premises
- School & crèches
- Infiltration

The sewerage from all commercial premises is collected via the public sewer and treated in conjunction with the domestic waste at the WWTP. There are no industrial waste streams discharging into the sewerage network.

The main source of emissions from the works is via a 300mm open pipe outfall to the River Funshion. The River Funshion flows along the western boundary of the Compound.

The storm water holding tank is fitted with a screened overflow discharge to the River Funshion which may come into use during prolonged storm water events. In the case of a power outage, the forward feed pump sump within the compound will contain incoming sewage. In the event of prolonged outage, the

forward feeding sump is fitted with an emergency overflow discharge to the River Funshion.

The nature and quantities of foreseeable emissions from the waste water works into the receiving aqueous environment as well as identification of significant effects of the emissions on the environment

The wastewater treatment plant treats only municipal waste water from Village and it environs via the sewerage collection system which is discharged to the River Funshion. The normal DWF from the WWTP is of the magnitude of 80-100m³/day (flow meter). The plant has exceeded the requirements of the Urban Waste Water Directive on a number of occasions.

During power black outs, the waste stream will back up the pump sump and will overflow in the pre-existing septic tank which will discharge directly to the effluent stream prior to the discharge point. There is no flow data for the discharge from this tank.

The proposed technology and other techniques for preventing or, where this is not possible, reducing emissions from the waste water works

The treatment works consists of the following elements:

- Automatic 6mm screen with manual screen bypass. Screenings are macerated and dewatered and stored in a wheelie bin for suitable disposal off-site.
- Two BL4000 Blivet Units. 'All in one' treatment plant which contains the following;
 - Primary settlement.
 - Aerobic treatment, combined fixed film reactor and active aeration system.
 - Final settlement.
 - Sludge storage.
- Surface water holding tank with duty/standby forward feed pumps and screened emergency overflow baffle.

The treatment plant does not have a backup power generation system.

The WWTP shall be operated and managed in accordance with the Performance Management System, developed by the Water Service National Training Group (WSMTG).

Further measures planned to comply with the general principle of the basic obligations of the operator, i.e., that no significant pollution is caused

Negotiations have been undertaken with an aim to secure lands adjacent to the existing compound to facilitate expansion of the existing treatment plant. However, there is no funding secured to proceed with the expansion.

Measures planned to monitor emissions into the environment

The Cork County Council Environmental Laboratory carries out sampling of the influent and effluent biannually. Sampling, Monitoring and analysis of the wastewater sludge is also undertaken by the Environmental Laboratory.

The Cork County Council Environmental Department located in Mallow takes samples from the River Funchion upstream and downstream of the wastewater treatment plant approximately 2 times per year. Samples of the influent and effluent are also taken at these times.

The wastewater treatment plant is equipped with an automatic sampler on the effluent stream.

The EU Water Framework Directive Monitoring Programme is to be fully operational by the year 2012. This monitoring programme was prepared by the EPA to meet the requirements of the EU Water Framework Directive (2000/60/EC) and National Regulations implementing the Water Framework Directive (S.I. No. 722 of 2003) and National Regulations implementing the Nitrates Directive (S.I. No. 788 of 2005).

For inspection purposes only.
Consent of copyright owner required for any other use.

SECTION B: GENERAL

Advice on completing this section is provided in the accompanying Guidance Note.

B.1 Agglomeration Details

Name of Agglomeration: Glanworth & Environs

Applicant's Details

Name and Address for Correspondence

Only application documentation submitted by the applicant and by the nominated person will be deemed to have come from the applicant.

Provide a drawing detailing the agglomeration to which the licence application relates. It should have the boundary of the agglomeration to which the licence application relates clearly marked in red ink.

Name*:	Cork County Council
Address:	Northern Division
	Annabella
	Mallow
	Co. Cork
Tel:	022 21123
Fax:	022 21983
e-mail:	Frank.cronin@corkcoco.ie

*This should be the name of the water services authority in whose ownership or control the waste water works is vested.

*Where an application is being submitted on behalf of more than one water services authority the details provided in Section B.1 shall be that of the lead water services authority.

Name*:	Frank Cronin
Address:	Northern Division
	Annabella
	Mallow
	Co. Cork
Tel:	022 21123
Fax:	022 21983
e-mail:	Frank.cronin@corkcoco.ie

*This should be the name of person nominated by the water services authority for the purposes of the application.

Co-Applicant's Details

Name*:	Not Applicable
Address:	Not Applicable
Tel:	Not Applicable
Fax:	Not Applicable
e-mail:	Not Applicable

*This should be the name of a water services authority, other than the lead authority, where multiple authorities are the subject of a waste water discharge (authorisation) licence application.

Design, Build & Operate Contractor Details

Name*:	Not Applicable
Address:	Not Applicable
Tel:	Not Applicable
Fax:	Not Applicable
e-mail:	Not Applicable

*Where a design, build & operate contract is in place for the waste water works, or any part thereof, the details of the contractor should be provided.

Attachment B.1 should contain appropriately scaled drawings / maps ($\leq A3$) of the agglomeration served by the waste water works showing the boundary clearly marked in red ink. These drawings / maps should also be provided as geo-referenced digital drawing files (e.g., ESRI Shapefile, MapInfo Tab, AutoCAD or other upon agreement) in Irish National Grid Projection. These drawings should be provided to the Agency on a separate CD-Rom containing sections B.2, B.3, B.4, B.5, C.1, D.2, E.3 and F.2.

Attachment included	Yes	No
	√	

B.2 Location of Associated Waste Water Treatment Plant(s)

Give the location of the waste water treatment plant associated with the waste water works, if such a plant or plants exists.

Name*:	Brendan O Gorman
Address:	Cork County Council
	Annabella
	Mallow
	Co. Cork
Grid ref (6E, 6N)	175812E 103927N
Level of Treatment	Secondary
Primary Telephone:	025-24944
Fax:	025-84072
e-mail:	Brendan.ogorman@corkcoco.ie

*This should be the name of the person responsible for the supervision of the waste water treatment plant.

Attachment B.2 should contain appropriately scaled drawings / maps ($\leq A3$) of the site boundary and overall site plan, including labelled discharge, monitoring and sampling points. These drawings / maps should also be provided as geo-referenced digital drawing files (e.g., ESRI Shapefile, MapInfo Tab, AutoCAD or other upon agreement) in Irish National Grid Projection. These drawings should be provided to the Agency on a separate CD-Rom containing sections B.1, B.3, B.4, B.5, C.1, D.2, E.3 and F.2.

Attachment included	Yes	No
	√	

B.3 Location of Primary Discharge Point

Give the location of the primary discharge point, as defined in the Waste Water Discharge (Authorisation) Regulation, associated with the waste water works.

Type of Discharge	Point Discharge 300mm diameter open pipe outfall.
Unique Point Code	SW01-GLAN
Location	River Funchion, close to Glanworth Bridge
Grid ref (6E, 6N)	175870E, 103919N

Attachment B.3 should contain appropriately scaled drawings / maps ($\leq A3$) of the discharge point, including labelled monitoring and sampling points associated with the discharge point. These drawings / maps should also be provided as geo-referenced digital drawing files (e.g. ESRI Shapefile, MapInfo Tab, AutoCAD or other upon agreement) in Irish National Grid Projection. This data should be provided to the Agency on a separate CD-Rom containing the drawings and tabular data requested in sections B.1, B.2, B.4, B.5, C.1, D.2, E.3 and F.2.

Attachment included	Yes	No
	√	

B.4 Location of Secondary Discharge Point(s)

Give the location of **all** secondary discharge point(s) associated with the waste water works. Please refer to Guidance Note for information on Secondary discharge points.

Type of Discharge	Not Applicable
Unique Point Code	Not Applicable
Location	Not Applicable
Grid ref (6E, 6N)	Not Applicable

Attachment B.4 should contain appropriately scaled drawings / maps ($\leq A3$) of the discharge point(s), including labelled monitoring and sampling points associated with the discharge point(s). These drawings / maps should also be provided as geo-referenced digital drawing files (e.g. ESRI Shapefile, MapInfo Tab, AutoCAD or other upon agreement) in Irish National Grid Projection. This data should be provided to the Agency on a separate CD-Rom containing sections B.1, B.2, B.3, B.5, C.1, D.2, E.3 and F.2.

Attachment included	Yes	No
		√

B.5 Location of Storm Water Overflow Point(s)

Give the location of **all** storm water overflow point(s) associated with the waste water works.

Type of Discharge	Point discharge -100mm diameter outfall pipe from storm holding tank. Outlet pipe fitted with Flap valve.
Unique Point Code	SW02-GLAN
Location	River Funchion, close to Glanworth Bridge
Grid ref (6E, 6N)	175868E, 103920N

Attachment B.5 should contain appropriately scaled drawings / maps ($\leq A3$) of storm water overflow point(s) associated with the waste water works, including labelled monitoring and sampling points associated with the discharge point(s). These drawings / maps should also be provided as geo-referenced digital drawing files (e.g. ESRI Shapefile, MapInfo Tab, AutoCAD or other upon agreement) in Irish National Grid Projection. This data should be provided to the Agency on a separate CD-Rom containing sections B.1, B.2, B.3, B.4, C.1, D.2, E.3 and F.2.

Attachment included	Yes	No
		√

B.6 Planning Authority

Give the name of the planning authority, or authorities, in whose functional area the discharge or discharges take place or are proposed to take place.

Name:	Cork County Council
Address:	Planning Department
	County Hall
	Carriagrohane Road
	Cork
Tel:	021 4276891
Fax:	021 4867007
e-mail:	Planninginfo@corkcoc.ie

Planning Permission relating to the waste water works which is the subject of this application:- (tick as appropriate)

has been obtained	√	is being processed	
is not yet applied for		is not required	

Local Authority Planning File Reference N^o:	Not Available
---	---------------

Attachment B.6 should contain **the most recent** planning permission, including a copy of **all** conditions, and where an EIS was required, copies of any such EIS and any certification associated with the EIS, should also be enclosed.

Where planning permission is not required for the development, provide reasons, relevant correspondence, etc.

Attachment included	Yes	No
		√

B.7 Other Authorities

B.7 (i) Shannon Free Airport Development Company (SFADCo.) area

The applicant should tick the appropriate box below to identify whether the discharge or discharges are located within the Shannon Free Airport Development Company (SFADCo.) area.

Attachment B.7(i) should contain details of any or all discharges located within the SFADCo. area.

Within the SFADCo Area	Yes	No
		√

B.7 (ii) Health Services Executive Region

The applicant should indicate the **Health Services Executive Region** where the discharge or discharges are or will be located.

Name:	Health Service Executive
Address:	North Cork Area Headquarters
	Gouldhill
	Mallow, Co. Cork
Tel:	022 30200
Fax:	022 30211
e-mail:	Gerry.oconnell@hse.ie

B.7 (iii) Other Relevant Water Services Authorities

Regulation 13 of the Waste Water Discharge (Authorisation) Regulations, 2007 requires all applicants, not being the water services authority in whose functional area the relevant waste water discharge or discharges, to which the relevant application relates, takes place or is to take place, to notify the relevant water services authority of the said application.

Name:	Not Applicable
Address:	Not Applicable
Tel:	Not Applicable
Fax:	Not Applicable
e-mail:	Not Applicable

Relevant Authority Notified	Yes	No
		√

Attachment B.7(iii) should contain a copy of the notice issued to the relevant local authority.

Attachment included	Yes	No
		√

B.8 Notices and Advertisements

Regulations 10 and 11 of the Waste Water Discharge (Authorisation) Regulations, 2007 require all applicants to advertise the application in a newspaper and by way of a site notice. See *Guidance Note*.

Attachment B.8 should contain a copy of the site notice and an appropriately scaled drawing (≤A3) showing its location. **The original application must include the original page of the newspaper in which the advertisement was placed.** The relevant page of the newspaper containing the advertisement should be included with the original and two copies of the application.

Attachment included	Yes	No
	√	

B.9 (i) Population Equivalent of Agglomeration

TABLE B.9.1 POPULATION EQUIVALENT OF AGGLOMERATION

The population equivalent (p.e.) of the agglomeration to be, or being, served by the waste water works should be provided and the period in which the population equivalent data was compiled should be indicated.

Population Equivalent	607 346 (yet to be built) 953
Data Compiled (Year)	2008/2009
Method	Building count & review of planning applications granted.

B.9 (ii) Pending Development

Where planning permission has been granted for development(s), but development has not been commenced or completed to date, within the boundary of the agglomeration and this development is being, or is to be, served by the waste water works provide the following information;

- information on the calculated population equivalent (p.e.) to be contributed to the waste water works as a result of those planning permissions granted,

Description	No. of Units	PE/unit	PE
Planning granted, not contributing - Domestic	120	2.8	336
Planning granted,	2	5	10

not contributing - Commercial			
Restricted due to WWTP Upgrade	82	2.8	230
		Total	576

- the percentage of the projected p.e. to be contributed by the non-domestic activities, and

$$\frac{10}{576} * 100 = 1.8\%$$
- the ability of the waste water works to accommodate this extra hydraulic and organic loading without posing an environmental risk to the receiving water habitat.

The treatment plant requires expansion to adequately cater for the projected PE. As noted, planning has been restricted on 82 sites due to limitations of existing sewage treatment infrastructure.

B.9 (iii) FEES

State the relevant Class of waste water discharge as per Column 1 of the Second Schedule, and the appropriate fee as per Columns 2 or 3 of the Third Schedule of the Waste Water Discharges (Authorisation) Regulations 2007, S.I. No. 684 of 2007.

Class of waste water discharge	Fee (in €)
Discharges from agglomerations with a population equivalent of 500-1,000	€10000

Appropriate Fee Included	Yes	No
	√	

B.10 Capital Investment Programme

State whether a programme of works has been prioritised for the development of infrastructure to appropriately collect, convey, treat and discharge waste water from the relevant agglomeration. If a programme of works has been prioritised provide details on funding, (local or national), allocated to the capital project. Provide details on the extent and type of work to be undertaken and the likely timeframes for this work to be completed.

Attachment B.10 should contain the most recent development programme, including a copy of any approved funding for the project and a timeframe for the completion of the necessary works to take place.

Works in relation to Glanworth WWTP or sewerage scheme has not been included in the most recent national Water Services Investment Programme (2007-2009).

Attachment included	Yes	No
	√	

B.11 Significant Correspondence

Provide a summary of any correspondence resulting from a Section 63 notice issued by the Agency in relation to the waste water works under the Environmental Protection Agency Acts, 1992 and 2003, as amended by Section 13 of Protection of the Environment Act, 2003.

Cork County Council has not registered any Section 63 notices from the Environmental Protection Agency in relation to these waste water works.

Attachment B.11 should contain a summary of any relevant correspondence issued in relation to a Section 63 notice.

Attachment included	Yes	No
		√

B.12 Foreshore Act Licences.

Provide a copy of the most recent Foreshore Act licence issued in relation to discharges from the waste water works issued under the Foreshore Act 1933.

Not Applicable

Attachment B.12 should contain the most recent licence issued under the Foreshore Act 1933, including a copy of **all** conditions attached to the licence and any monitoring returns for the previous 12-month period, if applicable.

Attachment included	Yes	No
		√

For inspection purposes only.
Consent of copyright owner required for any other use.

SECTION C: INFRASTRUCTURE & OPERATION

Advice on completing this section is provided in the accompanying Guidance Note.

C.1 Operational Information Requirements

Provide a description of the plant, process and design capacity for the areas of the waste water works where discharges occur, to include a copy of such plans, drawings or maps, (site plans and location maps, process flow diagrams), and such other particulars, reports and supporting documentation as are necessary to describe all aspects of the area of the waste water works discharging to the aquatic environment. Maps and drawings must be no larger than A3 size.

C.1.1 Storm Water Overflows

For each storm water overflow within the waste water works the following information shall be submitted:

- An assessment to determine compliance with the criteria for storm water overflows, as set out in the DoEHLG '*Procedures and Criteria in Relation to Storm Water Overflows*', 1995 and any other guidance as may be specified by the Agency, and
- Identify whether any of the storm water overflows are to be decommissioned, and identify a date by which these overflows will cease, if applicable.

Criteria for assessment of existing Storm water tank

- 1) *Causes a significant visual or aesthetic impact and public complaints*
Not deemed to have any significant visual or aesthetic impact.
No Public complaints logged in with Cork County Council
- 2) *Causes deterioration in water quality in receiving waters*
- 3) *Gives rise to failure in meeting the requirements of national regulations on foot of EU Directives.*
- 4) *Operates in Dry Weather.*

There is no information on frequencies/ quantities of discharges from the storm water holding tank to the river. There are no recorded complaints in relation to the storm water holding tank. Visual inspections of the emergency discharge point would indicate that it does discharge during DWFs to WWTP.

C.1.2 Pumping Stations

For each pump station operating within the waste water works, provide details of the following:

- Number of duty and standby pumps at each pump station;
- The measures taken in the event of power failure;
- Details of storage capacity at each pump station;

- Frequency and duration of activation of emergency overflow to receiving waters. Clarify the location where such discharges enter the receiving waters.

Not applicable, there are not pumping stations within the network.

Attachment C.1 should contain supporting documentation with regard to the plant and process capacity, systems, storm water overflows, emergency overflows, etc., including flow diagrams of each with any relevant additional information. These drawings / maps should also be provided as geo-referenced digital drawing files (e.g. ESRI Shapefile, MapInfo Tab, AutoCAD or other upon agreement) in Irish National Grid Projection. This data should be provided to the Agency on a separate CD-Rom containing sections B.1, B.2, B.3, B.4, B.5, D.2, E.3 and F.2.

Attachment included	Yes	No
	√	

C.2 Outfall Design and Construction

Provide details on the primary discharge point & secondary discharge points and storm overflows to include reference, location, design criteria and construction detail.

The main discharge point, SW01-GLAN, is the main outlet from Glanworth WWTP. The outfall is located east of the WWTP compound and discharges directly to the River Funshion, circa 10 m from the compound boundary. The point of discharge is an open pipe above the water level of the river. Some stone debris is in place as an anti-scouring measure. There is no headwall construction in place.

Emergency storm water overflow, SW02-GLAN, discharges at point adjacent to the main discharge point. The outlet is fitted with a flap valve and the above the water level of the river. There is no headwall construction in place.

Attachment C.2 should contain any supporting documentation on the design and construction of any and all discharge outfalls, including stormwater overflows, from the waste water works.

Attachment included	Yes	No
		√

SECTION D: DISCHARGES TO THE AQUATIC ENVIRONMENT

Advice on completing this section is provided in the accompanying Guidance Note.

Give particulars of the source, location, nature, composition, quantity, level and rate of discharges arising from the agglomeration and, where relevant, the period or periods during which such emissions are made or are to be made.

Details of all discharges of waste water from the agglomeration should be submitted via the following web based link: http://78.137.160.73/epa_wwd_licensing/. The applicant should address in particular all discharge points where the substances outlined in Tables D.1(i), (b) & (c) and D.1(ii), (b) & (c) of Annex 1 are emitted.

Where it is considered that any of the substances listed in Annex X of the Water Framework Directive (2000/60/EC) or any of the Relevant Pollutants listed in Annex VIII of the Water Framework Directive (2000/60/EC) are being discharged from the waste water works or are seen to be present in the receiving water environment downstream of a discharge from the works (as a result of any monitoring programme, e.g., under the Water Framework Directive Programme of Measures) the applicant shall screen the discharge for the relevant substance.

D.1 Discharges to Surface Waters

Details of all discharges of waste water from the agglomeration should be supplied via the following web based link: http://78.137.160.73/epa_wwd_licensing/. Tables D.1(i)(a), (b) & (c), should be completed for the primary discharge point from the agglomeration and Tables D.1(ii)(a), (b) & (c) should be completed for each secondary discharge point, where relevant. Table D.1(iii)(a) should be completed for each storm water overflow. Individual Tables must be completed for each discharge point.

Where monitoring information is available for the influent to the plant this data should also be provided in response to Section D.1. Cork County Council monitors the influent to the plant, the results of which are included in Attachment D.

Supporting information should form **Attachment D.1**

Attachment included	Yes	No
	√	

D.2 Tabular Data on Discharge Points

Applicants should submit the following information for each discharge point:

Table D.2:

PT_CD	PT_TYP E	LA_NAME	RWB_TYPE	RWB_NAME	DESIGNATION	EASTING	NORTHING
Point Code Provide label ID's	Point Type (e.g., Primary/ Secondary/ Storm Water Overflow)	Local Authority Name (e.g., Donegal County Council)	Receiving Water Body Type (e.g., River, Lake, Groundwater, Transitional, Coastal)	Receiving Water Body Name (e.g., River Suir)	Protected Area Type (e.g., SAC, candidate SAC, NHA, SPA etc.)	6E-digit GPS Irish National Grid Reference	6N-digit GPS Irish National Grid Reference
SW01- GLAN	Primary	Cork County Council	River	Funshion River	None	175870E	103919N
SW02- GLAN	Storm water overflow	Cork County Council	River	Funshion River	None	175868E	103920N

An individual record (i.e. row) is required for each discharge point. Acceptable file formats include Excel, Access or other upon agreement with the Agency. A standard Excel template can be downloaded from the EPA website at www.epa.ie. This data should be submitted to the Agency on a separate CD-Rom containing sections B.1, B.2, B.3, B.4, B.5, C.1, E.3 and F.2.

For inspection purposes only.
Consent of copyright owner required for any reuse.

SECTION E: MONITORING

Advice on completing this section is provided in the accompanying Guidance Note.

E.1 Waste Water Discharge Frequency and Quantities – Existing & Proposed

Provide an estimation of the quantity of waste water likely to be emitted in relation to all primary and secondary discharge points applied for. This information should be included in Table E.1(i) via the following web based link: http://78.137.160.73/epa_wwd_licensing/.

Refer to 'epa wwd licensing' web page print off attached.

Provide an estimation of the quantity of waste water likely to be emitted in relation to all storm water overflows within the agglomeration applied for. This information should be included in Table E.1(ii) via the following web based link: http://78.137.160.73/epa_wwd_licensing/.

Indicate if composite sampling or continuous flow monitoring is in place on the primary or any other discharge points. Detail any plans and timescales for the provision of composite sampling and continuous flow meters.

There is a Composite sampler located on the outlet manhole prior to the discharge point.

There is a flow monitors which measures flows from the pump sump to the BL4000 units.

E.2. Monitoring and Sampling Points

Programmes for environmental monitoring should be submitted as part of the application. These programmes should be provided as Attachment E.2.

Reference should be made to, provision of sampling points and safe means of access, sampling methods, analytical and quality control procedures, including equipment calibration, equipment maintenance and data recording/reporting procedures to be carried out in order to ensure accurate and reliable monitoring.

In determining the sampling programme to be carried out, the variability of the emission and its effect on the receiving environment should be considered.

Cork County Council Water Services Laboratories sample and monitor in accordance with 'Sampling Methods for examination of water and wastewater' 18th edition 1992. Sampling is carried out on a Bi-annual basis.

Details of any accreditation or certification of analysis should be included.

Attachment E.2 should contain any supporting information.

Attachment included	Yes	No
		√

E.3. Tabular data on Monitoring and Sampling Points

Applicants should submit the following information for each monitoring and sampling point:

PT_CD	PT_TYPE	MON_TYPE	EASTING	NORTHING	VERIFIED
Point Code Provide label ID's assigned in section E of application	Point Type (e.g., Primary, Secondary, Storm Water Overflow)	Monitoring Type M = Monitoring S = Sampling	6E-digit GPS Irish National Grid Reference	6N-digit GPS Irish National Grid Reference	Y = GPS used N = GPS not used
SW01	Primary	Sampling	175870	103919	N
aSW01u	u/s	Sampling	175897	103979	N
aSW01d	d/s	Sampling	179240	102995	N

An individual record (i.e., row) is required for each monitoring and sampling point. Acceptable file formats include Excel, Access or other upon agreement with the Agency. A standard Excel template can be downloaded from the EPA website at www.epa.ie. This data should be submitted to the Agency on a separate CD-Rom containing sections B.1, B.2, B.3, B.4, B.5, C.1, D.2 and F.2.

E.4 Sampling Data

Regulation 16(1)(h) of the Waste Water Discharge (Authorisation) Regulations 2007 requires all applicants in the case of an existing waste water treatment plant to specify the sampling data pertaining to the discharge based on the samples taken in the 12 months preceding the making of the application.

Regulation 16(1)(l) of the regulations requires applicants to give details of compliance with any applicable monitoring requirements and treatment standards.

Attachment E.4 should contain any supporting information.

Attachment included	Yes	No
	√	

SECTION F: EXISTING ENVIRONMENT & IMPACT OF THE DISCHARGE(S)

Advice on completing this section is provided in the accompanying Guidance Note.

Detailed information is required to enable the Agency to assess the existing receiving environment. This section requires the provision of information on the ambient environmental conditions within the receiving water(s) upstream and downstream of any discharge(s).

Where development is proposed to be carried out, being development which is of a class for the time being specified under Article 24 (First Schedule) of the Environmental Impact Assessment Regulations, the information on the state of the existing environment should be addressed in the EIS. **In such cases, it will suffice for the purposes of this section to provide adequate cross-references to the relevant sections in the EIS.**

F.1. Assessment of Impact on Receiving Surface or Ground Water

- o Give summary details and an assessment of the impacts of any existing or proposed emissions on the environment, including environmental media other than those into which the emissions are to be made. The monitoring results at the discharge point (attachment E4) indicate that the plant is operating well within the requirements of the Urban Waste Water Treatment regulations.

Emissions on Receiving Waters

Assimilative capacity assessment based on the dilution model is shown in the following table.

Assimilative Capacity of the Receiving water

2	m ³ /s	95% Median flow of River
6.35	m ³ /s	Median River Flow
0.001	m ³ /s	average volume of discharge

		Total Phosphate	Ortho Phosphate	BOD ₅	SS	Total Nitrogen	Sulphate	Ammonia-N
Median in River	mg/l	0.093	0.055	2.000	3.250	4.500	<30	0.150
Median in Discharge	mg/l	5.140	2.680	47.000	58.900	24.600	<30	19.540
C _{final}	mg/l	0.096	0.056	2.022	3.278	4.510	<30	0.160

Increase in River	mg/l	0.003	0.001	0.022	0.028	0.010	-	0.010
-------------------	------	-------	-------	-------	-------	-------	---	-------

Note: * Figures based on average of CCCN monitoring as per attachment E4
 Assimilative Capacity Calculations were not performed for the following parameters, as the substances were below the limit of detection in the upstream samples, in the discharge samples and in the downstream samples:
 (Chromium, Copper, Lead, Nickel, Cadmium, Barium, Boron, Zinc, Fluoride)

- o Details of all monitoring of the receiving water should be supplied via the following web based link: http://78.137.160.73/epa_wwd_licensing/. Tables F.1(i)(a) & (b) should be completed for the primary discharge point. Surface water monitoring locations upstream and downstream of the discharge point shall be screened for those substances listed in Tables F.1(i)(a) & (b). Monitoring of surface water shall be carried out at not less than two points, one upstream from the discharge location and one downstream.
Refer to 'epa wwd licensing' web page print off attached.
- o For discharges from secondary discharge points Tables F.1(ii)(a) & (b) should be completed. Furthermore, provide summary details and an assessment of the impacts of any existing or proposed emissions on the surface water or ground (aquifers, soils, sub-soils and rock environment), including any impact on environmental media other than those into which the emissions are to be made.
Not applicable, there are no secondary discharges from the works
- o Provide details of the extent and type of ground emissions at the works. For larger discharges to groundwaters, e.g., from Integrated Constructed Wetlands, large scale percolation areas, etc., a comprehensive report must be completed which should include, inter alia, topography, meteorological data, water quality, geology, hydrology, and hydrogeology. The latter must in particular present the aquifer classification and vulnerability. The Geological Survey of Ireland Groundwater Protection Scheme Dept of the Environment and Local Government, Geological Survey of Ireland, EPA (1999) methodology should be used for any such classification. This report should also identify all surface water bodies and water wells that may be at risk as a result of the ground discharge.
Not applicable, there are no ground emissions from the works.
- o Describe the existing environment in terms of water quality with particular reference to environmental quality standards or other legislative standards. Submit a copy of the most recent water quality management plan or catchment management plan in place for the receiving water body. Give details of any designation under any Council Directive or Regulations that apply in relation to the receiving water.
Water quality recorded at EPA sampling locations ;

Sampling Location	EPA Biological Quality Rating (Q values)		
	1995 -1997	2001 – 2003	Target
Br. at Glanworth	4	4	4
Ballynahow Br.	4-5	4-5	4

River Designations

- Shellfish Regulations Not designated.
S.I.200:1994;
- Bathing Water Regulations S.I. Not designated
178:1998
- Salmonid Water Regulations Not designated
S.I. 293: 1998
- Special Area of Conservation Not designated
(SAC)
- Special Protection Area (SPA); Not Designated, however the Blackwater estuary

is designated.

Sensitive Area (Urban Waste Not designated
water
Treatment Regulations
S.I.254:2001)

The River Blackwater is included in the draft Management Plan for the South Western River Basin District (Dec 2008). This can be downloaded at the following address;

<http://www.swrbd.ie/downloads/Web/South%20Western%20RBD%20RMBP.pdf>.

- o Provide a statement as to whether or not emissions of main polluting substances (as defined in the *Dangerous Substances Regulations S.I. No. 12 of 2001*) to water are likely to impair the environment.

There is no evidence to suggest that there are sources within the agglomeration or in the discharge itself which would lead to emissions of the main polluting substances (as defined in the dangerous substances Regulations SI 12:2001) at levels which would likely to impair the environment.

- o In circumstances where water abstraction points exist downstream of any discharge describe measures to be undertaken to ensure that discharges from the waste water works will not have a significant effect on faecal coliform, salmonella and protozoan pathogen numbers, e.g., *Cryptosporidium* and *Giardia*, in the receiving water environment.

There are no downstream water abstraction points.

- o Indicate whether or not emissions from the agglomeration or any plant, methods, processes, operating procedures or other factors which affect such emissions are likely to have a significant effect on –

- (a) a site (until the adoption, in respect of the site, of a decision by the European Commission under Article 21 of Council Directive 92/43/EEC for the purposes of the third paragraph of Article 4(2) of that Directive) —
 - (i) notified for the purposes of Regulation 4 of the Natural Habitats Regulations, subject to any amendments made to it by virtue of Regulation 5 of those Regulations,
 - (ii) details of which have been transmitted to the Commission in accordance with Regulation 5(4) of the Natural Habitats Regulations, or
 - (iii) added by virtue of Regulation 6 of the Natural Habitats Regulations to the list transmitted to the Commission in accordance with Regulation 5(4) of those Regulations,
- (b) a site adopted by the European Commission as a site of Community importance for the purposes of Article 4(2) of Council Directive 92/43/EEC¹ in accordance with the procedures laid down in Article 21 of that Directive,

- (c) a special area of conservation within the meaning of the Natural Habitats Regulations, or
- (d) an area classified pursuant to Article 4(1) or 4(2) of Council Directive 79/409/EEC²;

¹Council Directive 92/43/EEC of 21 May 1992 on the conservation of natural habitats and of wild fauna and flora (OJ No. L 206, 22.07.1992)

²Council Directive 79/409/EEC of 2 April 1979 on the conservation of wild birds (OJ No. L 103, 25.4.1979)

The development is in the surface water catchment of the River Blackwater, SAC 002170. In accordance with EPA Circular L8/08 Appendix 1, the project must be screened for its impacts. However, due to financial constraints, Cork County Council does not have the resources for the foreseeable future to assess the impacts in accordance with the EPA document, 'Waste Water discharge Licence – Appropriate Assessment'.

- o Describe, where appropriate, measures for minimising pollution over long distances or in the territory of other states.

Not applicable.

- o This section should also contain full details of any modelling of discharges from the agglomeration. Full details of the assessment and any other relevant information on the receiving environment should be submitted as **Attachment F.1**.

Attachment included	Yes	No
		√

F.2 Tabular Data on Drinking Water Abstraction Point(s)

Applicants should submit the following information for each downstream or downgradient drinking water abstraction point. The zone of contribution for the abstraction point should be delineated and any potential risks from the waste water discharge to the water quality at that abstraction point identified.

ABS_CD	AGG_SERVED	ABS_VOL	PT_CD	DIS_DS	EASTING	NORTHING	VERIFIED
Abstraction Code	Agglomeration served	Abstraction Volume in m ³ /day	Point Code Provide label ID's	Distance Downstream in meters from Emission Point to Abstraction Point	6E-digit GPS Irish National Grid Reference	6N-digit GPS Irish National Grid Reference	Y = GPS used N = GPS not used

Note: Attach any risk assessment that may have been carried out in relation to the abstraction point(s) listed.

An individual record (i.e. row) is required for each abstraction point. Acceptable file formats include Excel, Access or other upon agreement with the Agency. A standard Excel template can be downloaded from the EPA website at www.epa.ie. This data should be submitted to the Agency on a separate CD-Rom containing sections B.1, B.2, B.3, B.4, B.5, C.1, D.2 and E.3.

There are no downstream or downgradient drinking water abstraction point.

Attachment F.2 should contain any supporting information.

Attachment included	Yes	No
		√

For inspection purposes only.
Consent of copyright owner required for any other use.

SECTION G: PROGRAMMES OF IMPROVEMENTS

Advice on completing this section is provided in the accompanying Guidance Note.

G.1 Compliance with Council Directives

Provide details on a programme of improvements to ensure that emissions from the agglomeration or any premises, plant, methods, processes, operating procedures or other factors which affect such emissions will comply with, or will not result in the contravention of the;

- Dangerous Substances Directive 2006/11/EC,
- Water Framework Directive 2000/60/EC,
- Birds Directive 79/409/EEC,
- Groundwater Directives 80/68/EEC & 2006/118/EC,
- Drinking Water Directives 80/778/EEC,
- Urban Waste Water Treatment Directive 91/271/EEC,
- Habitats Directive 92/43/EEC,
- Environmental Liabilities Directive 2004/35/EC,
- Bathing Water Directive 76/160/EEC, and
- Shellfish Waters Directive (79/923/EEC).

There is currently no programme of improvements for the treatment plant.

Attachment G.1 should contain the most recent programme of improvements, including a copy of any approved funding for the project and a timeframe for the completion of the necessary works to take place.

Attachment included	Yes	No
		X

For inspection purposes only
Consent of copyright owner required for any other use.

G.2 Compliance with Water Quality Standards for Phosphorus Regulations (S.I. No. 258 of 1998).

Provide details on a programme of improvements, including any water quality management plans or catchment management plans in place, to ensure that improvements of water quality required under the Water Quality Standards for Phosphorous Regulations (S.I. No. 258 of 1998) are being achieved. Provide details of any specific measures adopted for waste water works specified in Phosphorus Measures Implementation reports and the progress to date of those measures. Provide details highlighting any waste water works that have been identified as the principal sources of pollution under the P regulations.

There is currently no programme of improvements for the treatment plant.

Attachment G.2 should contain the most recent programme of improvements and any associated documentation requested under Section G.3 of the application.

Attachment included	Yes	No

G.3 Impact Mitigation

Provide details on a programme of improvements to ensure that discharges from the agglomeration will not result in significant environmental pollution.

There is currently no programme of improvements for the treatment plant.

Attachment G.3 should contain the most recent programme of improvements, including a copy of any approved funding for the project and a timeframe for the completion of the necessary works to take place.

Attachment included	Yes	No
		X

G.4 Storm Water Overflow

Provide details on a programme of improvements to ensure that discharges other than the primary and secondary discharges comply with the definition of 'storm water overflow' as per Regulation 3 of the Waste Water Discharge (Authorisation) Regulations, 2007.

The water services Investment Programme 2007-2009 does not allocate any funding for improvements to the Glanworth WWTP.

The existing storm water tank was installed in 2005 to help the plant cope with peak storm events. The tank is fitted with 2 pumps to return stored sewerage to the inlet to the treatment works. When the storage facilities are overloaded, a baffled emergency overflow will allow discharge to the River Funshion. The existing tank has circa 24m³ storage capacity.

Cork County Council is currently in the process of acquiring lands adjacent to the existing compound to facilitate expansion of the treatment works. It is proposed to increase the storm water holding capacity to circa 100m³, however, funding has not been secured to proceed with this upgrade.

Attachment G.4 should contain the most recent programme of improvements, including a copy of any approved funding for the project and a timeframe for the completion of the necessary works to take place.

Attachment included	Yes	No
		X

For inspection purposes only.
Consent of copyright owner required for any other use.

SECTION H: DECLARATION


Declaration

I hereby make application for a waste water discharge licence/revised licence, pursuant to the provisions of the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. No. 684 of 2007).

I certify that the information given in this application is truthful, accurate and complete.

I give consent to the EPA to copy this application for its own use and to make it available for inspection and copying by the public, both in the form of paper files available for inspection at EPA and local authority offices, and via the EPA's website.

This consent relates to this application itself and to any further information or submission, whether provided by me as Applicant, any person acting on the Applicant's behalf, or any other person.

Signed by : 
(on behalf of the organisation)

Date : 16th June 2009

Print signature name: TOM STRITCH

Position in organisation: DIRECTOR OF SERVICES

For inspection purposes only.
Consent of copyright owner required for any other use.

SECTION I: JOINT DECLARATION

Joint Declaration Note1

I hereby make application for a waste water discharge licence/revised licence, pursuant to the provisions of the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. No. 684 of 2007).

I certify that the information given in this application is truthful, accurate and complete.

I give consent to the EPA to copy this application for its own use and to make it available for inspection and copying by the public, both in the form of paper files available for inspection at EPA and local authority offices, and via the EPA's website.

This consent relates to this application itself and to any further information or submission whether provided by me as Applicant, any person acting on the Applicant's behalf, or any other person.

Lead Authority

Signed by : _____ **Date :** _____
(on behalf of the organisation)

Print signature name: _____

Position in organisation: _____

Co-Applicants

Signed by : _____ **Date :** _____
(on behalf of the organisation)

Print signature name: _____

Position in organisation: _____

Signed by : _____ **Date :** _____
(on behalf of the organisation)

Print signature name: _____

Position in organisation: _____

Note 1: In the case of an application being lodged on behalf of more than a single water services authority the following declaration must be signed by all applicants.

*For inspection purposes only.
Consent of copyright owner required for any other use.*

Agglomeration details

Leading Local Authority	Cork County Council
Co-Applicants	
Agglomeration	Glanworth
Population Equivalent	990
Level of Treatment	Secondary
Treatment plant address	Glanworth Fermoy Co. Cork
Grid Ref (12 digits, 6E, 6N)	175812 / 103927
EPA Reference No:	

Contact details

Contact Name:	Frank Cronin
Contact Address:	Water Services Section Cork County Council Northern Division Annabella Mallow Co Cork
Contact Number:	022-21123
Contact Fax:	02221983
Contact Email:	frank.cronin@corkcoco.ie

Consent of copyright owner required for any other use.
For information purposes only.

Table D.1(i)(a): EMISSIONS TO SURFACE/GROUND WATERS (Primary Discharge Point)

Discharge Point Code: SW-1

Local Authority Ref No:	SW1-GLAN	
Source of Emission:	Glanworth WWTP	
Location:	Glanworth Village, Fermoy, Co. Cork	
Grid Ref (12 digits, 6E, 6N)	175870 / 103919	
Name of Receiving waters:	River Funshion	
Water Body:	River Water Body	
River Basin District	South Western RBD	
Designation of Receiving Waters:	U/s of Salmoid River	
Flow Rate in Receiving Waters:	0.37	m ³ .sec ⁻¹ Dry Weather Flow
	0.75	m ³ .sec ⁻¹ 95% Weather Flow
Additional Comments (e.g. commentary on zero flow or other information deemed of value)		

Emission Details:

(i) Volume emitted			
Normal/day	134 m ³	Maximum/day	650 m ³
Maximum rate/hour	134 m ³	Period of emission (avg)	60 min/hr 24 hr/day 365 day/yr
Dry Weather Flow	650 m ³ /sec		

For inspection purposes only. Consent of copyright owner required for any other use.

Table D.1(i)(b): EMISSIONS TO SURFACE/GROUND WATERS - Characteristics of The Emission (Primary Discharge Point)

Discharge Point Code: SW-1

Substance	As discharged			kg/day
	Unit of Measurement	Sampling Method	Max Daily Avg.	
pH	pH	24 hr composite	= 9	
Temperature	°C	24 hr composite	= 30	
Electrical Conductivity (@ 25°C)	µS/cm	24 hr composite	= 1000	
Suspended Solids	mg/l	24 hr composite	= 35	
Ammonia (as N)	mg/l	24 hr composite	= 0	0
Biochemical Oxygen Demand	mg/l	24 hr composite	= 25	
Chemical Oxygen Demand	mg/l	24 hr composite	= 125	
Total Nitrogen (as N)	mg/l	24 hr composite	= 35	
Nitrite (as N)	mg/l	24 hr composite	= 0	0
Nitrate (as N)	mg/l	24 hr composite	= 0	0
Total Phosphorous (as P)	mg/l	24 hr composite	= 8	
OrthoPhosphate (as P)	mg/l	24 hr composite	= 6	
Sulphate (SO ₄)	mg/l	24 hr composite	= 0	0
Phenols (Sum)	µg/l	24 hr composite	= 0	0

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper
 For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent only

For inspection purposes only
 Consent of copyright owner required for any other use

Table D.1(i)(c): DANGEROUS SUBSTANCE EMISSIONS TO SURFACE/GROUND WATERS - Characteristics of The Emission (Primary Discharge Point)

Discharge Point Code: SW-1

Substance	As discharged			
	Unit of Measurement	Sampling Method	Max Daily Avg.	kg/day
Atrazine	µg/l	24 hr composite	= 0	0
Dichloromethane	µg/l	24 hr composite	= 0	0
Simazine	µg/l	24 hr composite	= 0	0
Toluene	µg/l	24 hr composite	= 0	0
Tributyltin	µg/l	24 hr composite	= 0	0
Xylenes	µg/l	24 hr composite	= 0	0
Arsenic	µg/l	24 hr composite	= 0	0
Chromium	µg/l	24 hr composite	= 0	0
Copper	µg/l	24 hr composite	= 0	0
Cyanide	µg/l	24 hr composite	= 0	0
Flouride	µg/l	24 hr composite	= 0	0
Lead	µg/l	24 hr composite	= 0	0
Nickel	µg/l	24 hr composite	= 0	0
Zinc	µg/l	24 hr composite	= 0	0
Boron	µg/l	24 hr composite	= 0	0
Cadmium	µg/l	24 hr composite	= 0	0
Mercury	µg/l	24 hr composite	= 0	0
Selenium	µg/l	24 hr composite	= 0	0
Barium	µg/l	24 hr composite	= 0	0

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper

For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent.

Consent of copyright owner required for reproduction in any form or by any means other than for inspection purposes only.

Table D.1(iii)(a): EMISSIONS TO SURFACE/GROUND WATERS (Storm Overflow)

Discharge Point Code: SW-2

Local Authority Ref No:	SW2-GLAN
Source of Emission:	Glanworth WWTP
Location:	Glanworth, Fermoy, Co Cork
Grid Ref (12 digits, 6E, 6N)	175868 / 103920
Name of Receiving waters:	River Funshion
Water Body:	River Water Body
River Basin District	South Western RBD
Designation of Receiving Waters:	Upstream of SAC Code 002170
Flow Rate in Receiving Waters:	0.37 m ³ .sec ⁻¹ Dry Weather Flow 0.75 m ³ .sec ⁻¹ 95% Weather Flow
Additional Comments (e.g. commentary on zero flow or other information deemed of value)	no flow data available for the storm overflow.

Emission Details:

(i) Volume emitted			
Normal/day	0 m ³	Maximum/day	0 m ³
Maximum rate/hour	0 m ³	Period of emission (avg)	0 min/hr 0 hr/day 0 day/yr
Dry Weather Flow	0 m ³ /sec		

For inspection purposes only. Consent of copyright owner required for any other use.

TABLE E.1(i): WASTE WATER FREQUENCY AND QUANTITY OF DISCHARGE – Primary and Secondary Discharge Points

Identification Code for Discharge point	Frequency of discharge (days/annum)	Quantity of Waste Water Discharged (m ³ /annum)
SW-1	365	48910

For inspection purposes only.
Consent of copyright owner required for any other use.

TABLE E.1(ii): WASTE WATER FREQUENCY AND QUANTITY OF DISCHARGE – Storm Water Overflows

Identification Code for Discharge point	Frequency of discharge (days/annum)	Quantity of Waste Water Discharged (m ³ /annum)	Complies with Definition of Storm Water Overflow
SW-2	0	0	Yes

For inspection purposes only.
Consent of copyright owner required for any other use.

TABLE F.1(i)(a): SURFACE/GROUND WATER MONITORING

Primary Discharge Point

Discharge Point Code:	SW-1
MONITORING POINT CODE:	aSW-1d
Grid Ref (12 digits, 6E, 6N)	179240 / 102995

Parameter	Results (mg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	23/10/08	01/01/09	28/01/09	17/02/09			
pH			= 7.8	= 8.5	Grab	2	Electrochemical
Temperature				= 8.5	Grab	0.5	electrochemical
Electrical Conductivity (@ 25°C)			= 309	= 474	Grab	0.5	Electrochemical
Suspended Solids			= 9	= 7	Grab	0.5	Gravimetric
Ammonia (as N)			= 0.2	= 0.09	Grab	0.02	Colorimetric
Biochemical Oxygen Demand			= 1	< 4	Grab	0.06	Electrochemical
Chemical Oxygen Demand			< 21	= 5	Grab	8	Digestion & Colorimetric
Dissolved Oxygen		= 0			Grab	0	ISE
Hardness (as CaCO ₃)		= 0			Grab	0	titrimetric
Total Nitrogen (as N)			= 4.8	= 4.9	Grab	0.5	Digestion & Colorimetric
Nitrite (as N)			= 0.0235		Grab	0.013	colorimetric
Nitrate (as N)			= 4.47		Grab	0.04	Colorimetric
Total Phosphorous (as P)			= 0.2	= 0.05	Grab	0.2	Digestion & Colorimetric
OrthoPhosphate (as P)	< 0.05		< 0.05	< 0.05	Grab	0.02	Colorimetric
Sulphate (SO ₄)			< 30		Grab	30	Turbidimetric
Phenols (Sum)			< 0.1		Grab	0.1	GC-MS2

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper

For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent.

Additional Comments:	default of 01/01/09 and 0 where results are not available
----------------------	---

WWD Licence Application Annex I

Parameter	Results (mg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	19/02/09	05/03/09	19/03/09	21/04/09			
pH			= 8.1	= 8.2	Grab	2	Electrochemical
Temperature					Grab	0.5	electrochemical
Electrical Conductivity (@ 25°C)			= 512	= 498	Grab	0.5	Electrochemical
Suspended Solids			< 2	= 3	Grab	0.5	Gravimetric
Ammonia (as N)				< 0.05	Grab	0.02	Colorimetric
Biochemical Oxygen Demand			< 4	< 4	Grab	0.06	Electrochemical
Chemical Oxygen Demand			= 5	= 8	Grab	8	Digestion & Colorimetric
Dissolved Oxygen					Grab	0	ISE
Hardness (as CaCO ₃)					Grab	0	titrimetric
Total Nitrogen (as N)			= 4.6	= 4	Grab	0.5	Digestion & Colorimetric
Nitrite (as N)					Grab	0.013	colorimetric
Nitrate (as N)					Grab	0.04	Colorimetric
Total Phosphorous (as P)			= 0.18	= 0.09	Grab	0.2	Digestion & Colorimetric
OrthoPhosphate (as P)	< 0.05	= 0.1	= 0.05	= 0.07	Grab	0.02	Colorimetric
Sulphate (SO ₄)					Grab	30	Turbidimetric
Phenols (Sum)					Grab	0.1	GC-MS2

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper

For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent

Additional Comments:	default of 01/01/09 and 0 where results are not available
----------------------	---

For inspection purposes only. Consent of copyright owner required for any other use.

WWD Licence Application Annex I

Parameter	Results (mg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	19/05/09						
pH	= 7.9				Grab	2	Electrochemical
Temperature					Grab	0.5	electrochemical
Electrical Conductivity (@ 25°C)	= 387				Grab	0.5	Electrochemical
Suspended Solids	= 3				Grab	0.5	Gravimetric
Ammonia (as N)	= 0.06				Grab	0.02	Colorimetric
Biochemical Oxygen Demand	< 4				Grab	0.06	Electrochemical
Chemical Oxygen Demand	= 23				Grab	8	Digestion & Colorimetric
Dissolved Oxygen					Grab	0	ISE
Hardness (as CaCO ₃)					Grab	0	titrimetric
Total Nitrogen (as N)	= 4.32				Grab	0.5	Digestion & Colorimetric
Nitrite (as N)					Grab	0.013	colorimetric
Nitrate (as N)					Grab	0.04	Colorimetric
Total Phosphorous (as P)	= 0.08				Grab	0.2	Digestion & Colorimetric
OrthoPhosphate (as P)	= 0.08				Grab	0.02	Colorimetric
Sulphate (SO ₄)					Grab	30	Turbidimetric
Phenols (Sum)					Grab	0.1	GC-MS2

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper
 For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent.

Additional Comments:	default of 01/01/09 and 0 where results are not available
----------------------	---

For inspection purposes only. Consent of copyright owner required for any other use.

TABLE F.1(i)(b): SURFACE/GROUND WATER MONITORING (Dangerous Substances)

Primary Discharge Point

Discharge Point Code:	SW-1
MONITORING POINT CODE:	aSW-1d
Grid Ref (12 digits, 6E, 6N)	179240 / 102995

Parameter	Results (µg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	01/01/09	28/01/09	17/02/09	19/02/09			
Atrazine		< 0.01			Grab	0.96	HPLC
Dichloromethane		< 0.2			Grab	1	GC-MS1
Simazine		< 0.01			Grab	0.01	HPLC
Toluene		< 1			Grab	0.02	GC-MS1
Tributyltin	= 0				Grab	0.02	GC-MS1
Xylenes		< 1			Grab	1	GC-MS1
Arsenic		< 0.96			Grab	0.96	ICP-MS
Chromium		< 20	< 20	< 20	Grab	20	ICP-OES
Copper		< 20	< 20	< 20	Grab	20	ICP-OES
Cyanide		< 5			Grab	5	Colorimetric
Flouride		= 57			Grab	100	ISE
Lead		< 20	< 20	< 20	Grab	20	ICP-OES
Nickel		< 20	< 20	< 20	Grab	20	ICP-OES
Zinc		< 20	< 20	< 20	Grab	20	ICP-OES
Boron		< 20	< 20	< 20	Grab	20	ICP-OES
Cadmium		< 20	< 20	< 20	Grab	20	ICP-OES
Mercury		< 0.2			Grab	0.2	ICP-MS
Selenium		= 0.9			Grab	0.74	ICP-MS
Barium		= 51	< 20	= 25	Grab	20	ICP-OES

Additional Comments:	TBT value is 0.02ug/l as Sn TBT analysis not required
----------------------	--

WWD Licence Application Annex I

Parameter	Results (µg/l)			Sampling method	Limit of Quantitation	Analysis method / technique
	19/03/09	21/04/09	19/05/09			
Atrazine				Grab	0.96	HPLC
Dichloromethane				Grab	1	GC-MS1
Simazine				Grab	0.01	HPLC
Toluene				Grab	0.02	GC-MS1
Tributyltin				Grab	0.02	GC-MS1
Xylenes				Grab	1	GC-MS1
Arsenic				Grab	0.96	ICP-MS
Chromium	< 20	< 20	< 20	Grab	20	ICP-OES
Copper	= 43.1	< 20	< 20	Grab	20	ICP-OES
Cyanide				Grab	5	Colorimetric
Flouride				Grab	100	ISE
Lead	< 20	< 20	< 20	Grab	20	ICP-OES
Nickel	< 20	< 20	< 20	Grab	20	ICP-OES
Zinc	= 29.9	< 20	< 20	Grab	20	ICP-OES
Boron	= 43.9	< 20	< 20	Grab	20	ICP-OES
Cadmium	< 20	< 20	< 20	Grab	20	ICP-OES
Mercury				Grab	0.2	ICP-MS
Selenium				Grab	0.74	ICP-MS
Barium	= 28.2	< 20	< 20	Grab	20	ICP-OES

Additional Comments:	TBT value is 0.02ug/l as Sn TBT analysis not required
----------------------	--

*For inspection purposes only.
Consent of copyright owner required for any other use.*

TABLE F.1(i)(a): SURFACE/GROUND WATER MONITORING

Primary Discharge Point

Discharge Point Code:	SW-1
MONITORING POINT CODE:	aSW-1u
Grid Ref (12 digits, 6E, 6N)	175897 / 103979

Parameter	Results (mg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	23/10/08	01/01/09	28/01/09	17/02/09			
pH			= 7.8	= 7.9	Grab	2	Electrochemical
Temperature				= 8.5	Grab	0.5	electrochemical
Electrical Conductivity (@ 25°C)			= 304	= 451	Grab	0.5	Electrochemical
Suspended Solids			= 6	= 3	Grab	0.5	Gravimetric
Ammonia (as N)			= 0.2	= 0.3	Grab	0.02	Colorimetric
Biochemical Oxygen Demand			< 1	< 2	Grab	0.06	Electrochemical
Chemical Oxygen Demand			< 21	= 5	Grab	8	Digestion & Colorimetric
Dissolved Oxygen		= 0			Grab	0	ISE
Hardness (as CaCO ₃)		= 0			Grab	0	titrimetric
Total Nitrogen (as N)			= 4.8	= 4.7	Grab	0.5	Digestion & Colorimetric
Nitrite (as N)			= 0.0237		Grab	0.013	colorimetric
Nitrate (as N)			= 4.6		Grab	0.04	Colorimetric
Total Phosphorous (as P)			= 0.05	= 0.05	Grab	0.2	Digestion & Colorimetric
OrthoPhosphate (as P)	< 0.05		< 0.05	< 0.05	Grab	0.02	Colorimetric
Sulphate (SO ₄)			< 30		Grab	30	Turbidimetric
Phenols (Sum)			< 0.1		Grab	0.1	GC-MS2

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper
 For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent.

Additional Comments:	default of 01/01/09 and 0 where results are not available
----------------------	---

WWD Licence Application Annex I

Parameter	Results (mg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	19/02/09	05/03/09	19/03/09	21/04/09			
pH			= 8	= 8.1	Grab	2	Electrochemical
Temperature					Grab	0.5	electrochemical
Electrical Conductivity (@ 25°C)			= 483	= 505	Grab	0.5	Electrochemical
Suspended Solids			= 2	= 3	Grab	0.5	Gravimetric
Ammonia (as N)			= 0.06	= 0.05	Grab	0.02	Colorimetric
Biochemical Oxygen Demand			< 2	< 2	Grab	0.06	Electrochemical
Chemical Oxygen Demand			= 5	= 5	Grab	8	Digestion & Colorimetric
Dissolved Oxygen					Grab	0	ISE
Hardness (as CaCO ₃)					Grab	0	titrimetric
Total Nitrogen (as N)			= 4.4	= 4	Grab	0.5	Digestion & Colorimetric
Nitrite (as N)					Grab	0.013	colorimetric
Nitrate (as N)					Grab	0.04	Colorimetric
Total Phosphorous (as P)			= 0.16	= 0.08	Grab	0.2	Digestion & Colorimetric
OrthoPhosphate (as P)	< 0.05	= 0.1	= 0.05	= 0.08	Grab	0.02	Colorimetric
Sulphate (SO ₄)					Grab	30	Turbidimetric
Phenols (Sum)					Grab	0.1	GC-MS2

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper

For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent

Additional Comments:	default of 01/01/09 and 0 where results are not available
----------------------	---

For inspection purposes only. Consent of copyright owner required for any other use

WWD Licence Application Annex I

Parameter	Results (mg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	19/05/09						
pH	= 7.9				Grab	2	Electrochemical
Temperature					Grab	0.5	electrochemical
Electrical Conductivity (@ 25°C)	= 387				Grab	0.5	Electrochemical
Suspended Solids	= 6				Grab	0.5	Gravimetric
Ammonia (as N)	= 0.07				Grab	0.02	Colorimetric
Biochemical Oxygen Demand	< 2				Grab	0.06	Electrochemical
Chemical Oxygen Demand	= 31				Grab	8	Digestion & Colorimetric
Dissolved Oxygen					Grab	0	ISE
Hardness (as CaCO ₃)					Grab	0	titrimetric
Total Nitrogen (as N)	= 4.23				Grab	0.5	Digestion & Colorimetric
Nitrite (as N)					Grab	0.013	colorimetric
Nitrate (as N)					Grab	0.04	Colorimetric
Total Phosphorous (as P)	= 0.1				Grab	0.2	Digestion & Colorimetric
OrthoPhosphate (as P)	= 0.07				Grab	0.02	Colorimetric
Sulphate (SO ₄)					Grab	30	Turbidimetric
Phenols (Sum)					Grab	0.1	GC-MS2

For Orthophosphate: this monitoring should be undertaken on a sample filtered on 0.45µm filter paper
 For Phenols: USEPA Method 604, AWWA Standard Method 6240, or equivalent

Additional Comments:	default of 01/01/09 and 0 where results are not available
----------------------	---

For inspection purposes only. Consent of copyright owner required for any other use.

TABLE F.1(i)(b): SURFACE/GROUND WATER MONITORING (Dangerous Substances)

Primary Discharge Point

Discharge Point Code:	SW-1
MONITORING POINT CODE:	aSW-1u
Grid Ref (12 digits, 6E, 6N)	175897 / 103979

Parameter	Results (µg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	01/01/09	28/01/09	17/02/09	19/02/09			
Atrazine		< 0.01			Grab	0.96	HPLC
Dichloromethane		< 1			Grab	1	GC-MS1
Simazine		< 0.01			Grab	0.01	HPLC
Toluene		< 1			Grab	0.02	GC-MS1
Tributyltin	= 0				Grab	0.02	GC-MS1
Xylenes		< 1			Grab	1	GC-MS1
Arsenic		< 0.96			Grab	0.96	ICP-MS
Chromium		< 20	< 20	< 20	Grab	20	ICP-OES
Copper		< 20	< 20	< 20	Grab	20	ICP-OES
Cyanide		< 5			Grab	5	Colorimetric
Flouride		= 69			Grab	100	ISE
Lead		< 20	< 20	< 20	Grab	20	ICP-OES
Nickel		< 20	< 20	< 20	Grab	20	ICP-OES
Zinc		< 20	< 20	< 20	Grab	20	ICP-OES
Boron		< 20	< 20	< 20	Grab	20	ICP-OES
Cadmium		< 20	< 20	< 20	Grab	20	ICP-OES
Mercury		< 0.2			Grab	0.2	ICP-MS
Selenium		= 0.8			Grab	0.74	ICP-MS
Barium		= 43	= 20	= 23	Grab	20	ICP-OES

Additional Comments:	TBT value is 0.02ug/l as Sn TBT analysis not required
----------------------	--

WWD Licence Application Annex I

Parameter	Results (µg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	21/04/09	19/05/09					
Atrazine					Grab	0.96	HPLC
Dichloromethane					Grab	1	GC-MS1
Simazine					Grab	0.01	HPLC
Toluene					Grab	0.02	GC-MS1
Tributyltin					Grab	0.02	GC-MS1
Xylenes					Grab	1	GC-MS1
Arsenic					Grab	0.96	ICP-MS
Chromium	< 20	< 20			Grab	20	ICP-OES
Copper	< 20	< 20			Grab	20	ICP-OES
Cyanide					Grab	5	Colorimetric
Flouride					Grab	100	ISE
Lead	< 20	< 20			Grab	20	ICP-OES
Nickel	< 20	< 20			Grab	20	ICP-OES
Zinc	< 20	< 20			Grab	20	ICP-OES
Boron	< 20				Grab	20	ICP-OES
Cadmium	< 20	< 20			Grab	20	ICP-OES
Mercury					Grab	0.2	ICP-MS
Selenium					Grab	0.74	ICP-MS
Barium	= 20	< 20			Grab	20	ICP-OES

Additional Comments:	TBT value is 0.02ug/l as Sn TBT analysis not required
----------------------	--

*For inspection purposes only.
Consent of copyright owner required for any other use.*

Annex 2: Check List For Regulation 16 Compliance

Regulation 16 of the waste water discharge (Authorisation) Regulations 2007 (S.I. No. 684 of 2007) sets out the information which must, in all cases, accompany a discharge licence application. In order to ensure that the application fully complies with the legal requirements of regulation 16 of the 2007 Regulations, all applicants should complete the following.

In each case, refer to the attachment number(s), of your application which contains(s) the information requested in the appropriate sub-article.

Regulation 16(1) In the case of an application for a waste water discharge licence, the application shall -		Attachment Number	Checked by Applicant
(a)	give the name, address, telefax number (if any) and telephone number of the applicant (and, if different, of the operator of any treatment plant concerned) and the address to which correspondence relating to the application should be sent and, if the operator is a body corporate, the address of its registered office or principal office,	B .1	Yes
(b)	give the name of the water services authority in whose functional area the relevant waste water discharge takes place or is to take place, if different from that of the applicant,	not applicable	Yes
(c)	give the location or postal address (including where appropriate, the name of the townland or townlands) and the National Grid reference of the location of the waste water treatment plant and/or the waste water discharge point or points to which the application relates,	B.2	Yes
(d)	state the population equivalent of the agglomeration to which the application relates,	B.9	Yes
(e)	specify the content and extent of the waste water discharge, the level of treatment provided, if any, and the flow and type of discharge,	C,D	Yes
(f)	give details of the receiving water body, including its protected area status, if any, and details of any sensitive areas or protected areas or both in the vicinity of the discharge point or points likely to be affected by the discharge concerned, and for discharges to ground provide details of groundwater protection schemes in place for the receiving water body and all associated hydrogeological and geological assessments related to the receiving water environment in the vicinity of the discharge.	F.1	Yes
(g)	identify monitoring and sampling points and indicate proposed arrangements for the monitoring of discharges and, if Regulation 17 does not apply, provide details of the likely environmental consequences of any such discharges,	E.2, E.3	Yes
(h)	in the case of an existing waste water treatment plant, specify the sampling data pertaining to the discharge based on the samples taken in the 12 months preceding the making of the application,	E.4	Yes
(i)	describe the existing or proposed measures, including emergency procedures, to prevent unintended waste water discharges and to minimise the impact on the environment of any such discharges,	G.3	Yes
(j)	give particulars of the nearest downstream drinking water abstraction point or points to the discharge point or points,	not applicable	Yes
(k)	give details, and an assessment of the effects, of any existing or proposed emissions on the environment, including any environmental medium other than those into which the emissions are, or are to be made, and of proposed measures to prevent or eliminate or, where that is not practicable, to limit any pollution caused in such discharges,	F.1	Yes
(l)	give detail of compliance with relevant monitoring requirements and treatment standards contained in any applicable Council Directives of Regulations,	E.1, E.4	Yes
(m)	give details of any work necessary to meet relevant effluent discharge standards and a timeframe and schedule for such work.	not applicable	Yes
(n)	Any other information as may be stipulated by the Agency.	not applicable	Yes
Regulation 16(3) Without prejudice to Regulation 16 (1) and (2), an application for a licence shall be accompanied by -		Attachment Number	Checked by Applicant
(a)	a copy of the notice of intention to make an application given pursuant to Regulation 9,	B.8	Yes
(b)	where appropriate, a copy of the notice given to a relevant water services authority under Regulation 13,	not applicable	Yes
(c)	Such other particulars, drawings, maps, reports and supporting documentation as are necessary to identify and describe, as appropriate -	B	Yes
(c) (i)	the point or points, including storm water overflows, from which a discharge or discharges take place or are to take place, and	B.3, B.4, B.5	Yes
(c) (ii)	the point or points at which monitoring and sampling are undertaken or are to be undertaken,	E.3	Yes
(d)	such fee as is appropriate having regard to the provisions of Regulations 38 and 39.	B.9	Yes

WWD Licence Application Annex II

Regulation 16(4) An original application shall be accompanied by 2 copies of it and of all accompanying documents and particulars as required under Regulation 16(3) in hardcopy or in an electronic or other format as specified by the Agency.		Attachment Number	Checked by Applicant
1	An Original Application shall be accompanied by 2 copies of it and of all accompanying documents and particulars as required under regulation 16(3) in hardcopy or in electronic or other format as specified by the agency.		Yes
Regulation 16(5) For the purpose of paragraph (4), all or part of the 2 copies of the said application and associated documents and particulars may, with the agreement of the Agency, be submitted in an electronic or other format specified by the Agency.		Attachment Number	Checked by Applicant
1	Signed original.		Yes
2	2 hardcopies of application provided or 2 CD versions of application (PDF files) provided.		Yes
3	1 CD of geo-referenced digital files provided.		Yes
Regulation 17 Where a treatment plant associated with the relevant waste water works is or has been subject to the European Communities (Environmental Impact Assessment) Regulations 1989 to 2001, in addition to compliance with the requirements of Regulation 16, an application in respect of the relevant discharge shall be accompanied by a copy of an environmental impact statement and approval in accordance with the Act of 2000 in respect of the said development and may be submitted in an electronic or other format specified by the Agency		Attachment Number	Checked by Applicant
1	EIA provided if applicable	not applicable	Yes
2	2 hardcopies of EIS provided if applicable.	not applicable	Yes
3	2 CD versions of EIS, as PDF files, provided.	not applicable	Yes

*For inspection purposes only.
Consent of copyright owner required for any other use.*

ANNEX 1: TABLES / ATTACHMENT

Attachment	Description
A1 Map 1	1:50,000 Location Map
A1 Map 2	Site Location of WWTP
A1 Map 3	Wastewater Treatment Plant – Site Layout
B1 Map 4	Agglomeration
B2 Map 5	Layout of Waste Water Treatment Plant
B3 Map 6	Location of Primary Discharge Point
B3 Map 7	Location of Sampling Points
B4	Not Applicable
B5	Not Applicable
B6	Part VIII
B7	Not Applicable
B8 Map 8	Location of Site Notice
B8	Notice & Advertisement
B10	Not Applicable
B 11	Not Applicable
B 12	Not Applicable
C1 Map 9	Layout Wastewater Treatment Plant
C1 Drg 1	Schematic of Wastewater Treatment Plant
C2	Not Applicable
D1	Inlet monitoring Results
Section D2	Discharge Points
E2	Not Applicable
Section E3	Monitoring & Sampling Points
E4	Sampling Results
F1	Not Applicable
F2	Not Applicable
G1	Not Applicable
G2	Not Applicable
G3	Not Applicable
G4	Not Applicable

WWD Licence Application Annex I

Parameter	Results (µg/l)				Sampling method	Limit of Quantitation	Analysis method / technique
	21/04/09	19/05/09					
Atrazine					Grab	0.96	HPLC
Dichloromethane					Grab	1	GC-MS1
Simazine					Grab	0.01	HPLC
Toluene					Grab	0.02	GC-MS1
Tributyltin					Grab	0.02	GC-MS1
Xylenes					Grab	1	GC-MS1
Arsenic					Grab	0.96	ICP-MS
Chromium	< 20	< 20			Grab	20	ICP-OES
Copper	< 20	< 20			Grab	20	ICP-OES
Cyanide					Grab	5	Colorimetric
Flouride					Grab	100	ISE
Lead	< 20	< 20			Grab	20	ICP-OES
Nickel	< 20	< 20			Grab	20	ICP-OES
Zinc	< 20	< 20			Grab	20	ICP-OES
Boron	< 20				Grab	20	ICP-OES
Cadmium	< 20	< 20			Grab	20	ICP-OES
Mercury					Grab	0.2	ICP-MS
Selenium					Grab	0.74	ICP-MS
Barium	= 20	< 20			Grab	20	ICP-OES

Additional Comments:	TBT value is 0.02ug/l as Sn TBT analysis not required
----------------------	--

For inspection purposes only.
Consent of copyright owner required for any other use.

Annex 2: Check List For Regulation 16 Compliance

Regulation 16 of the waste water discharge (Authorisation) Regulations 2007 (S.I. No. 684 of 2007) sets out the information which must, in all cases, accompany a discharge licence application. In order to ensure that the application fully complies with the legal requirements of regulation 16 of the 2007 Regulations, all applicants should complete the following.

In each case, refer to the attachment number(s), of your application which contains(s) the information requested in the appropriate sub-article.

Regulation 16(1) In the case of an application for a waste water discharge licence, the application shall -		Attachment Number	Checked by Applicant
(a)	give the name, address, telefax number (if any) and telephone number of the applicant (and, if different, of the operator of any treatment plant concerned) and the address to which correspondence relating to the application should be sent and, if the operator is a body corporate, the address of its registered office or principal office,	B .1	Yes
(b)	give the name of the water services authority in whose functional area the relevant waste water discharge takes place or is to take place, if different from that of the applicant,	not applicable	Yes
(c)	give the location or postal address (including where appropriate, the name of the townland or townlands) and the National Grid reference of the location of the waste water treatment plant and/or the waste water discharge point or points to which the application relates,	B.2	Yes
(d)	state the population equivalent of the agglomeration to which the application relates,	B.9	Yes
(e)	specify the content and extent of the waste water discharge, the level of treatment provided, if any, and the flow and type of discharge,	C,D	Yes
(f)	give details of the receiving water body, including its protected area status, if any, and details of any sensitive areas or protected areas or both in the vicinity of the discharge point or points likely to be affected by the discharge concerned, and for discharges to ground provide details of groundwater protection schemes in place for the receiving water body and all associated hydrogeological and geological assessments related to the receiving water environment in the vicinity of the discharge.	F.1	Yes
(g)	identify monitoring and sampling points and indicate proposed arrangements for the monitoring of discharges and, if Regulation 17 does not apply, provide details of the likely environmental consequences of any such discharges,	E.2, E.3	Yes
(h)	in the case of an existing waste water treatment plant, specify the sampling data pertaining to the discharge based on the samples taken in the 12 months preceding the making of the application,	E.4	Yes
(i)	describe the existing or proposed measures, including emergency procedures, to prevent unintended waste water discharges and to minimise the impact on the environment of any such discharges,	G.3	Yes
(j)	give particulars of the nearest downstream drinking water abstraction point or points to the discharge point or points,	not applicable	Yes
(k)	give details, and an assessment of the effects, of any existing or proposed emissions on the environment, including any environmental medium other than those into which the emissions are, or are to be made, and of proposed measures to prevent or eliminate or, where that is not practicable, to limit any pollution caused in such discharges,	F.1	Yes
(l)	give detail of compliance with relevant monitoring requirements and treatment standards contained in any applicable Council Directives of Regulations,	E.1, E.4	Yes
(m)	give details of any work necessary to meet relevant effluent discharge standards and a timeframe and schedule for such work.	not applicable	Yes
(n)	Any other information as may be stipulated by the Agency.	not applicable	Yes
Regulation 16(3) Without prejudice to Regulation 16 (1) and (2), an application for a licence shall be accompanied by -		Attachment Number	Checked by Applicant
(a)	a copy of the notice of intention to make an application given pursuant to Regulation 9,	B.8	Yes
(b)	where appropriate, a copy of the notice given to a relevant water services authority under Regulation 13,	not applicable	Yes
(c)	Such other particulars, drawings, maps, reports and supporting documentation as are necessary to identify and describe, as appropriate -	B	Yes
(c) (i)	the point or points, including storm water overflows, from which a discharge or discharges take place or are to take place, and	B.3, B.4, B.5	Yes
(c) (ii)	the point or points at which monitoring and sampling are undertaken or are to be undertaken,	E.3	Yes
(d)	such fee as is appropriate having regard to the provisions of Regulations 38 and 39.	B.9	Yes

Regulation 16(4) An original application shall be accompanied by 2 copies of it and of all accompanying documents and particulars as required under Regulation 16(3) in hardcopy or in an electronic or other format as specified by the Agency.		Attachment Number	Checked by Applicant
1	An Original Application shall be accompanied by 2 copies of it and of all accompanying documents and particulars as required under regulation 16(3) in hardcopy or in electronic or other format as specified by the agency.		Yes
Regulation 16(5) For the purpose of paragraph (4), all or part of the 2 copies of the said application and associated documents and particulars may, with the agreement of the Agency, be submitted in an electronic or other format specified by the Agency.		Attachment Number	Checked by Applicant
1	Signed original.		Yes
2	2 hardcopies of application provided or 2 CD versions of application (PDF files) provided.		Yes
3	1 CD of geo-referenced digital files provided.		Yes
Regulation 17 Where a treatment plant associated with the relevant waste water works is or has been subject to the European Communities (Environmental Impact Assessment) Regulations 1989 to 2001, in addition to compliance with the requirements of Regulation 16, an application in respect of the relevant discharge shall be accompanied by a copy of an environmental impact statement and approval in accordance with the Act of 2000 in respect of the said development and may be submitted in an electronic or other format specified by the Agency		Attachment Number	Checked by Applicant
1	EIA provided if applicable	not applicable	Yes
2	2 hardcopies of EIS provided if applicable.	not applicable	Yes
3	2 CD versions of EIS, as PDF files, provided.	not applicable	Yes

For inspection purposes only.
Consent of copyright owner required for any other use.

ANNEX 1: TABLES / ATTACHMENT

Attachment	Description
A1 Map 1	1:50,000 Location Map
A1 Map 2	Site Location of WWTP
A1 Map 3	Wastewater Treatment Plant – Site Layout
B1 Map 4	Agglomeration
B2 Map 5	Layout of Waste Water Treatment Plant
B3 Map 6	Location of Primary Discharge Point
B3 Map 7	Location of Sampling Points
B4	Not Applicable
B5	Not Applicable
B6	Part VIII
B7	Not Applicable
B8 Map 8	Location of Site Notice
B8	Notice & Advertisement
B10	Not Applicable
B 11	Not Applicable
B 12	Not Applicable
C1 Map 9	Layout Wastewater Treatment Plant
C1 Drg 1	Schematic of Wastewater Treatment Plant
C2	Not Applicable
D1	Inlet monitoring Results
Section D2	Discharge Points
E2	Not Applicable
Section E3	Monitoring & Sampling Points
E4	Sampling Results
F1	Not Applicable
F2	Not Applicable
G1	Not Applicable
G2	Not Applicable
G3	Not Applicable
G4	Not Applicable