

*Extract from the 594th Licensing Meeting of the Agency, held on 6<sup>th</sup> October 2009, in Headquarters, Johnstown Castle Estate, Co Wexford*

3. **Waste Water Discharge Licence Application**

(iii) *Licensee:* **Cork County Council  
Northern Division  
Annabella  
Mallow  
Co Cork**

*Agglomeration:* **Watergrasshill and Environs**

*Register of Licence No:* **D0201-01**

The Directors considered a recommendation from the Office of Climate, Licensing and Resource Use that the Agency approve the recommended decision to grant a Waste Water Discharge Licence. The following documentation was submitted: Recommended Licence and summary report of the Inspector.

A copy of the licence application was available electronically.

F Clinton gave a verbal presentation.

**Inspector's Report**

The Directors noted the Inspector's Report.

**Recommended Licence**

***Introduction***

3<sup>rd</sup> Paragraph: Delete final sentence.

4<sup>th</sup> Paragraph: Delete final four sentences.

5<sup>th</sup> Paragraph: Amend to read - *The primary discharge SW-01 WGH is to the River Flesk (South Branch) via a 300mm concrete open pipe which discharges to an open drain, 3m in length, before it enters the river. The River Flesk (south branch) joins the main River Flesk circa 1.5km downstream. The main River Flesk joins the River Bride approximately 8km downstream of the discharge point of the WWTP. There is one storm water overflow (SW-02 WGH) in the agglomeration. There are two pumping stations within the agglomeration located at Ard Cashel and Priory Court Housing Estate. There are no overflows associated with the private pumping stations in the agglomeration.*

***Glossary***

Clarify the appropriate Fisheries Board.

***Condition***

4.14 Amend this condition to instruct the licensee to carry out monthly influent monitoring.

4.16 OEE to clarify the requirement for a risk assessment.

6.2 Clarify the appropriate Fisheries Board.

6.3 Clarify and reword this condition to make it more specific regarding the discharge.

***Schedule***

A.1 *Primary Waste Water Discharge*

Delete the kg/day column under the heading Emission Limit Value.

D *Annual Environmental Report Content*

Amend the 9<sup>th</sup> line to read: *Storm water overflow identification and inspection report*

Delete the 10<sup>th</sup> line – Storm Water Overflow assessment of compliance.

Following discussion, the Directors approved the recommended decision to grant a licence, as modified, to Cork County Council for the waste water discharge relating to the Watergrasshill and Environs agglomeration, Register of Licence No D0201-01, subject to the conditions as set out in the licence document.

*Extract from the 595th Licensing Meeting of the Agency, held on 13<sup>th</sup> October 2009,  
in Headquarters, Johnstown Castle Estate, Co Wexford*

2. **Minutes of Meeting held on 6 October 2009**

The Minutes of the Meeting held on 6 October 2009 were approved with the following amendments to the Waste Water Discharge Licence Application relating to Item 3(iii) Cork County Council, Register of Licence No D0201-01:

**Recommended Licence**

*Introduction*

Amend final sentence of the 5<sup>th</sup> Paragraph to read: *There are no overflows associated with the pumping stations in the agglomeration.*

It was confirmed that all of the matters for clarification raised at the meeting had been clarified to the satisfaction of the Board.

