



Ms Claire Downey
Project Co-Ordinator
Indaver Ireland (Branch of Indaver NV)
4 Haddington Terrace
Dun Laoghaire
Co Dublin

Regional Inspectorate
Rackhamsey House, Bow View,
Corkswater Road, Dublin 14, Ireland
Cúlaeach: Beigíní, Leach Mhac Chumascaigh
Dún Rúinín - Búirín Chéin Seach
Sáirínín, Clúth 14, Éire
T: +353 1 268 0100
F: +353 1 268 0100
E: info@epa.ie
W: www.epa.ie
Local: 1890 33 55 33

2nd June 2010

Reg. No. W0167-02

re: Notice in accordance with Article 14(2)(b)(ii) of the Waste Management (Licensing) Regulations

Dear Ms Downey,

I am to refer to the above referenced application for a revised waste licence relating to the Indaver Ireland Waste Management Facility at Carranstown, Duleek, Meath. Having examined the Article 12 and Article 13 responses received on 31/12/2009, you are now requested to provide the following information:

1. With reference to Table 12.b *Revised Table H.1(c) Showing Expected Waste Types and Quantities* of the Article 12 response, please provide the following:
 - (i) A list of wastes (by EWC code) to be accepted at the facility for incineration;
 - (ii) A separate list of wastes (by EWC code) to be accepted at the facility for treatment other than incineration;
 - (iii) Please explain footnotes c, d and e to the table; and
 - (iv) Clarify whether construction and demolition waste is to be accepted at the facility, and if so, for what purpose.
2. With reference to Chapter 11 of the 2009 EIS, please clarify the fire-water retention facility sizing calculations. Drawing No. 18081/WI/006 *Proposed Site Drainage Layout* shows a 600m³ fire-water retention tank, while section 11.5 of the EIS refers to 300m³ fire-water retention volume. Please clarify.
3. Clarify the proposed storage capacity (m³) for bottom ash in the ash handling building.



Please supply the information in the form of a one (1) original plus one (1) copy in hardcopy format within **2 weeks** of the date of this notice. In addition submit sixteen (16) copies of the requested information to the Agency in electronic searchable PDF format on CD-ROM. Please note that all maps/drawings should not exceed A3 in size.

Please note that the application's register number is **W0167-02**. Please direct all correspondence in relation to this matter to *Administration, Environmental Licensing Programme, Office of Climate, Licensing & Resource Use, Environmental Protection Agency, Headquarters, PO Box 3000, Johnstown Castle Estate, County Wexford* quoting the register number.

Yours sincerely,

A handwritten signature in cursive script, reading 'Aoife Loughhane', is written over a horizontal line.

Aoife Loughhane
Inspector
Office of Climate, Licensing & Resource Use