

***Extract from the Minutes of the 623rd Licensing Meeting of the  
Environmental Protection Agency, held on 20 July 2010  
at Headquarters, Johnstown Castle Estate, Co Wexford***

6. **Waste Water Discharge Licence Application**  
*Licensee:* **Cork County Council  
Southern Division  
County Hall  
Carrigrohane Road  
Cork**  
*Agglomeration:* **Cloyne**  
*Register of Licence No:* **D0298-01**

The Directors considered a recommendation from the Office of Climate, Licensing and Resource Use that the Agency approve the recommended decision to grant a Waste Water Discharge Licence. The following documentation was submitted: Recommended Licence; one third party submission; and summary Report of the Inspector.

A copy of the licence application was available electronically.

Frank Clinton gave a verbal presentation.

**Inspector's Report**

The Directors noted the Inspector's Report.

**Recommended Licence**

**Condition**

- 4.11** Insert a new condition 4.11 requiring a feasibility study on the relocation of the outfall to the sea at Ballycotton to be submitted as part of the second AER. If the results of the study indicate that the relocation of the outfall is feasible, then this should be added to the Programme of Improvements under Condition 5.  
Re-number existing and subsequent conditions accordingly.
- 5.2 (a)(i)** Amend to read: the existing level of treatment, capacity of treatment plant and associated equipment *including reed bed (constructed wetland)*;
- 5.7** Amend 1<sup>st</sup> sentence to read: Where the assessment ... .... the licensee shall install UV disinfection, *other appropriate disinfection systems or alternative proposals for the relocation of the discharge.*

Following discussion, the Directors approved the recommended decision to grant a licence, as modified, to Cork County Council for the waste water discharge relating to the Cloyne agglomeration, Register of Licence No D0298-01, subject to the conditions as set out in the licence document.