




Office of Licensing & Guidance
PO Box 3000
Johnstown Castle Estate
Co Wexford
28.10.09



RE: Technical Amendment to Waste License W0054-02.

To Whom It May Concern,

I wish to request technical amendment to Schedule C.1 (Emissions to Sewer) of Waste License W0054-02.

Please find attached revised limits from Dublin City Council Engineering Department.

Hoping that this meets your requirements and should you require further information please do not hesitate to contact me.

Kind Regards,

Joe Mahon,
Eco-Safe Systems Ltd

Eco-Safe Systems Ltd.

Unit 1a Allied Industrial Estate, Kylemore Road, Dublin 10

Ph: +353 1 6239135 Fax: +353 1 6239136

Email: services@srcl.com . www.ecosafesystems.ie

A SRCL® Company – Protecting People. Reducing Risk™

For inspection purposes only.
Consent of copyright owner required for any other use.



Mr Joe McMahon,
Eco-Safe Systems,
Unit 1a Allied Industrial Estate
Kilmore Road,
Dublin 10

Engineering Department
Drainage Division
Floor 2, Block 1
Civic Offices
Fishamble Street
Dublin 8
Tel: 353-1-2222090
Fax: 353-1-2222300
Website: www.dublincity.ie

Date: 11th August 2009

Re: EPA Waste Licence 54-2

Dear Joe,

I refer to your correspondence of 11-08-09 requesting a raising of the allowable discharge limits for the parameters Biochemical Oxygen Demand and Chemical Oxygen Demand and Flow in the consent given by Dublin City Council for EPA Waste Licence 54-2.

After consideration of your request I wish to inform you that Dublin City Council has no objection to new limits as follows

| Parameter | Emission | | Limit Value | |
|------------------|--------------|--------|---------------------------------|-----------------------------|
| | Grab Sample | (mg/l) | Daily Mean Concentration (mg/l) | Daily Mean Loading (kg/day) |
| B.O.D. | 5,000 | | 4,000 | 100.0 |
| C.O.D. | 15,000 | | 12,000 | 300.0 |
| Suspended Solids | 500 | | 400 | 10.0 |
| Sulphates(asSO4) | 1,000 | | 1,000 | 25.0 |
| Ph | 6-10 | | 6-10 | |
| Temperature | 42 degrees C | | | |

Roinn Innealtóireachta
Rannóg Draenála
Urlár 2, Bloc 1
Oifigi na Cathrach
Sráid Sheamais an Eisc
Baile Átha Cliath 8
Tel: 353 1-6722155
Fac: 353-1-6790809
Idirlíne: www.dublincity.ie


The loadings are based on a maximum flow rate of 25 cubic metres per day.

As the flow rate has now been increased I would request that you send monthly discharged flow readings to this office.

Yours Sincerely


Martin Ryan.

Senior Engineer


This matter is being dealt with by Mr. John Collins (a 2222090)

For inspection purposes only.
Consent of copyright owner required for any other use.