


## DECISION

<b>To: Laura Burke</b>		<b>Date:</b>
<b>D0329-01</b>	<b>Cork County Council</b>	<b>Agglomeration Name: <u>Killeens</u></b>
<b>Re: Final Decision on an application for a Waste Water Licence</b>		
<b>FD:</b> I have considered the application and the report of the Inspector in relation to the above referenced application.		
<p><del>I approve of the recommendation as submitted</del> <b>Or (delete as appropriate)</b> <del>I do not approve the recommendation as submitted</del> <b>Or (delete as appropriate)</b> <del>I am forwarding the recommendation as submitted to the Sub-Board of the Agency for decision</del> <b>Or (delete as appropriate)</b> I approve the recommendation as submitted subject to the following changes:</p> <p>&lt;&lt; Insert Changes &gt;&gt;     <i>CLARIFY AN APPROPRIATE ELU FOR AMMONIA UNDER SCHEDULE A, PRIOR TO JULY 2019.</i></p>		
Signed: 		Dated: <sup>12</sup> <del>06</del> /01/2011
<b>Laura Burke, Director, Office of Climate, Licensing &amp; Resource Use</b>		

## Maire Buckley

---

**Subject:** FW: D0329-01 Killeens

**From:** Stuart Huskisson  
**Sent:** 19 January 2011 12:53  
**To:** Maire Buckley  
**Subject:** FW: D0329-01 Killeens

**From:** Laura Burke  
**Sent:** 19 January 2011 12:49  
**To:** Stuart Huskisson  
**Subject:** RE: D0329-01 Killeens

Stuart, that's fine

thanks

Best Regards

Laura Burke  
Environmental Protection Agency

**From:** Stuart Huskisson  
**Sent:** 19 January 2011 12:46  
**To:** Laura Burke  
**Subject:** FW: D0329-01 Killeens

Hi Laura,

As the Killeens WWTP does not provide nitrification/denitrification the plant does not control the ammonia discharge.

Therefore, based on the current emission concentrations it is appropriate to set the ammonia ELV at 35mg/l until 30<sup>th</sup> June 2019.

I trust this addresses the requested clarification.

Regards  
Stuart