



Mr. Niall O'Mahony
 Cork County Council
 Water Services (Western Division)
 Courthouse
 Skibbereen
 County Cork

Headquarters, PO Box 3000
 Johnstown Castle Estate
 County Wexford, Ireland
 Ceannteathrú, Bosca Post 3000
 Easáit Chaisleán Bhaile Sheáin
 Contae Loch Garman, Éire
 T: +353 53 916 0600
 F: +353 53 916 0699
 E: info@epa.ie
 W: www.epa.ie
 10Call: 1890 33 55 99

31 January 2011

re: Notice in accordance with Regulation 25(c)(ii) of the Waste Water Discharge (Authorisation) Regulations 2007

Dear Mr. O'Mahony

I am to refer to the applications for a waste water discharge certificate of authorisation relating to the agglomerations named:

Sherkin Island	A0404-01
Ring	A0401-01

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 24 of the Waste Water Discharge (Authorisation) Regulations 2007.

You are therefore requested, in accordance with Regulation 25(c)(ii) of the regulations, to take the steps to supply the information detailed below for **each** of the above named agglomerations.

REGULATION 24 COMPLIANCE REQUIREMENTS

1. Provide an assessment of the likelihood of significant effects of the waste water discharges from the above agglomerations on the relevant European sites by referring to Circular L8/08 'Water Services Investment and Rural Water Programmes – Protection of Natural Heritage and National Monuments' issued by the Department of Environment, Heritage and Local Government. In particular, the flow diagram in Appendix 1 should be completed and the results of each section recorded. Provide details of the results of this assessment by **18 February 2011**.

If significant effects are likely then an appropriate assessment must be carried out and a report of this assessment forwarded to the Agency by **18 February 2011**.

Your reply to this notice should include a revised non-technical summary which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information in the form of a one original plus one copy by **18 February 2011**. In addition please submit one copy of the requested information in electronic searchable PDF format on a CD-ROM (no file to exceed 10MB) to the Agency. Please note that all maps/drawings should not exceed A3 in size.

Please direct all correspondence in relation to this matter to *Administration, Environmental Licensing Programme, Office of Climate, Licensing & Resource Use, Environmental Protection Agency, Headquarters, PO Box 3000, Johnstown Castle Estate, County Wexford* quoting the register number.

Yours sincerely,



Yvonne English

Inspector

Office of Climate, Licensing & Resource Use