


Scanned

7 FEB 2011

edms

Open Web Doc

Initials: **ld**



OFFICE OF CLIMATE,
LICENSING & RESOURCE USE.

**INSPECTORS REPORT ON A WASTE WATER DISCHARGE
CERTIFICATE OF AUTHORISATION APPLICATION**

To: Frank Clinton, Programme Manager, ELP

From: Yvonne English

**Environmental Licensing
Programme**

Date: 20 January 2011

RE: Application for a Waste Water Discharge Authorisation from Monaghan County Council, for the agglomeration named Carrickroe, Reg. No. A0034-01.

Application Details	
Schedule of Discharge Authorised:	Discharges from agglomerations with a population equivalent less than 500
Certificate of Authorisation Application Received:	21 December 2009
Submission(s) Received:	No

This application relates to the Carrickroe agglomeration in County Monaghan. The agglomeration currently has a population equivalent (p.e.) of 80. The agglomeration is serviced by one waste water treatment plant (WWTP). The WWTP provides tertiary treatment, consisting of primary settlement tanks, rotating biological contactors, a final settling tank and reed beds, and has a design capacity of 150 p.e. The WWTP discharges to an unnamed stream which is a tributary of the Blackwater River.

There are no designated or protected areas (i.e., drinking water abstractions, bathing waters, shellfish waters, salmonid waters or *Margaritifera margaritifera*) downstream of the discharge(s) from the agglomeration. Condition 3.3 of the Recommended Certificate of Authorisation (RCoA) states that the discharge(s) from the waste water works shall not cause a deterioration in the status of the receiving surface water body.

The certificate of authorisation applicant was required to complete a screening of the potential impact of the discharge(s) from the agglomeration on the designated European Site(s) downstream of the agglomeration. The certificate of authorisation applicant carried out a screening which identified that the discharge(s) were not likely to have a significant impact on a European site.

The RCoA states that within twelve months the authorisation holder shall identify appropriate improvements to the wastewater works, including a waste water treatment system necessary to ensure all discharge(s) from the agglomeration contribute towards achieving at least good status in accordance with the European Communities Environmental Objectives (Surface Waters) Regulations 2009 and/or the European Communities Environmental Objectives (Groundwater) Regulations 2010.

The discharge(s) from the agglomeration are considered not likely to have a significant impact on the receiving waterbody subject to the Certificate of Authorisation Holder complying with the conditions of the RCoA.

Recommendation

I recommend that a Final Certificate of Authorisation be issued subject to the conditions and for the reasons as set out in the attached Recommended Certificate of Authorisation.

Signed

C. Foley

Yvonne English

Inspector

Office of Climate, Licensing and Resource Use