



OFFICE OF CLIMATE,
LICENSING & RESOURCE
USE.

**INSPECTORS REPORT ON A WASTE WATER DISCHARGE
CERTIFICATE OF AUTHORISATION APPLICATION**

To:	Frank Clinton, Programme Manager, ELP		
From:	Yvonne English	Environmental Programme	Licensing
Date:	07 April 2011		
Re:	Application for a Waste Water Discharge Authorisation from Cork County Council, for the agglomeration named Rosemount, Kilcully, Reg. No. A0351-01.		

Application Details	
Schedule of Discharge Authorised:	Discharges from agglomerations with a population equivalent less than 500
Certificate of Authorisation Application Received:	23 November 2010
Submission(s) Received:	No

This application relates to the Rosemount, Kilcully agglomeration in County Cork. The agglomeration currently has a population equivalent (p.e.) of 100. The agglomeration is serviced by one waste water treatment plant (WWTP). The WWTP provides secondary treatment, consisting of settlement, aeration and percolation bed, and has a design capacity of 100 p.e.

The WWTP discharges to ground. Based on the nearest EPA water quality monitoring station, the ground water was classified as good status in 2009.

Based on the certificate of authorisation application submitted the current waste water treatment plant for the agglomeration is at capacity. The Recommended Certificate of Authorisation (RCoA) states that within twelve months the authorisation holder shall identify appropriate improvements to the wastewater works, including a waste water treatment system necessary to ensure all discharge(s) from the agglomeration contribute towards achieving at least good status in accordance with the European Communities Environmental Objectives (Surface Waters) Regulations 2009 and/or the European Communities Environmental Objectives (Groundwater) Regulations 2010.


The certificate of authorisation applicant was required to complete a screening of the potential impact of the discharge(s) from the agglomeration on the designated European Site(s) downstream of the agglomeration. The certificate of authorisation applicant carried out a screening which identified that the discharge(s) was not likely to have a significant impact on a European site.

The discharge(s) from the agglomeration are considered not likely to have a significant impact on the receiving waterbody subject to the Certificate of Authorisation Holder complying with the conditions of the RCoA.

Recommendation

I recommend that a Final Certificate of Authorisation be issued subject to the conditions and for the reasons as set out in the attached Recommended Certificate of Authorisation.

Signed



Yvonne English

Inspector

Office of Climate, Licensing and Resource Use