



**OFFICE OF CLIMATE,
LICENSING & RESOURCE USE.**

INSPECTORS REPORT ON A WASTE WATER DISCHARGE CERTIFICATE OF AUTHORISATION APPLICATION

To:	Frank Clinton, Programme Manager, ELP		
From:	Yvonne English	Environmental Programme	Licensing
Date:	7 April 2011		
Re:	Application for a Waste Water Discharge Authorisation from Cork County Council, for the agglomeration named Garryvoe, Reg. No. A0363-01.		

Application Details	
Schedule of Discharge Authorised:	Discharges from agglomerations with a population equivalent less than 500
Certificate of Authorisation Application Received:	23 November 2010
Submission(s) Received:	No

This application relates to the Garryvoe agglomeration in County Cork. The agglomeration currently has a population equivalent (p.e.) of 466. The agglomeration is serviced by one waste water treatment plant (WWTP). The WWTP provides primary treatment, consisting of a septic tank, and has a design capacity of 250 p.e.

The WWTP discharges to the Ballycotton Bay. Based on the nearest EPA water quality monitoring station, the coastal water was classified as moderate status in 2009.

Based on the certificate of authorisation application submitted there is currently inadequate treatment in place for the agglomeration. The current waste water treatment plant for the agglomeration is overloaded. The Recommended Certificate of Authorisation (RCoA) states that within twelve months the authorisation holder shall identify appropriate improvements to the wastewater works, including a waste water treatment system necessary to ensure all discharge(s) from the agglomeration contribute towards achieving at least good status in accordance with the European Communities Environmental Objectives (Surface Waters) Regulations 2009 and/or the European Communities Environmental Objectives (Groundwater) Regulations 2010.

There is a designated bathing water located in the vicinity of the discharge(s) from the agglomeration. The RCoA includes a condition whereby the Certificate of Authorisation holder shall ensure that the discharge(s) from the agglomeration shall not cause a deterioration in the microbiological and physicochemical parameters in the bathing waters.


The certificate of authorisation applicant was required to complete a screening of the potential impact of the discharge(s) from the agglomeration on the designated European Site(s) downstream of the agglomeration. The certificate of authorisation applicant carried out a screening which identified that the discharge(s) was not likely to have a significant impact on a European site.

The discharge(s) from the agglomeration are considered not likely to have a significant impact on the receiving waterbody subject to the Certificate of Authorisation Holder complying with the conditions of the RCoA.

Recommendation

I recommend that a Final Certificate of Authorisation be issued subject to the conditions and for the reasons as set out in the attached Recommended Certificate of Authorisation.

Signed



Yvonne English
Inspector

Office of Climate, Licensing and Resource Use