

# APPENDIX 2

**Monitoring results for  
Ballinode WwTP May 2009 to date.  
D0435-01**

*For inspection purposes only.  
Consent of copyright owner required for any other use.*

EntryName	PlantID	Influent Or Effluent	Date of Sampling	Sample Type (C or G)	Total P mg/l P	Ortho P mg/l P	Total N mg/l N	NH3-N mg/l N	TKN mg/l N	
Ballinode	704	Effluent	20/10/2010	C	3.7	26	4	0.78	8.05	0.27
Ballinode	704	Effluent	23/03/2010	C	4	39	4	0.85	10.2	3.12
Ballinode	704	Effluent	28/04/2010	C	2	47	15	0.492	11.58	11.66
Ballinode	704	Effluent	05/08/2010	C	2	31	3	0.45	14.7	1.3
Ballinode	704	Effluent	24/08/2010	C	2	28	3	0.548	16.85	0.866
Ballinode	704	Effluent	20/10/2010	C	2	21	4	2.14	16.29	0.289
Ballinode	704	Effluent	14/12/2010	C	2	25	8	0.621	28.7	0.128
Ballinode	704	Effluent	09/03/2011	C	8	32	5	1.484	16.54	7.36
Ballinode	704	Effluent	13/04/2011	C	5	30	12	2.05	16.69	8.06
Ballinode	704	Effluent	29/06/2011	C	2	34	2	2.721	17.49	0.972
Ballinode	704	Effluent	21/06/2011	C	11	47	10	5.317	19.32	4.06
Ballinode	704	Effluent	20/07/2011	C	7	32	12	5.497	18.52	2.65
Using 12 latest samples averages for data for EPA response										
Section F	AVERAGE				4.23	32.67	6.83	1.91	16.24	3.39

For inspection purposes only. Consent of copyright owner required for any other use.

