

***Extract from the Minutes of the 687<sup>th</sup> Licensing Meeting of the  
Environmental Protection Agency, held on 7 February 2012  
at Headquarters, Johnstown Castle Estate, Co Wexford***

1. The 687<sup>th</sup> Licensing Meeting of the Agency was held on 7 February 2012, in EPA Headquarters, Johnstown Castle Estate, Co. Wexford.

Directors Present: L Burke (Chair) (Video Conference – Richview).  
M Crowe; D Lynott; M Ó Cinnéide.

2. **Minutes of Meeting held on the 31 January 2012**

The Minutes of the Meeting held on the 31 January 2012 were approved subject to the following amendment to Item 4;

*Licensee:* **Murray Waste Recycling Limited  
Coolatore  
Ferns  
County Wexford**

*Register of Licence No:* **W0258-01**

Delete Conditions 3.21.1; 3.21.2; & 3.21.3, and replace with the following;

- 3.21.1** *The licensee shall carry out a risk assessment to determine if the activity should have a fire-water retention facility. The licensee shall submit the assessment and a report to the Agency on the findings and recommendations of the assessment within six months of the date of grant of this licence.*
- 3.21.2** *In the event that a significant risk exists for the release of contaminated fire-water, the licensee shall, based on the findings of the risk assessment, prepare and implement, with the agreement of the Agency, a suitable risk management programme. The risk management programme shall be fully implemented within three months of date of notification by the Agency.*
- 3.21.3** *In the event of a fire or a spillage to storm water, the site storm water shall be diverted to the containment pond. The licensee shall examine, as part of the response programme in Condition 3.21.2 above, the provision of automatic diversion of storm water to the containment pond. The licenses shall have regard to any guidelines issued by the Agency with regard to firewater retention.*
- 3.21.4** *The licensee shall have regard to the Environmental Protection Agency Draft Guidance Note to Industry on the Requirements for Fire-Water Retention Facilities when implementing Conditions 3.21.1 and 3.21.2 above.*

It was confirmed that all matters for clarification raised at the meeting had been clarified to the satisfaction of the Board.