

***Extract from the Minutes of the 696th Licensing Meeting of the
Environmental Protection Agency, held on 22 May 2012
at Headquarters, Johnstown Castle Estate, Co Wexford***

1. The 696th Licensing Meeting of the Agency was held on 22 May 2012, in EPA Headquarters, Johnstown Castle Estate, Co. Wexford.

Directors Present: L Burke (Chair).
M Crowe; D Lynott; M Ó Cinneide; G O'Leary.

6. **Waste Water Discharge Licence Application**

Licensee: **Cork County Council (southern Division)
County Hall
Carrigrohane Road
Cork
County Cork**

Agglomeration: **Youghal**

Register of Licence No: **D0139-01**

The Directors considered a recommendation from the Office of Climate, Licensing and Resource Use that the Agency approve the recommended decision to grant a Waste Water Discharge Licence. The following documentation was submitted: Recommended Licence; 3 submissions received and the summary report of the Inspector dated 17 May 2012.

A copy of the licence application was available electronically.

Karen Creed gave a verbal presentation.

Inspector's Report

The Directors noted the Inspector's Report.

Recommended Licence

Conditions

5.6.2 Amend the first sentence of the Condition as follows; 'The licensee shall, within
... of licence, *unless otherwise agreed by the Agency*, implement all
identified in Condition 5.6.1.'

5.6.3 Amend the first sentence of the Condition as follows; 'The licensee shall, within
... of licence, *unless otherwise agreed by the Agency*, submit a report the
waste water works.

Schedule

Schedule C.1 Improvement Programme for Primary Discharge

Insert new Specified Improvements as follows;

Specified Improvement	Completion Date
New waste water treatment plant (with denitrification) and ancillary works	31 st December 2015
Upgrade of drainage network	31 st December 2015
Upgrade of Summerfield and Strand Pumping Station, plus installation of a new pumping station at	31 st December 2015

Green Park	
Decommissioning of Cork Hill comminutor station	31 st December 2015
Upgrade of Frond Strand storm water holding tank	31 st December 2015
<i>Work to be completed as per Condition 5.6</i>	<i>Within 9 months from date of grant of licence unless otherwise agreed by the Agency</i>
Any other works notified in writing by the Agency	As agreed

Schedule C.3 Implementing Programme for Storm Water Overflows

Amend schedule as follows;

Specified Improvement	Completion Date
Upgrade of drainage network	31 st December 2015
Upgrade of the <ul style="list-style-type: none"> • Summerfield Pumping Station (associated with SW010), and • Strand Pumping Station (associated with SW005) 	31 st December 2015
Upgrade of Storm Water Overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows, 1995'	31 st December 2015
Any other overflows notified in writing by the Agency	As agreed

Following discussion, the Directors approved the recommended decision to grant a licence, as modified, to Cork County Council for the waste water discharge relating to the Youghal agglomeration, Register of Licence No D0139-01, subject to the conditions as set out in the licence document.