

Licensing Action - Reg 18(3)(b) Notice Sent - 4 for Ballyclough Licence (D0441-01)

Licence: Ballyclough (D0441-01)

Status Reason: Open

Issued On: 18/04/2013

Due Date: 26/04/2013

Action Type: Licensing Action

Status History Action: Reg 18(3)(b) Notice Sent

Dear Applicant

I refer to your application for a waste water discharge licence relating to agglomeration named Ballyclough.

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007, as amended.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below:

REGULATION 16 COMPLIANCE REQUIREMENTS

Question

Provide the grid reference (easting and northing) of the monitoring point for the primary discharge from the WWTP

Associated Documents

Your reply to this notice should include a revised non-technical summary which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information by 26/04/2013. Please note that all maps/drawings should not exceed A3 in size.

Please direct any queries that you may have in relation to the above to the Inspector Yvonne English or to OCLR Admin Team E.

Yours sincerely

Environmental Licensing Programme

Office of Climate, Licensing & Resource Use

Tel: 053-9160600