

## Licensing Reply - Reg 18(3)(b) Reply Received - 4 for Ballyhooley Licence (D0432-01)

**Licence:** Ballyhooley (D0432-01)

**Status Reason:** Closed

**Issued On:** 25/04/2013

**Action Type:** Licensing Reply

**Status History Action:** Reg 18(3)(b) Reply Received

Dear Applicant

I refer to your application for a waste water discharge licence relating to agglomeration named Ballyhooley.

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007, as amended.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below:

### REGULATION 16 COMPLIANCE REQUIREMENTS

#### Question

Provide a revised drawing clearly detailing the boundary of the agglomeration to which this application relates. Please note that the agglomeration boundary shall include all areas serviced by the sewer network and shall include the wastewater treatment plant. All areas of the agglomeration shall be within the agglomeration boundary.

#### Associated Documents

#### Response

Please find attached, response to the above query which is due today.  
Regards, Gillian Vaughan, Waste Water Liaison, Cork Co. Council.

#### Associated Documents

- Reply to EPA Licensing Action - Reg 18(3)(b) Ballyhooly

Your reply to this notice should include a revised non-technical summary which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information by 25/04/2013. Please note that all maps/drawings should not exceed A3 in size.

Please direct any queries that you may have in relation to the above to the Inspector Eimer Godsil or to OCLR Admin Team E.

Yours sincerely

Environmental Licensing Programme

Office of Climate, Licensing & Resource Use

Tel: 053-9160600

*For inspection purposes only.  
Consent of copyright owner required for any other use.*