

Licensing Reply - Reg 18(3)(b) Reply Received - 4 for Clonakilty and Environs Licence (D0051-01)

Licence: Clonakilty and Environs (D0051-01)

Status Reason: Closed

Issued On: 29/05/2013

Action Type: Licensing Reply

Status History Action: Reg 18(3)(b) Reply Received

Dear Applicant

I refer to your application for a waste water discharge licence relating to agglomeration named Clonakilty and Environs.

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007, as amended.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below:

REGULATION 16 COMPLIANCE REQUIREMENTS

Question

Provide a revised drawing clearly detailing the boundary of the agglomeration to which this application relates. Please note that the agglomeration boundary shall include all areas serviced by the sewer network and shall include the wastewater treatment plant and all wastewater works. All areas of the agglomeration shall be within a single agglomeration boundary.

Associated Documents

Response

Please find attached response to Reg 18(3)(b) for Clonakilty and Environs.
Regards, Gillian O'Sullivan Waste Water Liaison Engineer

Associated Documents

- Clonakilty Reply to Reg 18(3)(b) Notice May 2013.pdf

Your reply to this notice should include a revised non-technical summary which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information by 30/05/2013. Please note that all maps/drawings should not exceed A3 in size.

Please direct any queries that you may have in relation to the above to the Inspector Gavin Clabby or to OCLR Admin Team E.

Yours sincerely

Environmental Licensing Programme

Office of Climate, Licensing & Resource Use

Tel: 053-9160600

*For inspection purposes only.
Consent of copyright owner required for any other use.*