

## Licensing Reply - Reg 18(3)(b) Reply Received - 1 for Ballygarvan Licence (D0540-01)

**Licence:** Ballygarvan (D0540-01)

**Status Reason:** Closed

**Issued On:** 18/06/2013

**Action Type:** Licensing Reply

**Status History Action:** Reg 18(3)(b) Reply Received

Dear Applicant

I refer to your application for a waste water discharge licence relating to agglomeration named Ballygarvan.

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007, as amended.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below:

### REGULATION 16 COMPLIANCE REQUIREMENTS

#### Question

Normal waste water discharge was estimated during site visit at 120m<sup>3</sup>/day – provide average normal waste water discharge per day in m<sup>3</sup>/day.

#### Associated Documents

#### Response

In response to RI000687, the design capacity of Ballygarvan plant is 120m<sup>3</sup>/day but the current average daily flow is 50m<sup>3</sup>/day. Regards, Gillian O'Sullivan, Waste Water Liaison Engineer, Cork Co. Council.

#### Associated Documents

#### Question

Provide date that Ballygarvan Waste Water Treatment Plant was taken in charge by Cork County Council.

#### Associated Documents

#### Response

In response to RI000688, Ballygarvan WWTP was taken in charge by cork Co. Council on January 1st 2011. Regards, Gillian O'Sullivan, Waste Water Liaison Engineer, Cork Co. Council.

#### Associated Documents

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information by 21/06/2013. Please note that all maps/drawings should not exceed A3 in size.

Please direct any queries that you may have in relation to the above to Loretta Joyce or to OCLR Admin Team A.

Yours sincerely

Loretta Joyce

Environmental Licensing Programme

Office of Climate, Licensing & Resource Use

Tel: 01 268 0100

*For inspection purposes only.  
Consent of copyright owner required for any other use.*